

1 Q. **Reference: CA-NLH-099**

2 It is stated *“The use of mobile generation must not be considered a permanent solution in the*
3 *absence of Holyrood T7, as this generation must be available for other unforeseen events on the*
4 *Hydro or Newfoundland Power systems.”* Has this mobile generation been available for
5 unforeseen events during the past two winter periods and will it be available for unforeseen
6 events during the upcoming winter period? Has there been a need for the mobile generation
7 elsewhere during the past two winter periods?

8

9

10 A. The mobile generation referred to as options in the absence of Holyrood T7 are Newfoundland
11 Power Inc.’s (“Newfoundland Power”) mobile GT (located at Blaketown), Newfoundland Power’s
12 mobile diesel (located at Grand Bay), Newfoundland and Labrador Hydro’s black start diesel
13 generation (located at Holyrood) and potential rental options. The mobile generation was
14 available for unforeseen events during the past two winter periods and is available for
15 unforeseen events for the upcoming winter season.

16 For the past two winter periods, there has not been any requirement for this mobile generation
17 to be located elsewhere, nor has there been a requirement for rental options to be employed.