

1 Q. **Reference: 2024 Capital Budget Application (Revision 1), Program 8, Upgrade Power**
2 **Transformers (2024-2025), page 6, Table 1.**

3 Please confirm that there were no sustained forced outages in the years 2018, 2019, 2020, or
4 2021.

5

6

7 A. Newfoundland and Labrador Hydro notes that Table 1 contains an error; this table contains
8 power transformer outages for 2022 only. A listing of sustained forced outages for 2018 to 2022
9 are provided herein.

Table 1: Power Transformer Outages and Durations from 2018 to 2022 (minutes)

Start Date	Transformer	Outage Duration
6-Aug-2022	Grandy Brook T1	241
7-Mar-2022	Bay d'Espoir T5	36,482
28-Apr-2022	Sunnyside T1	5
28-Apr-2022	Sunnyside T4	5
22-Apr-2022	Deer Lake T2	337
21-Mar-2022	Hardwoods T10	1,475
21-Mar-2022	Holyrood T5	1,376
12-Nov-2021	Holyrood T2	87,507
1-Nov-2021	Upper Salmon T1	8,017
3-Aug-2021	Hardwoods T2	430
8-Jul-2021	Oxen Pond T1	3,421
8-Jul-2021	Oxen Pond T2	87
14-Jun-2020	English Harbour West T1	10
23-Apr-2020	St. Anthony Diesel T1	183
17-Jan-2020	Holyrood T2	72
17-Jan-2020	Holyrood T8	75
11-Jan-2020	Rocky Harbour T1	267
30-Nov-2019	Doyles T1	1,160
30-Nov-2019	Doyles T1	254
30-Nov-2019	Voisey's Bay Nickel T1	348
30-Sep-2019	Doyles T1	1,552
19-Jun-2019	Bottom Brook T1	204
20-Mar-2019	Grandy Brook T1	2,603
22-Nov-2018	Bay d'Espoir T3	10
18-Oct-2018	Doyles T1	9
9-Apr-2018	Parson's Pond T1	23
5-Feb-2018	Bear Cove T1	23