

1 Q. **Reference: Schedule 1 2024 Capital Budget Overview, Appendix F, page F-29, lines 4-6**

2 It is stated that foundations in terminal stations are inspected every 120 days during regular  
3 terminal stations inspections.

4 a) Explain how deficiencies in foundations are identified, reported and prioritized for  
5 corrective action.

6 b) Explain when the foundation in Figure 15 was first identified as deteriorating, when first  
7 it was identified as requiring repair, when first scheduled for repair and the date now  
8 scheduled for repair.

9

10

11 A. a) Deficiencies are identified during regular terminal station inspections, which occur every  
12 120 days and include visual inspections of each foundation. Deficiencies identified during  
13 inspections are recorded on an inspection checksheet. These deficiencies are then typically  
14 prioritized for corrective action as required through inclusion in the scope of Newfoundland  
15 and Labrador Hydro's Replace Equipment Foundations capital project.

16 b) Figure 15 is included in the Terminal Station Asset Management Overview as an illustrative  
17 example of terminal station foundation deterioration. The foundation depicted therein was  
18 repaired on February 25, 2016.