

1 Q. **Reference: Schedule 1 2024 Capital Budget Overview, Appendix F, page F-33, lines 9-12**

2 It is stated that Hydro will continue with the replacement of 230kV electromechanical and  
3 obsolete solid-state generator, transformer, line and bus relays as part of the Terminal Station  
4 Renewal Program. However, on page 28, line 21-page 29, line 3 of the 2024 Capital Budget  
5 Overview it is stated that the Terminal Station Renewal Program has been dissolved for the 2024  
6 Capital Budget Application and replaced with programs for specific terminal station assets.  
7 Please list each program in the 2024 Capital Budget application which is intended to replace a  
8 component or part of the previous Terminal Station Renewal Program.

9

10

11 A. Newfoundland and Labrador Hydro (“Hydro”) notes that the reference within Appendix F,  
12 Terminal Station Asset Management Overview to the “Terminal Station Renewal Program” was  
13 made in error. The reference, on page F-33, lines 9-12, should read:

14 As part of its annual Replace Protective Relays Program, Hydro will continue to  
15 execute the replacement of 230 kV electromechanical and obsolete solid-state  
16 generator, transformer, line, and bus relays with modern digital multifunction  
17 relays, which began in 2016 under the Replace Protective Relays – Various Sites  
18 project. [emphasis added]

19 The programs proposed individually that replaced the components of the Terminal Station  
20 Renewal Program are:

- 21 ● Replace Instrument Transformers (2024–2025);
- 22 ● Replace Protective Relays (2024–2025);
- 23 ● Replace Disconnects (2024–2025);
- 24 ● Upgrade Power Transformers (2024-2025); and
- 25 ● Replace Terminal Station Battery Banks and Chargers (2024–2025).