

1 Q. **Reference: 2025 Capital Budget Application, Program 2, Upgrade Worst-Performing**
2 **Distribution Feeders (2025-2027), page 15, Figure 17 and pages A-1 to A-3.**

- 3 a) Please provide a customer count for each downline recloser shown in Figure 17.
- 4 b) Please provide a customer count and peak demand for the feeders in tables A-1 through
5 A-3.

6
7
8 A. a) Table 1 provides a customer count for each downline recloser for the English Harbour West
9 distribution system.

Table 1: Downline Recloser Customer Count

Recloser Name	Customer Count
English Harbour West, Line 1, Recloser 5	91
English Harbour West, Line 1, Recloser 4	125
Proposed Recloser for Belleoram Tap	298
Proposed Recloser for English Harbour West Tap	288

10 b) Table 2 provides a customer count and peak demand for the requested feeders.

Table 2: Customer Count and Peak Demand for Various Feeders

Feeder	Customer Count	Peak Demand (MW)
Barachoix, Line 1	563	2.6
Barachoix, Line 4	808	4.9
Bay d'Espoir, Line 1	1276	7.1
Bear Cove, Line 6	675	3.8
Black Tickle, Line 1	94	0.3
Bottom Waters, Line 1	375	4
Bottom Waters, Line 2	7	4
Bottom Waters, Line 3	190	2.9
Bottom Waters, Line 4	455	1.6
Cartwright, Line 1	328	0.9
English Harbour, Line 1	802	3
Farewell Head, Line 1	244	6.8
Farewell Head, Line 4	412	1.3
Farewell Head, Line 5	663	2.2
Farewell Head, Line 6	504	2.4
Fleur-de-Lys, Line 1	185	0.6
Happy Valley, Line 1	107	7.2
Happy Valley, Line 15	359	12.2
Happy Valley, Line 6	431	2.9
Happy Valley, Line 7	963	13.6
Hawke's Bay, Line 3	982	5.3
Jackson's Arm, Line 2	299	1
Kings Point, Line 1	588	2
L'Anse-au-Loup, Line 1	436	5.9 ¹
L'Anse-au-Loup, Line 2	618	3.2
Main Brook, Line 2	65	0.2
Monkstown, Line 2	60	0.1
Rocky Harbour, Line 1	765	3.3
Roddickton, Line 1	549	1.3
South Brook, Line 1	902	2.2
St. Anthony, Line 1	658	3.2
St. Anthony, Line 7	178	0.5
St. Brendan's, Line 1	151	0.3

¹ Note that this value assumes that the Hydro-Québec Interconnection is in service.