

1 Q. **Reference: 2025 Capital Budget Application, Program 15, Upgrade Power Transformers, page**
2 **10, lines 2 to 11.**

3 How does Hydro prioritize transformers for the installation of online DGA monitors?
4
5

6 A. Newfoundland and Labrador Hydro's primary consideration for prioritization for the installation
7 of online DGA¹ monitors on transformers is asset criticality and condition, as it relates to
8 historical gassing. Secondary consideration is given to alignment with planned transformer
9 outages and other work activities.

¹ Dissolved gas analysis ("DGA").