

1 Q. Please confirm the age of the spare Pelton runner that will be used on Unit 1.

2

3

4 A. The spare Pelton runner is approximately 40 years old.<sup>1</sup> The spare was procured during the  
5 original construction of the Cat Arm Hydroelectric Generating Station, which was commissioned  
6 in 1985, and was never used.

---

<sup>1</sup> The exact manufacturing date is unknown.