

1 Q. **Reference: Renew Circuit Breakers (2027 – 2029), Appendix A**

2 Will the circuit breakers that are planned for replacement or refurbishment at Holyrood and
3 Hardwoods be repurposed after these plants are retired in 2030?

4

5

6 A. The breakers planned for refurbishment or replacement at Holyrood and Hardwoods are related
7 to the terminal station infrastructure and not the generation assets. As such, there is no risk of
8 asset stranding upon the retirement of these plants.