

1 Q. **Reference: 2027 Capital Budget Application, Schedule 1, 2027 Capital Budget Overview,**
2 **Appendix F, page 13.**

3 What is the inspection frequency of visual inspections for Hydro's power transformers?
4
5

6 A. The inspection frequency of visual inspections for Newfoundland and Labrador Hydro's power
7 transformers is 120 days, with an exception for a subset of the least-critical power transformers
8 that have a visual inspection frequency of 180 days.