

1 Q. **Reference: Program 10: Terminal Station In-Service Failures (2027)**

2 Provide a list of all spare assets maintained in inventory for this program.

3
4
5 A. Assets procured through this program that are presently available for as-needed installation
6 include:

- 7 • 253 kV 4000A live-tank SF6 circuit breaker.
- 8 • 253 kV 2000A dead-tank SF6 circuit breaker.
- 9 • 245 kV 2000A dead-tank SF6 circuit breaker.
- 10 • 152 kV 1200A dead-tank SF6 circuit breaker.
- 11 • 145 kV 1200A dead-tank SF6 circuit breaker.
- 12 • 72.5 kV 2000A dead-tank SF6 circuit breaker (x2).
- 13 • 230 kV circuit switcher.
- 14 • 245 kV 1200A horizontal mount center break disconnect switch.
- 15 • 245 kV 1200A horizontal mount vertical break disconnect switch.
- 16 • 145 kV horizontal mount center break disconnect switch.
- 17 • 145 kV 1200A horizontal mount vertical break disconnect switch.
- 18 • 72.5 kV 1200A vertical mount vertical break disconnect switch.
- 19 • 230 kV current + voltage instrument transformer.
- 20 • 230 kV current transformer.
- 21 • 66 kV/230 V 75 kVA station service voltage transformer.
- 22 • 46 kV/14.4 kV 333 kVA transformer (x2).
- 23 • 230 kV/13.8 Spare Generator Step-Up Transformer (T6S).
- 24 • 15 kV Breaker for Synchronous Condenser 1 or 2 in Wabush.
- 25 • Journal Bearings (2) for Synchronous Condenser 1 or 2 in Wabush.