

1 Q. **Reference: Project 7: Upgrade Worst-Performing Distribution Feeders (2027–2028) Appendix**
2 **A, page A-6**

3 Similar to FDL-L1, St. Anthony, Line 1 has a recommendation for capital work to replace failing,
4 aged insulators and replace St. Anthony, Line 1 sub-standard conductor. Hydro states that it
5 plans to propose this work in a future CBA. Why wasn't the work recommended for St. Anthony,
6 Line 1 included in the 2027 CBA?

7
8
9 A. Fleur de Lys Line 1 was proposed in the 2027 Capital Budget Application ("CBA") ahead of St.
10 Anthony Line 1 based on ranking criteria, including key performance indicators such as SAIDI¹,
11 CHIKM² and overall customer impact ranking. Other key performance indicators, such as SAIFI³,
12 were near equal, leading to a higher priority for refurbishment of Fleur de Lys Line 1. St.
13 Anthony Line 1 is currently planned for proposal in the 2028 CBA.

¹ System Average Interruption Duration Index.

² Customer Hours Interrupted per Kilometer.

³ System Average Interruption Frequency Index.