

1 Q. **Reference: Project 14: Renew Distribution Feeders (2027–2028) page 4**

2 Provide the reliability data (SAIFI, SAIDI and CHI) for St. Brendan’s Line 1 (“SBN-L1”).

3

4

5 A. The five-year average reliability data for St. Brendan’s – Line 1, for the period of 2021–2025, is  
6 outlined in Table 1.

**Table 1: Five-Year Average Reliability – St. Brendan’s Line 1<sup>1</sup>**

| SAIFI <sup>2</sup> | SAIDI <sup>3</sup> | CHI <sup>4</sup> |
|--------------------|--------------------|------------------|
| 2.942              | 11.703             | 1,735.976        |

---

<sup>1</sup> This data is overall reliability data and includes all outage types impacting the customers, including planned outages, loss of supply outages, customer requests, and major events.

<sup>2</sup> System Average Interruption Frequency Index.

<sup>3</sup> System Average Interruption Duration Index.

<sup>4</sup> Customer-hours Interruption.