

1 **Q. Reference: “2020 Capital Budget Application,” Newfoundland Power, July 5, 2019,**
 2 **Report 3.1 “2020 Transmission Line Rebuild,” sec. 2.2, at p. 2.**
 3

4 **In 2017, inspections identified significant deterioration of the line due to decay,**
 5 **splits and checks in the poles and spar arms, cracks in insulators and other**
 6 **hardware deficiencies. Many of these components were identified as being in**
 7 **advanced stages of deterioration and requiring replacement. The inspections also**
 8 **identified conductor damage requiring repair.**
 9

10 **Has Newfoundland Power experienced any outages due to conductor failure on**
 11 **363L? If so, please provide the dates and durations of these outages.**
 12

13 A. No, Newfoundland Power has not experienced any outages due to conductor failure on
 14 transmission line 363L.
 15

16 Transmission Line Rebuild projects, including the rebuilding of 363L, are intended to be
 17 *proactive* in addressing aged and deteriorated transmission lines. This requires assessing
 18 the potential risk of customer outages on a transmission line and, when necessary,
 19 undertaking capital investments to *prevent* those outages from impacting customers.¹
 20 This *proactive* approach recognizes that transmission lines are critical in providing
 21 reliable service to large numbers of customers.
 22

23 Reliability indices, as requested in this question, are lagging indicators that encompass
 24 historical issues. Waiting for reliability on the transmission system to degrade before
 25 undertaking capital investments would result in a poor quality of service being
 26 experienced by large numbers of customers for several years. Such an approach would
 27 not recognize the criticality of transmission lines in serving customers² and would be
 28 inconsistent with the provincial power policy.³
 29

30 Newfoundland Power *does* rely on reliability indices to target certain capital investments
 31 in the electrical system, when appropriate. For example, reliability indices are used to
 32 target capital investments under the Company’s Distribution Reliability Initiative. Under
 33 this capital project, reliability indices are used to determine the worst-performing feeders
 34 where capital investments may improve the quality of service experienced by customers
 35 in specific areas. This is consistent with maintaining an adequate level of reliability for
 36 all customers.

¹ Newfoundland Power’s Transmission Line Rebuild Strategy establishes that rebuild projects will be prioritized based on the: (i) condition of a transmission line; (ii) risk of failure; and (iii) impact on customers.

² The North American Electric Reliability Corporation publication *Reliability Concepts* describes risk in the context of electric system reliability as the likelihood that an operating event will reduce reliability to the point where the consequences are unacceptable. For example, a lower level of reliability could be tolerated on a distribution feeder serving 500 customers than on a transmission line serving 25,000 customers.

³ The provincial power policy effectively requires that electricity be delivered to customers at the lowest possible cost consistent with *reliable* service. See Section 3(b)(iii) of the *Electrical Power Control Act, 1994*.

1 This difference in approaches effectively recognizes the different levels of criticality
2 distribution and transmission lines play in providing reliable service to customers.⁴ The
3 appropriateness of such an approach has been recognized by The Liberty Consulting
4 Group⁵ and other Canadian utilities.⁶

⁴ The difference in criticality of distribution and transmission lines is also observed within Newfoundland Power's inspection practices. While distribution lines are inspected on a 7-year cycle, transmission lines are inspected annually.

⁵ In its *Report on Island Interconnected System to Interconnection with Muskrat Falls addressing Newfoundland Power Inc.*, December 17, 2014, The Liberty Consulting Group concluded that: "*Newfoundland Power uses an effective combination of periodic O&M inspection and maintenance programs and capital transmission, distribution, and annual capital substation capital rebuild and modernization projects to address condition, reliability, and operating issues with its transmission, distribution, and substation assets*" (page 49).

⁶ For example, in its *2007-2008 Transmission Revenue Requirement and Rate Application (EB-2006-0501)*, Hydro One stated that it would be inappropriate to wait for "*reduced transmission system reliability before any corrective action is taken.*"