Reference: Volume 2, Customer, Energy and Demand Forecast

1 2 3

Q. Volume 2, Customer, Energy and Demand and Forecast, page 10. Explain how system losses of 5% for the forecast period were determined. Include in the response the historical information relied on in determining the losses.

5 6 7

8

9

4

A. Losses of 5.0% for the forecast period were based on 2020 losses of 5.0% as reported in Return 15 of the Newfoundland Power 2020 Annual Report to the Board. Losses of 5.0% in 2020 were reasonably consistent with losses of 5.1% in each of 2018 and 2019.

Newfoundland Power's 2020 Annual Report to the Board was filed with the Board on March 31, 2021.