

1 **Q. Newfoundland Power’s 2023 capital budget application, Tab 2023 Capital**
2 **Budget Overview, Appendix B, page 3, lists various projects that were deferred**
3 **from 2023 to subsequent years and includes Memorial Substation**
4 **Refurbishment and Modernization. Newfoundland Power states that “Memorial**
5 **Substation located at Memorial University in St. John’s requires refurbishment**
6 **and modernization to replace deteriorated equipment. The project was**
7 **originally planned for 2023. The project has been deferred to allow further**
8 **engineering assessment of the components in the substation and to coordinate**
9 **with work planned by Memorial University on the equipment it owns in the**
10 **substation. The project is now planned for 2024.”**

- 11
- 12 **(a) Was MUN-T2 being considered for replacement as part of the above?**
 - 13
 - 14 **(b) What impact, if any, did the deferral of this project have upon the timing**
15 **of the discovery of the issue with MUN-T2?**
 - 16

17 **A. (a)** No, the replacement of power transformer MUN-T2 was not included as part of the
18 planned refurbishment and modernization of Memorial (“MUN”) Substation. The
19 planned scope of work for MUN Substation focused on the refurbishment and
20 modernization of certain infrastructure and to coordinate with work planned by
21 Memorial University for replacement of its switchgear.

22

23 **(b)** Deferring the refurbishment and modernization of MUN Substation did not impact
24 the timing of discovering the issue with MUN-T2.

25

26 Newfoundland Power determined in the first quarter of 2022 that the
27 refurbishment and modernization of MUN Substation should be deferred from 2023
28 to 2024. This decision was made to permit further engineering assessments to
29 coordinate with work planned by Memorial University. Preliminary engineering
30 assessments completed in the first quarter of 2022 did not identify any issues with
31 MUN-T2. This is because oil samples collected in February 2022 appeared normal.

32

33 In August 2022, only six months following the latest oil sampling, Newfoundland
34 Power was notified by Memorial University that MUN-T2 was producing a high
35 noise level during operation and was experiencing a higher than normal internal
36 temperature. Additional oil sampling was completed and, while the sample
37 appeared dark in colour, laboratory analysis showed the results again appeared
38 normal. This necessitated an internal inspection and an assessment by an
39 independent consultant to diagnose the specific failure mode.¹

40

41 Engineering assessments for substation refurbishment and modernization projects
42 generally rely on standard maintenance procedures to identify issues with power
43 transformers. Internal inspections are rare and are typically completed to

¹ See the *Application, Schedule B, Section 2.0 Background*.

1 diagnose a suspected failure.² In the case of MUN-T2, an internal inspection was
2 deemed necessary based on the abnormal noise and temperature levels that
3 materialized in August 2022. Without these operational concerns, an internal
4 inspection would not have been completed and a standard engineering assessment
5 would not have detected the deterioration.

² An internal inspection requires de-energizing the power transformer and partially draining the oil. The results of the inspection may or may not reveal the issue, depending on what the issue is and where it originates within the transformer. If an internal inspection does not identify the issue, a full dismantling of the power transformer may be required.