

- 1 **Q. (Reference Application, 4.1 Sandy Brook Hydro Plant Generator**
2 **Refurbishment) Would Newfoundland Power judge this project to be economic**
3 **if the value of system capacity were zero in 2024 and beyond?**
4
- 5 A. If the value of system capacity were zero in 2024 and beyond, the Sandy Brook Hydro
6 Plant life cycle analysis would show the cost of production exceeding the benefit of
7 export energy by 0.99 ¢/kWh. This net cost would indicate that the continued operation
8 of the plant is not economic.