

- 1 **Q. (Reference NLH-NP-033) It is stated “In Newfoundland Power’s view, a**
2 **replacement generator would not provide any additional benefits sufficient to**
3 **justify these added costs. The plant’s efficiency would not necessarily improve**
4 **and the expected remaining service life would not change materially.” What is**
5 **the typical water conversion efficiency of hydro generator technology today**
6 **versus when the Mobile Hydro Plant was commissioned?**
7
- 8 A. Newfoundland Power’s assessment that the plant’s efficiency would not necessarily
9 improve is based on the *Hydroelectric Systems Strategic Planning Study* completed by
10 Hatch (formerly Acres International) in January 2001.¹ The typical water conversion
11 efficiency of hydro generator technology today is estimated to be between 90% and
12 92%.² The most recent estimate of water conversion efficiency for the Mobile Hydro
13 Plant is approximately 90%.³

¹ The *Hydroelectric Systems Strategic Planning Study* was most recently filed with the Board in the response to Request for Information PUB-NP-009 of the Company’s *2010 Capital Budget Application*.

² See the IEA-ETSAP and IRENA *Technology Brief E06 – February 2015* and the Agtech Centre’s *Focus on Alternative Energy* pamphlet on Hydroelectric Power.

³ The original Mobile Hydro Plant turbine runner was replaced by a more efficient design in 1990. At that time, the water conversion efficiency was determined to be 91.8% following the runner replacement. Over the past 32 years the efficiency has reduced slightly due to age and deterioration.