

1 **Q. (Reference CA-NP-121) What are the outage rates for the Mobile hydro plant**
 2 **in each of the past 10 years?**

3
 4 A. Table 1 provides the annual outage rates for the Mobile hydro plant from 2012 to 2021.

Table 1 Annual Outage Rates Mobile Hydro Plant	
Year	Unavailability ¹
2012	0.98%
2013	0.12%
2014	0.25%
2015	2.68%
2016	0.22%
2017	0.11%
2018	1.02%
2019	0.30%
2020	1.79%
2021	12.96% ²

¹ Unavailability is based on the percentage of hours per year during which the unit was unavailable due to forced outages, planned outages, maintenance, and system events resulting in the unit tripping offline.

² The Mobile hydro plant was unavailable between July 2, 2021 and August 11, 2021, due to unplanned maintenance associated with the unit's cooling system.