

Transmission

1 **Q. Reference: "2024 Capital Budget Application," Newfoundland Power Inc.,**  
 2  
 3 **June 22, 2023, Supporting Materials, Transmission: 3.1, sec. 4.2, p. 10.**  
 4  
 5

6 **Additionally, in order to ensure future rebuild of this line adheres**  
 7 **to current design standards, the new poles being installed may**  
 8 **need to be higher than the existing poles that are being**  
 9 **replaced. Installing a large number of poles of greater height**  
 10 **will require additional conductor to be spliced onto the existing**  
 11 **conductor. The conductor will also have to be re-sagged when all**  
 12 **of the poles are replaced.**  
 13

14 **a) Under Alternative 1, please explain why Newfoundland Power would not**  
 15 **install higher poles, assuming that the line will be rebuilt in 2028, and**  
 16 **frame the poles lower instead of modifying conductor.**  
 17

18 **b) Under Alternative 1, please explain why transmission line 146L would be**  
 19 **rebuilt in 2028 if existing deficiencies would be addressed in 2025.**  
 20

21 A. a) Under Alternative 1, Newfoundland Power would not plan to install higher poles and  
 22 temporarily frame them at a lower height. Doing so would cause a significant  
 23 amount of rework during the future rebuild stage of the project. In addition to  
 24 replacing all of the structures not addressed in the original deficiency corrections,  
 25 each structure that was previously remediated would have to be reframed at the  
 26 appropriate height before installing the new conductor. This would add a significant  
 27 cost to the project, while also adding additional complexities and inefficiencies,  
 28 ultimately increasing the length of time required to complete the project.  
 29

30 b) Under Alternative 1, the remaining structures not originally addressed in 2025 would  
 31 be rebuilt in 2028 and 2029. At that time, those remaining structures and the  
 32 conductor which were originally installed in 1964 would have been in service for 65  
 33 years. The typical useful service life of transmission wood poles and transmission  
 34 overhead conductor is 58 years and 63 years, respectively.  
 35

36 Furthermore, the engineering assessment completed on Transmission Line 146L  
 37 found that an additional 98 poles, beyond those currently identified as requiring  
 38 replacement, were in moderate condition. The poles are currently showing initial  
 39 signs of deterioration and their condition is expected to continue to decline. This  
 40 aligns with the increased number of deficiencies found throughout Transmission Line  
 41 146L during recent annual inspections.  
 42

43 Due to the remaining line components having exceeded their typical useful service  
 44 life in 2028, and the present condition of the structures that will not be addressed in  
 45 2025, an increased risk of equipment failure on Transmission Line 146L would be  
 46 expected. A rebuild of the remaining structures on the line would be required to  
 47 address this risk of failure.