

**Distribution**

**Q. Reference: “2024 Capital Budget Application,” Newfoundland Power Inc., June 22, 2023, Supporting Materials, Distribution: 1.1, app. A, p. 1, Table A-1 to p. 5, Table A-5.**

**a) Please explain why WAV-01 was chosen for this project instead of feeders that were identified in Appendix A with worse distribution reliability data.**

**b) Please compare WAV-01 to the Electricity Canada average and the Atlantic Canadian utility counterparts.**

A. a) See the response to Request for Information PUB-NP-029.

b) Table 1 provides a comparison of the five-year average System Average Interruption Duration Index (“SAIDI”) and System Average Interruption Frequency Index (“SAIFI”) performance of distribution feeder WAV-01 compared to the averages of Electricity Canada Region 2 and the Atlantic Canadian utility counterparts, excluding loss of supply and scheduled outages.

Table 1 Average SAIDI and SAIFI Performance of Distribution Feeder WAV-01, Electricity Canada – Region 2 and Atlantic Canadian Utilities Five-Year Average			
	Electricity Canada Region 2	Atlantic Canada <sup>1</sup>	WAV-01
SAIDI	4.07	4.40	3.35
SAIFI	2.06	-	1.85

At the feeder level, the reliability performance of distribution feeder WAV-01 is on average 18% and 24% better for SAIDI when compared to the averages of Electricity Canada Region 2 and Atlantic Canadian utilities, respectively. The reliability performance is on average 10% better for SAIFI when compared to the Electricity Canada Region 2 average.

Table 2 provides a comparison of the three-year average SAIDI and SAIFI performance for the section of distribution feeder WAV-01 downstream of downline recloser WAV-01-R2 compared to the five-year averages of Electricity Canada Region 2 and the Atlantic Canadian utility counterparts, excluding loss of supply and scheduled outages.

<sup>1</sup> Data necessary to calculate the SAIFI performance of the Atlantic Canadian utilities is not available.

<b>Table 2</b> <b>Average SAIDI and SAIFI Performance of Distribution Feeder WAV-01,</b> <b>Electricity Canada – Region 2 and Atlantic Canadian Utilities</b>			
	<b>Electricity Canada</b> <b>Region 2</b> <b>(Five-Year Average)</b>	<b>Atlantic Canada<sup>2</sup></b> <b>(Five-Year Average)</b>	<b>Downstream WAV-</b> <b>01-R2</b> <b>(Three-Year Average)</b>
<b>SAIDI</b>	4.07	4.40	8.77
<b>SAIFI</b>	2.06	-	3.98

1           The reliability performance of the identified section of distribution feeder WAV-01 is  
2           on average 115% and 99% worse for SAIDI when compared to the averages of  
3           Electricity Canada Region 2 and Atlantic Canadian utilities, respectively. The  
4           reliability performance is on average 93% worse for SAIFI when compared to the  
5           Electricity Canada Region 2 average.

---

<sup>2</sup> Ibid.