

Distribution

1
2
3 **Q. Reference: "2024 Capital Budget Application," Newfoundland Power Inc.,**
4 **June 22, 2023, Supporting Materials, Distribution: 1.2, sec. 3.3, p. 7.**

5
6 **The analysis showed that the load on the identified single-phase**
7 **section of the feeder is approximately 180 amps, which exceeds**
8 **the Company's planning criteria for maximum current on a**
9 **single-phase distribution line.**

10
11 **Newfoundland Power states that distribution feeder OXP-01 has a single-**
12 **phase section with 180 Amps that exceeds the Company's planning criteria**
13 **for maximum current on the single-phase distribution line. Why was this**
14 **section of the line not upgraded before this year, as it is exceeding the**
15 **planning criteria by 95 Amps?**

16
17 **A. See the response to Request for Information PUB-NP-032.**