**Substations** 

1

## 4 5

- 2 3
- 6 7 8
- 9 10
- 11 12 13
- 14 15 16 17 18 19
- 20 21 22
- 23 24 25

27 28

26

29 30

31

Reference: "2025 Capital Budget Application," Newfoundland Power Inc., Q. June 28, 2024, Supporting Materials, Substations: 2.1, app. C, att. A. Newfoundland Power's five-year plan provided in its 2024 Capital Budget **Application indicated refurbishment of the Lockston Substation was** scheduled to commence in 2026. Why has Newfoundland Power decided to advance the Lockston Substation project to begin in 2025?

- A. The Lockston ("LOK") Substation refurbishment and modernization project was advanced by one year as a result of deteriorating infrastructure, the need to address regulatory requirements, and the increased risk of equipment failure.
  - The three generation transformers, LOK-T1, LOK-T2 and LOK-T4 are arranged in a non-standard configuration with a non-standard 46 kV voltage. LOK-T1 has a PCB concentration above 50 ppm that must be addressed by the end of 2025 to comply with Government PCB regulations. LOK-T1 and LOK-T4 are the fourth and fifth oldest power transformers in the Company's fleet with both at 69 years old. If any one of the power transformers failed, a portable substation would be required to bypass all three transformers in order to maintain the existing electrical capacity. Replacing these transformers with a single power transformer will eliminate the non-standard 46 kV voltage, reduce electrical losses on the system and reduce the amount of equipment maintenance required at the substation.
  - A majority of the substation switches have deteriorated and are now at end of life, the wood pole structures are deteriorated, and there are deficiencies with the ground grid that pose a risk to safety and reliability.
  - Coordinating these replacements achieves efficiencies in project planning and execution. Advancing the project mitigates risks to safety, reliability, and environmental compliance, ensuring continued delivery of reliable service.