

1 **Substations**

2

3 **Q. Reference: "2025 Capital Budget Application," Newfoundland Power Inc.,**

4 **June 28, 2024, Supporting Materials, Substations: 2.2, p. 2 and p. 4.**

5

6 **According to industry experience, the expected life of a power transformer is**

7 **between 30 and 50 years, with a sharp decline for in-service power**

8 **transformers past 70 years of age. The load profile in Newfoundland and**

9 **Labrador is favourable for transformer life expectancy, as the highest loads**

10 **are experienced in the winter when ambient temperatures are the lowest.**

11 **[p. 2]**

12

13 **and;**

14

15 **PUL-T2 is a 39-year-old, 15/20/25 MVA, 66-12.5 kV power transformer**

16 **manufactured by Ferranti Packard. [p. 4]**

17

18 **a) Please explain the deterioration of PUL-T2 at 39 years when "the load**

19 **profile in Newfoundland and Labrador is favourable for transformer life**

20 **expectancy?"**

21 **b) Please provide the results of the electrical testing, the internal inspection**

22 **report, and the Dissolved Gas Analysis test results for each year from 2021**

23 **to 2023 for PUL-T2.**

24 **c) This project is being proposed as a two-year project. In its report,**

25 **Newfoundland Power states that lead times on Power Transformers have**

26 **increased from an average of 34 weeks in 2019 to an average of 117**

27 **weeks in 2024. Given these extended lead times, does Newfoundland**

28 **Power feel the proposed two-year schedule will be attainable?**

29

30 **A. a) There are multiple factors that contribute to the deterioration of a power transformer**

31 **beyond its load profile. As indicated in *CEATI's Enhancing End-of-Life Assessment of***

32 ***Power Transformers* report:¹**

33

34 *The main degradation, decomposition, or damaging events to transformer*

35 *systems are:*

- 36 • *Applied mechanical forces: Mechanical forces due to transportation,*
- 37 *vibrations, electromagnetism (natural, system short circuits, or inrush*
- 38 *currents), or unintentional physical movement by personnel (e.g., during*
- 39 *internal inspection or by altering settings or processes, such as increasing*
- 40 *oil flow).*
- 41 • *Thermal ageing and chemical reactions: Pyrolysis, oxidation, hydrolysis,*
- 42 *byproduct reactions, and so on are accelerated by increased temperatures*
- 43 *and oxygen, water, and impurity concentrations*
- 44 • *Voltage stresses*
- 45 • *Contamination*

¹ Refer to *CEATI Report No. T213700-30140 Enhancing End-of-Life Assessment of Power Transformers* published in October 2023.

1
2 *The type of transformer failures can be broadly classified as electrical,*
3 *mechanical, or thermal. It is important to note that failures may start with one*
4 *type of failure, but progress to include two or three of the broad classes. Typical*
5 *causes of transformer failures are:*

- 6 • *Internal: Insulation deterioration, loss of winding clamping, overheating,*
7 *moisture, solid contamination in the insulating oil, PD, design and*
8 *manufacturing defects, winding resonance*
- 9 • *External: Lightning strikes, system switching operations, system overload,*
10 *system faults (short circuits)*

11
12 Any of the factors listed above could have contributed to the deterioration of the
13 PUL-T2 power transformer.

14
15 See *Appendix A Section 1.2 PUL-T2 Power Transformer* of *NP 2025 Capital Budget*
16 *Application Report 2.2 Substation Power Transformer Replacements* for a history of
17 the PUL-T2 transformer. This transformer was initially installed in Chamberlains
18 Substation where it was heavily loaded, and was then moved multiple times until it
19 was installed in PUL Substation in 2019. The heavy loading on this transformer, as
20 well as the multiple moves, could have also contributed to the deterioration of the
21 transformer.

- 22
23 b) See Attachment A for the PUL-T2 maintenance report from 2022 which includes the
24 electrical testing and internal inspection results. See Attachment B for the dissolved
25 gas analysis test results from 2021 to 2023.
- 26
27 c) The proposed two-year schedule is expected to be obtainable based on experience
28 with recent power transformer purchases and quotations.²

² The 117-week average lead time is based on an average of lead times that have been received from all bidders through the Company's competitive bidding process. The recent successful bids have had a better lead time than the average, which is anticipated to be around 90 weeks.



ATTACHMENT A:
PUL-T2 2022 Maintenance Report



Maintenance Standard Report Form TRANSFORMER



OWNER Substation Asset Group DATE 2022,09,19 ASSET ID 200331
 SITE St. Johns AMBIENT TEMP. 15 °C HUMIDITY _____ %
 SUBSTATION PUL: Pulpit Rock Substation WORK ORDER NO Substation Maintenance
 EQUIPMENT 200331 - Power Transformer (PUL-T2) **Open Classifications Folder**

Maintenance 1 Maintenance 3 Maintenance 4 Maintenance 5 Internal Inspection? On-Load Tapchanger? Fall Arrest Bracket?
 Style of Pressure Relief System: Explosion Vent Pressure Relief Device Yes No Yes No Yes No

MANUFACTURER: Ferranti-Packard SERIAL #: 46311 TYPE: ONAN/ONAF MODEL #: _____ RATED VOLT.: 66000

Check each item with a v for OK, X to indicate a problem, NA for not applicable, or ND for not done. Once work is completed, the Maintenance Lead Hand and the Maintenance Supervisor must sign and forward to Planner for processing and filing.

Refer to Maintenance Standard MSP004A for additional procedure step information.

Procedure Step	Task	Status or Results	Done By
SECTION 1 – Maintenance IV Inspection and Checks			
1.1	Company ID number generated and applied OR verified.	v	BM/TH
1.2	Nameplate information recorded and updated from all components with a nameplate. (Main Tank, bushings, Tap changer, etc.) (Record this info. On MSF001)	v	
1.3	Perform visual inspection	v	
1.4	If present, remove any bushing wrap.	NA	
1.5	If not installed and height of XFMR > 10 feet, install fall arrest bracket.	x	
1.6	Ensure cooling fans operate correctly. Ensure drain plugs or adhesive is removed from fan motors.	v	
1.7	Ensure an appropriate PCB label is installed on the unit. Record PCB level on MSF009.	v	
1.8	Obtain Oil Sample with a syringe and bottle for gas analysis.	v	
1.9	Perform dew point test if moisture is suspected to have entered the tank.	°C: 0	
1.10	Test and record dielectric value of the insulating oil.	kV: 0	
1.11	Inspect bushings for oil leakage and oil level.	v	
1.12	Ensure control cabinet is clean and dry. Verify proper operation of cabinet heater.	v	
1.13	Check radiators for:	Paint Condition:	v
		No Oil Leaks:	v
		Correct position of all valves	v
SECTION 2 – Instrumentation and Protection Devices - Inspection			
2.1	Inspect Oil Level as indicated by the gauge on the conservator tank.	Gauge Condition: PASS Oil Level Reading:	BM/TH
2.2	Inspect Oil Temperature Gauge	Gauge Condition: PASS	
		Oil Temperature:	
		Oil Temperature Alarm Setting:	
		Oil Temperature Trip Setting:	
2.3	Inspect Winding Temperature Gauge	Gauge Condition: PASS	
		Oil Temperature:	
		Oil Temperature Alarm Setting:	
		Oil Temperature Trip Setting:	
2.4	Inspect Fan Temperature Gauge	Gauge Condition: PASS	
		Stage 1 Activation Temperature:	
		Stage 2 Activation Temperature:	
2.5	Check operation of the gas detector relay. Refer to MST007.	FAIL	
2.6	Inspect Cab Tire, connections and weatherproofing on all instrumentation and protection wiring.	PASS	
2.7	Perform a Transformer Protection Devices Inspection as per maintenance standard MST017.	NOT COMPLETE	
2.8a	Inspect Pressure Relief Device for physical damage.	Condition: PASS	BM/TH
2.9a	Inspect Pressure Relief Device and spool for oil leaks.	Condition: PASS	
2.10a	Is a spill pan present? If Present - Inspect operation of heat tracing: If present - inspect operation of valve. (Does not bind, operates smooth): If Present - Ensure pan is drained and clear of debris:	(Yes/No) PASS	
		PASS	
		PASS	



Maintenance Standard Report Form TRANSFORMER



PAGE _____

SECTION 3 – Service and Maintenance

3.1.1	Paint Transformer if de-energized.	Completed?	NOT COMPLETE	BM/TH
3.1.2	Clean bushings and lighting arrestors. Porcelain should free of atmospheric pollution.		PASS	
3.1.3	Install / Replace humidity absorbent packets in the gas detector relay.		NOT COMPLETE	
3.1.4	Inspect condition of silica gel. Replacement required? <i>If replacement required - Silica Gel Replaced?</i>		PASS	
3.1.5	Ensure off-load tap changer can be operated smoothly. Lubricate locking pins in handle. Operate tap changer throughout its entire range.		NOT APPLICABLE	

SECTION 3 – Internal Inspection

Transformer Internal Inspection: Duration and Weather conditions

Weather Conditions: Cloudy Temperature: 18 Celsius Duration tank was open: 6 Hours 0 Minutes

Inspection Procedure:	Pass	Fail	N/A
Inside of tank free of loose or damaged parts.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Inside of tank free of tools or debris.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Explosion Vent Lower Diaphragm intact.	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
Main Tank Oil Level gauge checked.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Bushing leads in good condition.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
CT leads good and connections tight.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Tapchanger leads good and connections tight.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
All fasteners (nuts, bolts) in correct place and tight.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Core laminations and supports in place.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Off-load tap changer in good condition.	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
Terminal Board structure good.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
No signs of carbon or tracking.	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
Any and all shipping braces removed.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
CTs, PTs and Auxiliary Transformers properly mounted.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Coils and insulation in good condition.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
No signs of moisture present.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
No signs of structural failure in tank, such as cracks in wall or welding.	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
No signs of physical damage on tank wall.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
All lines checked for proper connections and tightness.	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>

SECTION 3 – Service and Maintenance - Other Maintenance or Repairs

Was any other Maintenance or repairs completed? Yes No

SECTION 5 – Diagnostic Testing (Maintenance III, IV and Acceptance)

5.1	Megger Test <i>Attach data using "Transformer - Meggering" form</i>	√	BM/TH
5.2	Megger Test (Control Wiring) <i>Attach data using "Transformer - Control Wiring Meggering" form</i>	NA	
5.3	Ratio Test <i>Attach data using "Transformer - Offload / Onload Tapchanger Ratio Test" form</i>	√	BM/TH
5.4	Power Factor Test <i>Attach data using "Transformer - Power Factoring" form</i>	√	BM/TH



Maintenance Standard Report Form TRANSFORMER



PAGE _____

SECTION 4 - Tapchanger Inspection

Separate Diverter Tank? Yes No

Counts: Initial Counter Reading: 0 Final Counter Reading: 0

Oil Dielectric Testing: Tapchanger Compartment: 0 kV Diverter: 0 kV PCB Level: 0 PPM

Oil Level Reading: Tapchanger Compartment: 0 Diverter: 0

Motor Testing: Motor Megger Test: 0 MΩ Motor Current: 0 Amps

Please make the appropriate selection:		Yes:	No:	Check:	Pass	Fail	N/A
Operated Manually:	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Insulating Barriers	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
Operated Electrically:	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Arc Chutes	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
Evidence of Oil Leakage Outside:	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Contacts	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Evidence of Oil Leakage Between Tanks:	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Gears	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Evidence of Moisture in Compartment(s):	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Cams	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Oil Filtered:	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Chain Drive (Where Applicable)	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
Oil Replaced:	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Mechanical Stops	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Compartment(s) flushed with Clean Oil	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Brake Operation	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
Gears, Shafts, Bearings, etc. Lubricated	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Operations Counter	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
All Control Features Operational	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Gaskets	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Tap Position Indicator Operational	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Relief Vent and/or Breather	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Drag Hand Reset Operational	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Oil Filter (if applicable)	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
Limit Switches Operational:	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Contactors	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
All Nuts and Bolts Tight	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Relay Contacts	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
All Pins Properly in Position	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Auxiliary Switches	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
Pressure Relief Device installed on Tapchanger	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Cabinet Heaters and Thermostat	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
If so, Operation Indicator and/or Alarm Switch Required Resetting?	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Cabinet Light and Receptacle	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Control Cabinet Clean and Dry	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Wiring Connections Tight	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
Oil Sample Obtained	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>				

COMMENTS:

- unit un-tanked and inspected for internal damage / signs of fault
- signs of carbon present in oil, dark / discoloured oil. small particles of carbon found on level surfaces
- unit pressurised with dry air while oil was removed
- gas detector and bleed line replaced
- Top Center Hatch was leaking once refilled,
- cleaned up hatch, cut and replaced new cork gasket, new hardware torqued to 45Fib
- repaired leaking piping for GDR
- performed associated testing with x-former, ratio, winding resistance, power factor
- pictures of internal inspection attached

DEFICIENCIES:

- Tap changer "raise" function not working from local control, broken switch
- oil leaking into hollow void of transformer designed for structure (bench) appears to be a small crack in weld, allowing oil to migrate into empty void, (attached is a picture of us trying to drain this oil)

GST, Measure R Ground B "H"

"X"

V: 10.02 kV
I: 23.18 mA
W: .6361 W
PF: 0.27%
C: 6140.7 pF

V: 10.06 kV
I: 23.27 mA
W: 0.738 W
PF: 0.29%
C: 6139.8 pF

GST Burard R+B "H"

"X"

V: 10.07 kV
I: 11.77 mA
W: .4944 W
PF: 0.42%
C: 3100.8 pF

V: 10.09 kV
I: 30.61 mA
W: 1.661 W
PF: 0.54%
C: 8047.4 pF

GST Ground R+B "H"

"X"

V: 10.05 kV
I: 35.01 mA
W: 1.129 W
PF: 0.32%
C: 9241.9 pF

V: 10.02 kV
I: 53.58 mA
W: 2.551 W
PF: 0.48%
C: 14181 pF

Tap H1 - H0/H2-H0

H3-H0

JH, BM

T-1	.392	✓	1	.392	✓
2	.395		2	.387	
3	.387		3	.382	
4	.385		4	.380	
5	.383		5	.377	
6	.378		6	.375	
7	.376		7	.374	
8	.375		8	.374	
9	.372		9	.377	
10	.368		10	.372 .372	
11	.366		11	.372 .372	
12	.364		12	.370	
13	.362		13	.371	
14	.361		14	.368	
15	.367		15	.365	
16	.368		16	.363	
17	.360		17	.355	
18	.356		18	.354	

1	.391	✓
2	.389	
3	.386	
4	.384	
5	.382	
6	.379	
7	.376	
8	.375	
9	.372	
10	.368	
11	.367	
12	.365	
13	.363	
14	.360	
15	.359	
16	.357	
17	.352	
18	.355	

X1-X0

X2-X0

X3-X0

7.5 m ✓

7.8 m ✓

7.7 m ✓

Winding
Resistance



Revised: 2022-09-22

Maintenance Standard Report Form POWER TRANSFORMERS

Check if Okay:

Physical Condition	_____	Line Connections	_____	Cabinet Heaters	_____
Paint	_____	Alarms Operational	_____	Breather	_____
Bushings	_____	Gaskets	_____	Silica Gel	_____
Lightning Arresters	_____	Control Wiring Terminal Connections	_____	Fans	_____
Bushing Oil Level	_____	Control Cabinet	_____	Foundation	_____


Ratio Test:


Tap Position	H1 Phase	H2 Phase	H3 Phase	Tap Position	H1 Phase	H2 Phase	H3 Phase
	H1 - _____ - - _____	H2 - _____ - - _____	H3 - _____ - - _____		H1 - _____ - - _____	H2 - _____ - - _____	H3 - _____ - - _____
1	5.57	5.57	5.57	18	5.06	5.06	5.06
2	5.54	5.54	5.54	19	5.03	5.03	5.03
3	5.51	5.51	5.51	20	5.00	5.00	5.00
4	5.48	5.48	5.48	21	4.97	4.97	4.97
5	5.45	5.45	5.45	22	4.94	4.94	4.94
6	5.42	5.42	5.42	23	4.91	4.91	4.91
7	5.39	5.39	5.39	24	4.87	4.87	4.87
8	5.36	5.36	5.36	25	4.85	4.85	4.85
9	5.33	5.33	5.33	26	4.81	4.81	4.81
10	5.30	5.30	5.30	27	4.78	4.78	4.78
11	5.27	5.27	5.27	28	4.75	4.75	4.75
12	5.24	5.24	5.24	29	4.72	4.72	4.72
13	5.21	5.21	5.21	30	4.69	4.69	4.69
14	5.18	5.18	5.18	31	4.66	4.66	4.66
15	5.15	5.15	5.15	32	4.63	4.63	4.63
16	5.12	5.12	5.12	33	4.60	4.60	4.60
17	5.09	5.09	5.09				


Remarks:

Type of Maintenance _____ Date _____ Inspected By _____













ATTACHMENT B:

PUL-T2 2021 to 2023 Dissolved Gas Analysis



Tapchanger Activity Signature Analysis TASA™

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation : Conservator
Compartment : Common

Date : 3/16/2021
Report Number : 5073165
Purchase Order Number:
Manufacturer : ASEA
Model : UZERN200/300

	Sample Date :	3/8/2021	3/19/2020	2/28/2019	9/29/2017	9/20/2016
	Laboratory No. :	5073165	5069802	5065827	5060354	5056599
	Container No. :	47388	44953	40421	35579	34155
	Temperature :	18	50	0.5	35	0
H2	Hydrogen (ppm) :	8025	3889	299	254	153
CH4	Methane (ppm) :	27	135	10	19	10
C2H6	Ethane (ppm) :	8	5	0	1	2
C2H4	Ethylene (ppm) :	240	121	5	26	10
C2H2	Acetylene (ppm) :	2736	1574	79	233	11
CO	Carbon monoxide (ppm) :	212	179	26	91	218
CO2	Carbon dioxide (ppm) :	1115	975	218	1548	2139
N2	Nitrogen (ppm) :	89626	95591	86490	81239	83281
O2	Oxygen (ppm) :	19768	19287	25018	35142	35933
	Total (ppm) :	121757	121756	112145	118553	121757
	TDCG (ppm) :	11248	5903	419	624	404
	SHL (%) :	3.99	4.01	4.07	4.28	5.34
	ETCG (% in blanket) :	12.48	6.22	0.54	0.53	0.41
Particles	5 to 15 um :	965405	3543850	746750	10700	3950
Particles	15 to 25 um :	10270	63150	23000	1450	300
Particles	25 to 50 um :	850	4500	3450	750	0
Particles	50 to 100 um :	38	100	400	250	0
Particles	> 100 um :	4	0	0	0	0
D1533	Moisture (ppm) :	14	12	11	10	10
D1816	Dielectric BV (kV) :	29	31	33	32	25
D974	Acid Number (mg KOH/g) :	0.04	0.04	0.04	0.007	0.007
D971	Interfacial Tension (dynes/cm) :	29.0	28.4	29.3	39.2	40.3
D1500	Color Number :	<2.0	<2.0	<2.0	<1.0	<1.0

Tapchanger Activity Signature Analysis Diagnostic Evaluation

TASA Assessment :	2 ID: 200331	1 ID: 200331	1 ID: 200331	1 ID: 200331	1 ID: 200331
	Sampler: Brent	Sampler: Tim	Sampler: Brent	Sampler: Allan	Sampler: Glenn
	Green Counter:	Horlick Counter:	Green Counter:	Bartlett Counter:	Knott Counter:
	6355	58833	5446	52095	51528

Sampling Interval : Recommend retest within 150 days (5 months) for trending.
 Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.
 Comments : A slightly abnormal dissipation of energy is noted. This is an early indication of fault or wear activity.
 Partial discharge is indicated.
 Abnormal arcing is indicated.
 Follow guidelines for oils with high flammable gas content.

Approved by: RWarmenhove
 Rico Warmenhove
 Lab Manager



H₂b

ANALYTICAL SERVICES
INCORPORATED

Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV: 66

Date : 03-22-2021
Report Number : 5073164
Fluid volume : 14443
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	3/8/2021	3/19/2020	2/28/2019	2/3/2019	6/14/2018
	Laboratory No. :	5073164	5069800	5065826	5065670	5063173
	Container No. :	47368	44922	40414	38487	38699
	Temperature :	33	40	30	-6	26
H2	Hydrogen (ppm) :	16	10	2	0	14
CH4	Methane (ppm) :	3	5	1	1	7
C2H6	Ethane (ppm) :	1	0	0	0	3
C2H4	Ethylene (ppm) :	20	6	0	0	5
C2H2	Acetylene (ppm) :	14	5	0	0	1
CO	Carbon monoxide (ppm) :	423	314	43	23	520
CO2	Carbon dioxide (ppm) :	2025	1509	385	153	2640
N2	Nitrogen (ppm) :	98897	79459	37624	32806	98030
O2	Oxygen (ppm) :	22759	21223	10007	8671	4518
	Total (ppm) :	124158	102531	48062	41654	105738
	TDCG (ppm) :	477	340	46	24	550
	SHL (%) :	10.41	10.72	10.25	12.28	11.00
	ETCG (% in blanket) :	0.30	0.27	0.08	0.05	0.40
Particles	5 to 15 um :	25053	87800	240350	127200	115400
Particles	15 to 25 um :	1620	13300	56650	17000	10400
Particles	25 to 50 um :	651	2050	14150	3750	3350
Particles	50 to 100 um :	81	50	700	200	550
Particles	> 100 um :	11	0	0	0	100
D1533	Moisture (ppm) :	9	6	4	5	4
D1816	Dielectric BV (kV) :	36	30	32	35	31
D974	Acid Number (mg KOH/g) :	0.06	0.06	0.05	0.06	0.05
D971	Interfacial Tension (dynes/cm) :	26.2	25.9	26.0	25.2	25.3
D1500	Color Number :	<2.5	<2.5	<2.0	<2.0	<2.0
D924	Power Factor :	0.026	0.124	0.156	0.077	0.128
D2668	Oxidation Inhibitor (%) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	0.011
2 ACF	2 acetylfuran (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	994

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment : 3 ID: 200331 1 ID: 200331 1 ID: 200331 1 ID: 200331 1 ID: 200331
 Sampler: Brent Green Sampler: Tim Horlick Sampler: Brent Green Sampler: N/A Sampler: Allan Bartlett

Sampling Interval : Retest in three months.

Operating Procedure : Continue normal operation. Paper mechanical condition is normal.

Comments : Arcing is indicated.

Field Comments : Fluid condition is within acceptable in-service parameters.

Approved by: RWarmenhove

Rico Warmenhove
Lab Manager



H₂b

ANALYTICAL SERVICES
INCORPORATED

Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV: 66

Date : 05-03-2021
Report Number : 5073412
Fluid volume : 14443
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	4/14/2021	3/8/2021	3/19/2020	2/28/2019	2/3/2019
	Laboratory No. :	5073412	5073164	5069800	5065826	5065670
	Container No. :	44874	47368	44922	40414	38487
	Temperature :	28	33	40	30	-6
H2	Hydrogen (ppm) :	3	16	10	2	0
CH4	Methane (ppm) :	1	3	5	1	1
C2H6	Ethane (ppm) :	0	1	0	0	0
C2H4	Ethylene (ppm) :	15	20	6	0	0
C2H2	Acetylene (ppm) :	12	14	5	0	0
CO	Carbon monoxide (ppm) :	319	423	314	43	23
CO2	Carbon dioxide (ppm) :	1442	2025	1509	385	153
N2	Nitrogen (ppm) :	64528	98897	79459	37624	32806
O2	Oxygen (ppm) :	16276	22759	21223	10007	8671
	Total (ppm) :	82596	124158	102531	48062	41654
	TDCG (ppm) :	350	477	340	46	24
	SHL (%) :	11.64	10.41	10.72	10.25	12.28
	ETCG (% in blanket) :	0.32	0.30	0.27	0.08	0.05
Particles	5 to 15 um :	9621	25053	87800	240350	127200
Particles	15 to 25 um :	406	1620	13300	56650	17000
Particles	25 to 50 um :	136	651	2050	14150	3750
Particles	50 to 100 um :	13	81	50	700	200
Particles	> 100 um :	0	11	0	0	0
D1533	Moisture (ppm) :	6	9	6	4	5
D1816	Dielectric BV (kV) :	32	36	30	32	35
D974	Acid Number (mg KOH/g) :	0.05	0.06	0.06	0.05	0.06
D971	Interfacial Tension (dynes/cm) :	26.6	26.2	25.9	26.0	25.2
D1500	Color Number :	<2.5	<2.5	<2.5	<2.0	<2.0
D924	Power Factor :	0.132	0.026	0.124	0.156	0.077
D2668	Oxidation Inhibitor (%) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	2 ID: 200331	3 ID: 200331	1 ID: 200331	1 ID: 200331	1 ID: 200331
	Sampler: David Warren	Sampler: Brent Green	Sampler: Tim Horlick	Sampler: Brent Green	Sampler: N/A

Sampling Interval : Retest in six months.

Operating Procedure : Continue normal operation. Paper mechanical condition is normal.

Comments : Arcing is indicated.

Field Comments : Fluid condition is within acceptable in-service parameters.

Approved by: RWarmenhove

Rico Warmenhove
Lab Manager



*Tapchanger Activity
Signature Analysis TASA* TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation :
Compartment : Common

Date : 9/15/2021
Report Number : 5075045
Purchase Order Number:
Manufacturer : ASEA
Model :

	Sample Date :	8/25/2021	3/8/2021	3/19/2020	2/28/2019	9/29/2017
	Laboratory No. :	5075045	5073165	5069802	5065827	5060354
	Container No. :	49277	47388	44953	40421	35579
	Temperature :	40	18	50	0.5	35
H2	Hydrogen (ppm) :	7238	8025	3889	299	254
CH4	Methane (ppm) :	319	27	135	10	19
C2H6	Ethane (ppm) :	10	8	5	0	1
C2H4	Ethylene (ppm) :	301	240	121	5	26
C2H2	Acetylene (ppm) :	3421	2736	1574	79	233
CO	Carbon monoxide (ppm) :	324	212	179	26	91
CO2	Carbon dioxide (ppm) :	1553	1115	975	218	1548
N2	Nitrogen (ppm) :	88367	89626	95591	86490	81239
O2	Oxygen (ppm) :	13056	19768	19287	25018	35142
	Total (ppm) :	114589	121757	121756	112145	118553
	TDCG (ppm) :	11613	11248	5903	419	624
	SHL (%) :	4.00	3.99	4.01	4.07	4.28
	ETCG (% in blanket) :	12.10	12.48	6.22	0.54	0.53
Particles	5 to 15 um :	97278	965405	3543850	746750	10700
Particles	15 to 25 um :	263	10270	63150	23000	1450
Particles	25 to 50 um :	65	850	4500	3450	750
Particles	50 to 100 um :	5	38	100	400	250
Particles	> 100 um :	0	4	0	0	0
D1533	Moisture (ppm) :	15	14	12	11	10
D1816	Dielectric BV (kV) :	35	29	31	33	32
D974	Acid Number (mg KOH/g) :	0.03	0.04	0.04	0.04	0.007
D971	Interfacial Tension (dynes/cm) :	30.6	29.0	28.4	29.3	39.2
D1500	Color Number :	<2.0	<2.0	<2.0	<2.0	<1.0

Tapchanger Activity Signature Analysis Diagnostic Evaluation

TASA Assessment :	2 ID: 200331	2 ID: 200331	1 ID: 200331	1 ID: 200331	1 ID: 200331
	Sampler: Brent	Sampler: Brent	Sampler: Tim	Sampler: Brent	Sampler: Allan
	Green Counter: 23	Green Counter: 6355	Horlick Counter: 58833	Green Counter: 5446	Bartlett Counter: 52095

Sampling Interval : Recommend retest within 150 days (5 months) for trending.
 Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.
 Comments : A slightly abnormal dissipation of energy is noted. This is an early indication of fault or wear activity.
 Partial discharge is indicated.
 Abnormal arcing is indicated.
 Follow guidelines for oils with high flammable gas content.

Approved by: RWarmenhove
 Rico Warmenhove
 Lab Manager



Tapchanger Activity Signature Analysis TASA™

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation : Conservator
Compartment : Common

Date : 2/1/2022
Report Number : 5076545
Purchase Order Number:
Manufacturer : ASEA
Model : UZERN200/300

	Sample Date :	1/17/2022	8/25/2021	3/8/2021	3/19/2020	2/28/2019
	Laboratory No. :	5076545	5075045	5073165	5069802	5065827
	Container No. :	47734	49277	47388	44953	40421
	Temperature :	3	40	18	50	0.5
H2	Hydrogen (ppm) :	8078	7238	8025	3889	299
CH4	Methane (ppm) :	316	319	27	135	10
C2H6	Ethane (ppm) :	22	10	8	5	0
C2H4	Ethylene (ppm) :	335	301	240	121	5
C2H2	Acetylene (ppm) :	3778	3421	2736	1574	79
CO	Carbon monoxide (ppm) :	299	324	212	179	26
CO2	Carbon dioxide (ppm) :	1705	1553	1115	975	218
N2	Nitrogen (ppm) :	88384	88367	89626	95591	86490
O2	Oxygen (ppm) :	18839	13056	19768	19287	25018
	Total (ppm) :	121756	114589	121757	121756	112145
	TDCG (ppm) :	12828	11613	11248	5903	419
	SHL (%) :	3.99	4.00	3.99	4.01	4.07
	ETCG (% in blanket) :	12.91	12.10	12.48	6.22	0.54
Particles	5 to 15 um :	94797	97278	965405	3543850	746750
Particles	15 to 25 um :	403	263	10270	63150	23000
Particles	25 to 50 um :	48	65	850	4500	3450
Particles	50 to 100 um :	3	5	38	100	400
Particles	> 100 um :	0	0	4	0	0
D1533	Moisture (ppm) :	9	15	14	12	11
D1816	Dielectric BV (kV) :	36	35	29	31	33
D974	Acid Number (mg KOH/g) :	0.03	0.03	0.04	0.04	0.04
D971	Interfacial Tension (dynes/cm) :	30.9	30.6	29.0	28.4	29.3
D1500	Color Number :	<2.0	<2.0	<2.0	<2.0	<2.0

Tapchanger Activity Signature Analysis Diagnostic Evaluation

TASA Assessment :	2 ID: 200331	2 ID: 200331	2 ID: 200331	1 ID: 200331	1 ID: 200331
	Sampler: Brent	Sampler: Brent	Sampler: Brent	Sampler: Tim	Sampler: Brent
	Green Counter:6639	Green Counter: 23	Green Counter: 6355	Horlick Counter: 58833	Green Counter: 5446

Sampling Interval : Recommend retest within 150 days (5 months) for trending.
 Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.
 Comments : A slightly abnormal dissipation of energy is noted. This is an early indication of fault or wear activity.
 Partial discharge is indicated.
 Abnormal arcing is indicated.
 Follow guidelines for oils with high flammable gas content.

Approved by: RWarmenhove

Rico Warmenhove
Lab Manager



H₂b

ANALYTICAL SERVICES
INCORPORATED

Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV: 66

Date : 06-06-2022
Report Number : 5077103
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	5/26/2022	4/14/2021	3/8/2021	3/19/2020	2/28/2019
	Laboratory No. :	5077103	5073412	5073164	5069800	5065826
	Container No. :	51296	44874	47368	44922	40414
	Temperature :	32	28	33	40	30
H2	Hydrogen (ppm) :	10	3	16	10	2
CH4	Methane (ppm) :	2	1	3	5	1
C2H6	Ethane (ppm) :	1	0	1	0	0
C2H4	Ethylene (ppm) :	23	15	20	6	0
C2H2	Acetylene (ppm) :	27	12	14	5	0
CO	Carbon monoxide (ppm) :	340	319	423	314	43
CO2	Carbon dioxide (ppm) :	1796	1442	2025	1509	385
N2	Nitrogen (ppm) :	79991	64528	98897	79459	37624
O2	Oxygen (ppm) :	23546	16276	22759	21223	10007
	Total (ppm) :	105736	82596	124158	102531	48062
	TDCG (ppm) :	403	350	477	340	46
	SHL (%) :	10.54	11.64	10.41	10.72	10.25
	ETCG (% in blanket) :	0.29	0.32	0.30	0.27	0.08
Particles	5 to 15 um :	1580	9621	25053	87800	240350
Particles	15 to 25 um :	60	406	1620	13300	56650
Particles	25 to 50 um :	15	136	651	2050	14150
Particles	50 to 100 um :	2	13	81	50	700
Particles	> 100 um :	0	0	11	0	0
D1533	Moisture (ppm) :	9	6	9	6	4
D1816	Dielectric BV (kV) :	36	32	36	30	32
D974	Acid Number (mg KOH/g) :	0.05	0.05	0.06	0.06	0.05
D971	Interfacial Tension (dynes/cm) :	25.4	26.6	26.2	25.9	26.0
D1500	Color Number :	2.0	<2.5	<2.5	<2.5	<2.0
D924	Power Factor :	0.127	0.132	0.026	0.124	0.156
D2668	Oxidation Inhibitor (%) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment : Potential 4 ID: 2 ID: 200331 3 ID: 200331 1 ID: 200331 1 ID: 200331
200331 Sampler: Tim Sampler: David Sampler: Brent Green Sampler: Tim Horlick Sampler: Brent Green
Horlick Warren

Sampling Interval : Retest immediately to confirm condition.


Operating Procedure : Plan to remove from service for additional testing, investigation, and analysis.

Comments : Arcing and heating at higher temperatures are indicated. Paper condition is normal.

Approved by: RWarmenhove

Rico Warmenhove
Lab Manager

Field Comments : Fluid condition is within acceptable in-service parameters.



ANALYTICAL SERVICES
INCORPORATED

Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 06-21-2022
Report Number : 5077235
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	6/7/2022	5/26/2022	4/14/2021	3/8/2021	3/19/2020
	Laboratory No. :	5077235	5077103	5073412	5073164	5069800
	Container No. :	48297	51296	44874	47368	44922
	Temperature :	25	32	28	33	40
H2	Hydrogen (ppm) :	11	10	3	16	10
CH4	Methane (ppm) :	3	2	1	3	5
C2H6	Ethane (ppm) :	0	1	0	1	0
C2H4	Ethylene (ppm) :	30	23	15	20	6
C2H2	Acetylene (ppm) :	30	27	12	14	5
CO	Carbon monoxide (ppm) :	276	340	319	423	314
CO2	Carbon dioxide (ppm) :	1653	1796	1442	2025	1509
N2	Nitrogen (ppm) :	84176	79991	64528	98897	79459
O2	Oxygen (ppm) :	35445	23546	16276	22759	21223
	Total (ppm) :	121624	105736	82596	124158	102531
	TDCG (ppm) :	350	403	350	477	340
	SHL (%) :	10.00	10.54	11.64	10.41	10.72
	ETCG (% in blanket) :	0.22	0.29	0.32	0.30	0.27
Particles	5 to 15 um :	492	1580	9621	25053	87800
Particles	15 to 25 um :	166	60	406	1620	13300
Particles	25 to 50 um :	78	15	136	651	2050
Particles	50 to 100 um :	8	2	13	81	50
Particles	> 100 um :	0	0	0	11	0
D1533	Moisture (ppm) :	10	9	6	9	6
D1816	Dielectric BV (kV) :	28	36	32	36	30
D974	Acid Number (mg KOH/g) :	0.05	0.05	0.05	0.06	0.06
D971	Interfacial Tension (dynes/cm) :	26.4	25.4	26.6	26.2	25.9
D1500	Color Number :	2.0	2.0	<2.5	<2.5	<2.5
D924	Power Factor :	0.128	0.127	0.132	0.026	0.124
D2668	Oxidation Inhibitor (%) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetyl furan (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment : 4 ID: 200331 Potential 4 ID: 2 ID: 200331 3 ID: 200331 1 ID: 200331
 Sampler: David 200331 Sampler: Tim Warren Sampler: David Warren Sampler: Brent Green Sampler: Tim Horlick

Sampling Interval : Retest in 14 days

Operating Procedure : Plan to remove from service for additional testing, investigation and analysis.

Comments : Heating at higher temperatures and arcing are indicated. Cellulose may be involved.
 Paper condition is normal.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 06-21-2022
Report Number : 5077235
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by: RWarmenhove
Rico Warmenhove
Lab Manager



Tapchanger Activity Signature Analysis TASA™

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation : Conservator
Compartment : Common

Date : 6/23/2022
Report Number : 5077241
Purchase Order Number:
Manufacturer : ASEA
Model : UZERN200/300

	Sample Date :	6/8/2022	1/17/2022	8/25/2021	3/8/2021	3/19/2020
	Laboratory No. :	5077241	5076545	5075045	5073165	5069802
	Container No. :	45361	47734	49277	47388	44953
	Temperature :	6	3	40	18	50
H2	Hydrogen (ppm) :	7954	8078	7238	8025	3889
CH4	Methane (ppm) :	305	316	319	27	135
C2H6	Ethane (ppm) :	15	22	10	8	5
C2H4	Ethylene (ppm) :	367	335	301	240	121
C2H2	Acetylene (ppm) :	3746	3778	3421	2736	1574
CO	Carbon monoxide (ppm) :	293	299	324	212	179
CO2	Carbon dioxide (ppm) :	1638	1705	1553	1115	975
N2	Nitrogen (ppm) :	86778	88384	88367	89626	95591
O2	Oxygen (ppm) :	20659	18839	13056	19768	19287
	Total (ppm) :	121755	121756	114589	121757	121756
	TDCG (ppm) :	12680	12828	11613	11248	5903
	SHL (%) :	3.99	3.99	4.00	3.99	4.01
	ETCG (% in blanket) :	12.81	12.91	12.10	12.48	6.22
Particles	5 to 15 um :	68107	94797	97278	965405	3543850
Particles	15 to 25 um :	111	403	263	10270	63150
Particles	25 to 50 um :	9	48	65	850	4500
Particles	50 to 100 um :	0	3	5	38	100
Particles	> 100 um :	0	0	0	4	0
D1533	Moisture (ppm) :	15	9	15	14	12
D1816	Dielectric BV (kV) :	38	36	35	29	31
D974	Acid Number (mg KOH/g) :	0.03	0.03	0.03	0.04	0.04
D971	Interfacial Tension (dynes/cm) :	28.4	30.9	30.6	29.0	28.4
D1500	Color Number :	<2.0	<2.0	<2.0	<2.0	<2.0

Tapchanger Activity Signature Analysis Diagnostic Evaluation

TASA Assessment :	2 ID: 200331	2 ID: 200331	2 ID: 200331	2 ID: 200331	1 ID: 200331
	Sampler: David	Sampler: Brent	Sampler: Brent	Sampler: Brent	Sampler: Tim
	Warren Counter: 67363	Green Counter:6639	Green Counter: 23	Green Counter: 6355	Horlick Counter: 58833

Sampling Interval : Recommend retest within 150 days (5 months) for trending.
 Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.
 Comments : A slightly abnormal dissipation of energy is noted. This is an early indication of fault or wear activity.
 Partial discharge is indicated.
 Abnormal arcing is indicated.
 Follow guidelines for oils with high flammable gas content.



Tapchanger Activity
Signature Analysis TASA TM


Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation : Conservator
Compartment : Common

Date : 6/23/2022
Report Number : 5077241
Purchase Order Number:
Manufacturer : ASEA
Model : UZERN200/300

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by: RWarmenhove
Rico Warmenhove
Lab Manager



ANALYTICAL SERVICES
INCORPORATED

Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 06-28-2022
Report Number : 5077408
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	6/20/2022	6/7/2022	5/26/2022	4/14/2021	3/8/2021
Laboratory No. :		5077408	5077235	5077103	5073412	5073164
Container No. :		45373	48297	51296	44874	47368
Temperature :		32	25	32	28	33
H2	Hydrogen (ppm) :	10	11	10	3	16
CH4	Methane (ppm) :	5	3	2	1	3
C2H6	Ethane (ppm) :	1	0	1	0	1
C2H4	Ethylene (ppm) :	34	30	23	15	20
C2H2	Acetylene (ppm) :	36	30	27	12	14
CO	Carbon monoxide (ppm) :	272	276	340	319	423
CO2	Carbon dioxide (ppm) :	2072	1653	1796	1442	2025
N2	Nitrogen (ppm) :	79466	84176	79991	64528	98897
O2	Oxygen (ppm) :	22037	35445	23546	16276	22759
	Total (ppm) :	103933	121624	105736	82596	124158
	TDCG (ppm) :	358	350	403	350	477
	SHL (%) :	9.99	10.00	10.54	11.64	10.41
	ETCG (% in blanket) :	0.24	0.22	0.29	0.32	0.30
Particles	5 to 15 um :	449	492	1580	9621	25053
Particles	15 to 25 um :	165	166	60	406	1620
Particles	25 to 50 um :	48	78	15	136	651
Particles	50 to 100 um :	3	8	2	13	81
Particles	> 100 um :	0	0	0	0	11
D1533	Moisture (ppm) :	10	10	9	6	9
D1816	Dielectric BV (kV) :	35	28	36	32	36
D974	Acid Number (mg KOH/g) :	0.05	0.05	0.05	0.05	0.06
D971	Interfacial Tension (dynes/cm) :	24.9	26.4	25.4	26.6	26.2
D1500	Color Number :	<2.5	2.0	2.0	<2.5	<2.5
D924	Power Factor :	0.123	0.128	0.127	0.132	0.026
D2668	Oxidation Inhibitor (%) :	<0.01	<0.010	<0.010	<0.010	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetyl furan (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	4 ID: 200331	4 ID: 200331	Potential 4 ID:	2 ID: 200331	3 ID: 200331
	Sampler: David Warren	Sampler: David Warren	200331 Sampler: Tim Horlick	Sampler: David Warren	Sampler: Brent Green

Sampling Interval : Retest in 14 days

Operating Procedure : Plan to remove from service for additional testing, investigation and analysis.

Comments : Heating at higher temperatures and arcing are indicated.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 06-28-2022
Report Number : 5077408
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by: RWarmenhove
Rico Warmenhove
Lab Manager



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 08-16-2022
Report Number : 5078286
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	7/19/2022	6/20/2022	6/7/2022	5/26/2022	4/14/2021
Laboratory No. :		5078286	5077408	5077235	5077103	5073412
Container No. :		51292	45373	48297	51296	44874
Temperature :		39	32	25	32	28
H2	Hydrogen (ppm) :	19	10	11	10	3
CH4	Methane (ppm) :	21	5	3	2	1
C2H6	Ethane (ppm) :	12	1	0	1	0
C2H4	Ethylene (ppm) :	38	34	30	23	15
C2H2	Acetylene (ppm) :	46	36	30	27	12
CO	Carbon monoxide (ppm) :	610	272	276	340	319
CO2	Carbon dioxide (ppm) :	2750	2072	1653	1796	1442
N2	Nitrogen (ppm) :	84367	79466	84176	79991	64528
O2	Oxygen (ppm) :	3708	22037	35445	23546	16276
	Total (ppm) :	91571	103933	121624	105736	82596
	TDCG (ppm) :	746	358	350	403	350
	SHL (%) :	10.39	9.99	10.00	10.54	11.64
	ETCG (% in blanket) :	0.56	0.24	0.22	0.29	0.32
Particles	5 to 15 um :	1684	449	492	1580	9621
Particles	15 to 25 um :	115	165	166	60	406
Particles	25 to 50 um :	52	48	78	15	136
Particles	50 to 100 um :	0	3	8	2	13
Particles	> 100 um :	0	0	0	0	0
D1533	Moisture (ppm) :	15	10	10	9	6
D1816	Dielectric BV (kV) :	23	35	28	36	32
D974	Acid Number (mg KOH/g) :	0.05	0.05	0.05	0.05	0.05
D971	Interfacial Tension (dynes/cm) :	23.0	24.9	26.4	25.4	26.6
D1500	Color Number :	2.0	<2.5	2.0	2.0	<2.5
D924	Power Factor :	0.128	0.123	0.128	0.127	0.132
D2668	Oxidation Inhibitor (%) :	<0.010	<0.01	<0.010	<0.010	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	4 ID: 200331	4 ID: 200331	4 ID: 200331	Potential 4 ID:	2 ID: 200331
	Sampler: David Warren	Sampler: David Warren	Sampler: David Warren	200331 Sampler: Tim Horlick	Sampler: David Warren

Sampling Interval : Retest in 14 days

Operating Procedure : Plan to remove from service for additional testing, investigation and analysis.

Comments : Heating at higher temperatures and arcing are indicated. Paper condition is normal.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 08-16-2022
Report Number : 5078286
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink that reads 'RWarmenhove'.

Rico Warmenhove
Lab Manager



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 09-23-2022
Report Number : 5078595
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	8/18/2022	7/19/2022	6/20/2022	6/7/2022	5/26/2022
Laboratory No. :		5078595	5078286	5077408	5077235	5077103
Container No. :		51288	51292	45373	48297	51296
Temperature :		35	39	32	25	32
H2	Hydrogen (ppm) :	34	19	10	11	10
CH4	Methane (ppm) :	11	21	5	3	2
C2H6	Ethane (ppm) :	3	12	1	0	1
C2H4	Ethylene (ppm) :	31	38	34	30	23
C2H2	Acetylene (ppm) :	39	46	36	30	27
CO	Carbon monoxide (ppm) :	488	610	272	276	340
CO2	Carbon dioxide (ppm) :	2121	2750	2072	1653	1796
N2	Nitrogen (ppm) :	75442	84367	79466	84176	79991
O2	Oxygen (ppm) :	3841	3708	22037	35445	23546
	Total (ppm) :	82010	91571	103933	121624	105736
	TDCG (ppm) :	606	746	358	350	403
	SHL (%) :	9.27	10.39	9.99	10.00	10.54
	ETCG (% in blanket) :	0.54	0.56	0.24	0.22	0.29
Particles	5 to 15 um :	295	1684	449	492	1580
Particles	15 to 25 um :	17	115	165	166	60
Particles	25 to 50 um :	1	52	48	78	15
Particles	50 to 100 um :	0	0	3	8	2
Particles	> 100 um :	0	0	0	0	0
D1533	Moisture (ppm) :	16	15	10	10	9
D1816	Dielectric BV (kV) :	36	23	35	28	36
D974	Acid Number (mg KOH/g) :	0.04	0.05	0.05	0.05	0.05
D971	Interfacial Tension (dynes/cm) :	24.8	23.0	24.9	26.4	25.4
D1500	Color Number :	2.0	2.0	<2.5	2.0	2.0
D924	Power Factor :	0.121	0.128	0.123	0.128	0.127
D2668	Oxidation Inhibitor (%) :	<0.010	<0.010	<0.01	<0.010	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	4 ID: 200331	4 ID: 200331	4 ID: 200331	4 ID: 200331	Potential 4 ID:
	Sampler: David Warren	Sampler: David Warren	Sampler: David Warren	Sampler: David Warren	200331 Sampler: Tim Horlick

Sampling Interval : Retest in 14 days

Operating Procedure : Plan to remove from service for additional testing, investigation and analysis.

Comments : Heating at higher temperatures and arcing are indicated. Paper condition is normal.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 09-23-2022
Report Number : 5078595
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink that reads 'RWarmenhove'.

Rico Warmenhove
Lab Manager



Tapchanger Activity Signature Analysis TASA TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation : Conservator
Compartment : Common

Date : 11-02-2022
Report Number : 5079108
Purchase Order Number:
Manufacturer : ASEA
Model : UZERN200/300

	Sample Date :	9/29/2022	6/8/2022	1/17/2022	8/25/2021	3/8/2021
Laboratory No. :		5079108	5077241	5076545	5075045	5073165
Container No. :		52747	45361	47734	49277	47388
Temperature :		19	6	3	40	18
H2	Hydrogen (ppm) :	5936	7954	8078	7238	8025
CH4	Methane (ppm) :	385	305	316	319	27
C2H6	Ethane (ppm) :	17	15	22	10	8
C2H4	Ethylene (ppm) :	505	367	335	301	240
C2H2	Acetylene (ppm) :	2412	3746	3778	3421	2736
CO	Carbon monoxide (ppm) :	308	293	299	324	212
CO2	Carbon dioxide (ppm) :	2138	1638	1705	1553	1115
N2	Nitrogen (ppm) :	70499	86778	88384	88367	89626
O2	Oxygen (ppm) :	18819	20659	18839	13056	19768
	Total (ppm) :	101019	121755	121756	114589	121757
	TDCG (ppm) :	9563	12680	12828	11613	11248
	SHL (%) :	4.02	3.99	3.99	4.00	3.99
	ETCG (% in blanket) :	11.81	12.81	12.91	12.10	12.48
Particles	5 to 15 um :	707	68107	94797	97278	965405
Particles	15 to 25 um :	37	111	403	263	10270
Particles	25 to 50 um :	45	9	48	65	850
Particles	50 to 100 um :	4	0	3	5	38
Particles	> 100 um :	0	0	0	0	4
D1533	Moisture (ppm) :	17	15	9	15	14
D1816	Dielectric BV (kV) :	33	38	36	35	29
D974	Acid Number (mg KOH/g) :	<0.02	0.03	0.03	0.03	0.04
D971	Interfacial Tension (dynes/cm) :	24.9	28.4	30.9	30.6	29.0
D1500	Color Number :	2.0	<2.0	<2.0	<2.0	<2.0

Tapchanger Activity Signature Analysis Diagnostic Evaluation

TASA Assessment :	2 ID: 200331	2 ID: 200331	2 ID: 200331	2 ID: 200331	2 ID: 200331
	Sampler: David	Sampler: David	Sampler: Brent	Sampler: Brent	Sampler: Brent
	Warren Counter: 6819	Warren Counter: 67363	Green Counter: 6639	Green Counter: 23	Green Counter: 6355

Sampling Interval : Recommend retest within 150 days (5 months) for trending.
 Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.
 Comments : A slightly abnormal dissipation of energy is noted. This is an early indication of fault or wear activity.
 Partial discharge is indicated.
 Abnormal arcing is indicated.
 Follow guidelines for oils with high flammable gas content.



Tapchanger Activity Signature Analysis TASA TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation : Conservator
Compartment : Common

Date : 11-02-2022
Report Number : 5079108
Purchase Order Number:
Manufacturer : ASEA
Model : UZERN200/300

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink that reads 'RWarmenhove'. The signature is written in a cursive style and is positioned above a horizontal line.

Rico Warmenhove
Lab Manager



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 12-07-2022
Report Number : 5079438
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	11/16/2022	8/18/2022	7/19/2022	6/20/2022	6/7/2022
Laboratory No. :		5079438	5078595	5078286	5077408	5077235
Container No. :		52714	51288	51292	45373	48297
Temperature :		45	35	39	32	25
H2	Hydrogen (ppm) :	8	34	19	10	11
CH4	Methane (ppm) :	7	11	21	5	3
C2H6	Ethane (ppm) :	1	3	12	1	0
C2H4	Ethylene (ppm) :	31	31	38	34	30
C2H2	Acetylene (ppm) :	28	39	46	36	30
CO	Carbon monoxide (ppm) :	314	488	610	272	276
CO2	Carbon dioxide (ppm) :	2256	2121	2750	2072	1653
N2	Nitrogen (ppm) :	81395	75442	84367	79466	84176
O2	Oxygen (ppm) :	26048	3841	3708	22037	35445
	Total (ppm) :	110088	82010	91571	103933	121624
	TDCG (ppm) :	389	606	746	358	350
	SHL (%) :	10.55	9.27	10.39	9.99	10.00
	ETCG (% in blanket) :	0.26	0.54	0.56	0.24	0.22
Particles	5 to 15 um :	123	295	1684	449	492
Particles	15 to 25 um :	59	17	115	165	166
Particles	25 to 50 um :	13	1	52	48	78
Particles	50 to 100 um :	0	0	0	3	8
Particles	> 100 um :	0	0	0	0	0
D1533	Moisture (ppm) :	9	16	15	10	10
D1816	Dielectric BV (kV) :	37	36	23	35	28
D974	Acid Number (mg KOH/g) :	0.06	0.04	0.05	0.05	0.05
D971	Interfacial Tension (dynes/cm) :	23.1	24.8	23.0	24.9	26.4
D1500	Color Number :	2.5	2.0	2.0	<2.5	2.0
D924	Power Factor :	0.106	0.121	0.128	0.123	0.128
D2668	Oxidation Inhibitor (%) :	0.069	<0.010	<0.010	<0.01	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	4 ID: 200331	4 ID: 200331	4 ID: 200331	4 ID: 200331	4 ID: 200331
	Sampler: Holly Best	Sampler: David Warren	Sampler: David Warren	Sampler: David Warren	Sampler: David Warren

Sampling Interval : Retest in thirty days.

Operating Procedure : Plan to remove from service for additional testing, investigation and analysis.

Comments : Arcing is indicated. Paper condition is normal.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 12-07-2022
Report Number : 5079438
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink that reads 'RWarmenhove'.

Rico Warmenhove
Lab Manager



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 02-21-2023
Report Number : 5079764
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	2/8/2023	11/16/2022	8/18/2022	7/19/2022	6/20/2022
	Laboratory No. :	5079764	5079438	5078595	5078286	5077408
	Container No. :	53323	52714	51288	51292	45373
	Temperature :	30	45	35	39	32
H2	Hydrogen (ppm) :	24	8	34	19	10
CH4	Methane (ppm) :	9	7	11	21	5
C2H6	Ethane (ppm) :	2	1	3	12	1
C2H4	Ethylene (ppm) :	32	31	31	38	34
C2H2	Acetylene (ppm) :	29	28	39	46	36
CO	Carbon monoxide (ppm) :	378	314	488	610	272
CO2	Carbon dioxide (ppm) :	2511	2256	2121	2750	2072
N2	Nitrogen (ppm) :	85398	81395	75442	84367	79466
O2	Oxygen (ppm) :	24955	26048	3841	3708	22037
	Total (ppm) :	113338	110088	82010	91571	103933
	TDCG (ppm) :	474	389	606	746	358
	SHL (%) :	9.41	10.55	9.27	10.39	9.99
	ETCG (% in blanket) :	0.32	0.26	0.54	0.56	0.24
Particles	5 to 15 um :	1947	123	295	1684	449
Particles	15 to 25 um :	176	59	17	115	165
Particles	25 to 50 um :	90	13	1	52	48
Particles	50 to 100 um :	12	0	0	0	3
Particles	> 100 um :	0	0	0	0	0
D1533	Moisture (ppm) :	5	9	16	15	10
D1816	Dielectric BV (kV) :	33	37	36	23	35
D974	Acid Number (mg KOH/g) :	0.06	0.06	0.04	0.05	0.05
D971	Interfacial Tension (dynes/cm) :	35.0	23.1	24.8	23.0	24.9
D1500	Color Number :	<2.5	2.5	2.0	2.0	<2.5
D924	Power Factor :	0.126	0.106	0.121	0.128	0.123
D2668	Oxidation Inhibitor (%) :	<0.010	0.069	<0.010	<0.010	<0.01
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	3 ID: 200331	4 ID: 200331	4 ID: 200331	4 ID: 200331	4 ID: 200331
	Sampler: David Warren	Sampler: Holly Best	Sampler: David Warren	Sampler: David Warren	Sampler: David Warren

Sampling Interval : Retest in 90 days.

Operating Procedure : Continue normal operation.

Comments : Heating and arcing are indicated. Paper condition is normal.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 02-21-2023
Report Number : 5079764
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink that reads 'RWarmenhove'. The signature is written in a cursive style and is positioned above a horizontal line.

Rico Warmenhove
Lab Manager



Tapchanger Activity Signature Analysis TASA™

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation : Conservator
Compartment : Common

Date : 4/4/2023
Report Number : 5079890
Purchase Order Number:
Manufacturer : ASEA
Model : UZERN200/300

	Sample Date :	3/20/2023	9/29/2022	6/8/2022	1/17/2022	8/25/2021
	Laboratory No. :	5079890	5079108	5077241	5076545	5075045
	Container No. :	53411	52747	45361	47734	49277
	Temperature :	5	19	6	3	40
H2	Hydrogen (ppm) :	6878	5936	7954	8078	7238
CH4	Methane (ppm) :	385	385	305	316	319
C2H6	Ethane (ppm) :	19	17	15	22	10
C2H4	Ethylene (ppm) :	557	505	367	335	301
C2H2	Acetylene (ppm) :	2946	2412	3746	3778	3421
CO	Carbon monoxide (ppm) :	313	308	293	299	324
CO2	Carbon dioxide (ppm) :	1834	2138	1638	1705	1553
N2	Nitrogen (ppm) :	74805	70499	86778	88384	88367
O2	Oxygen (ppm) :	21156	18819	20659	18839	13056
	Total (ppm) :	108893	101019	121755	121756	114589
	TDCG (ppm) :	11098	9563	12680	12828	11613
	SHL (%) :	4.01	4.02	3.99	3.99	4.00
	ETCG (% in blanket) :	12.65	11.81	12.81	12.91	12.10
Particles	5 to 15 um :	63862	707	68107	94797	97278
Particles	15 to 25 um :	346	37	111	403	263
Particles	25 to 50 um :	65	45	9	48	65
Particles	50 to 100 um :	2	4	0	3	5
Particles	> 100 um :	1	0	0	0	0
D1533	Moisture (ppm) :	15	17	15	9	15
D1816	Dielectric BV (kV) :	33	33	38	36	35
D974	Acid Number (mg KOH/g) :	0.04	<0.02	0.03	0.03	0.03
D971	Interfacial Tension (dynes/cm) :	26.8	24.9	28.4	30.9	30.6
D1500	Color Number :	<2.0	2.0	<2.0	<2.0	<2.0

Tapchanger Activity Signature Analysis Diagnostic Evaluation

TASA Assessment :	2 ID: 200331	2 ID: 200331	2 ID: 200331	2 ID: 200331	2 ID: 200331
	Sampler: William	Sampler: David	Sampler: David	Sampler: Brent	Sampler: Brent
	Crane Counter: 69635	Warren Counter: 6819	Warren Counter: 67363	Green Counter:6639	Green Counter: 23

Sampling Interval : Recommend retest within 150 days (5 months) for trending.
 Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.
 Comments : A slightly abnormal dissipation of energy is noted. This is an early indication of fault or wear activity.
 Partial discharge is indicated.
 Heating is indicated.
 Abnormal arcing is indicated.

Follow guidelines for oils with high flammable gas content.



Tapchanger Activity Signature Analysis TASA TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation : Conservator
Compartment : Common

Date : 4/4/2023
Report Number : 5079890
Purchase Order Number:
Manufacturer : ASEA
Model : UZERN200/300

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink, appearing to read 'MKutzleb', written over a horizontal line.

Michelle Kutzleb, PhD
Director of Operations



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 04-05-2023
Report Number : 5079889
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

			3/20/2023	2/8/2023	11/16/2022	8/18/2022	7/19/2022
	Sample Date :		3/20/2023	2/8/2023	11/16/2022	8/18/2022	7/19/2022
	Laboratory No. :		5079889	5079764	5079438	5078595	5078286
	Container No. :		53414	53323	52714	51288	51292
	Temperature :		48	30	45	35	39
H2	Hydrogen (ppm) :		21	24	8	34	19
CH4	Methane (ppm) :		9	9	7	11	21
C2H6	Ethane (ppm) :		2	2	1	3	12
C2H4	Ethylene (ppm) :		32	32	31	31	38
C2H2	Acetylene (ppm) :		31	29	28	39	46
CO	Carbon monoxide (ppm) :		346	378	314	488	610
CO2	Carbon dioxide (ppm) :		2181	2511	2256	2121	2750
N2	Nitrogen (ppm) :		79073	85398	81395	75442	84367
O2	Oxygen (ppm) :		21856	24955	26048	3841	3708
	Total (ppm) :		103551	113338	110088	82010	91571
	TDCG (ppm) :		441	474	389	606	746
	SHL (%) :		9.44	9.41	10.55	9.27	10.39
	ETCG (% in blanket) :		0.32	0.32	0.26	0.54	0.56
Particles	5 to 15 um :		3571	1947	123	295	1684
Particles	15 to 25 um :		257	176	59	17	115
Particles	25 to 50 um :		79	90	13	1	52
Particles	50 to 100 um :		3	12	0	0	0
Particles	> 100 um :		1	0	0	0	0
D1533	Moisture (ppm) :		14	5	9	16	15
D1816	Dielectric BV (kV) :		26	33	37	36	23
D974	Acid Number (mg KOH/g) :		0.05	0.06	0.06	0.04	0.05
D971	Interfacial Tension (dynes/cm) :		29.7	35.0	23.1	24.8	23.0
D1500	Color Number :		<2.5	<2.5	2.5	2.0	2.0
D924	Power Factor :		0.119	0.126	0.106	0.121	0.128
D2668	Oxidation Inhibitor (%) :		<0.010	<0.010	0.069	<0.010	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :		<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :		<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :		<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :		<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :		<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :		>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	3 ID: 200331	3 ID: 200331	4 ID: 200331	4 ID: 200331	4 ID: 200331
	Sampler: William Crane	Sampler: David Warren	Sampler: Holly Best	Sampler: David Warren	Sampler: David Warren

Sampling Interval : Retest in three months. Establish trends and confirm condition.

Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.

Comments : Arcing is indicated. Partial discharge is indicated. Paper condition is normal.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 04-05-2023
Report Number : 5079889
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink, appearing to read 'MKutzleb', written over a horizontal line.

Michelle Kutzleb, PhD
Director of Operations



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 05-26-2023
Report Number : 5080048
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	5/8/2023	3/20/2023	2/8/2023	11/16/2022	8/18/2022
Laboratory No. :		5080048	5079889	5079764	5079438	5078595
Container No. :		53417	53414	53323	52714	51288
Temperature :		31	48	30	45	35
H2	Hydrogen (ppm) :	13	21	24	8	34
CH4	Methane (ppm) :	6	9	9	7	11
C2H6	Ethane (ppm) :	1	2	2	1	3
C2H4	Ethylene (ppm) :	31	32	32	31	31
C2H2	Acetylene (ppm) :	34	31	29	28	39
CO	Carbon monoxide (ppm) :	293	346	378	314	488
CO2	Carbon dioxide (ppm) :	2212	2181	2511	2256	2121
N2	Nitrogen (ppm) :	79052	79073	85398	81395	75442
O2	Oxygen (ppm) :	31024	21856	24955	26048	3841
	Total (ppm) :	112666	103551	113338	110088	82010
	TDCG (ppm) :	378	441	474	389	606
	SHL (%) :	9.82	9.44	9.41	10.55	9.27
	ETCG (% in blanket) :	0.25	0.32	0.32	0.26	0.54
Particles	5 to 15 um :	1481	3571	1947	123	295
Particles	15 to 25 um :	51	257	176	59	17
Particles	25 to 50 um :	11	79	90	13	1
Particles	50 to 100 um :	2	3	12	0	0
Particles	> 100 um :	0	1	0	0	0
D1533	Moisture (ppm) :	9	14	5	9	16
D1816	Dielectric BV (kV) :	40	26	33	37	36
D974	Acid Number (mg KOH/g) :	0.06	0.05	0.06	0.06	0.04
D971	Interfacial Tension (dynes/cm) :	27.1	29.7	35.0	23.1	24.8
D1500	Color Number :	2.0	<2.5	<2.5	2.5	2.0
D924	Power Factor :	0.133	0.119	0.126	0.106	0.121
D2668	Oxidation Inhibitor (%) :	<0.010	<0.010	<0.010	0.069	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	3 ID: 200331	3 ID: 200331	3 ID: 200331	4 ID: 200331	4 ID: 200331
	Sampler: David Warren	Sampler: William Crane	Sampler: David Warren	Sampler: Holly Best	Sampler: David Warren

Sampling Interval : Retest in three months. Establish trends and confirm condition.

Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.

Comments : Arcing is indicated. Partial discharge is indicated. Paper condition is normal.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 05-26-2023
Report Number : 5080048
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink, appearing to read 'MKutzleb', written over a horizontal line.

Michelle Kutzleb, PhD
Director of Operations



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 07-31-2023
Report Number : 5080444
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

			7/13/2023	5/8/2023	3/20/2023	2/8/2023	11/16/2022
	Sample Date :		7/13/2023	5/8/2023	3/20/2023	2/8/2023	11/16/2022
	Laboratory No. :		5080444	5080048	5079889	5079764	5079438
	Container No. :		4660	53417	53414	53323	52714
	Temperature :		47	31	48	30	45
H2	Hydrogen (ppm) :		17	13	21	24	8
CH4	Methane (ppm) :		6	6	9	9	7
C2H6	Ethane (ppm) :		1	1	2	2	1
C2H4	Ethylene (ppm) :		34	31	32	32	31
C2H2	Acetylene (ppm) :		38	34	31	29	28
CO	Carbon monoxide (ppm) :		335	293	346	378	314
CO2	Carbon dioxide (ppm) :		1919	2212	2181	2511	2256
N2	Nitrogen (ppm) :		72869	79052	79073	85398	81395
O2	Oxygen (ppm) :		27096	31024	21856	24955	26048
	Total (ppm) :		102315	112666	103551	113338	110088
	TDCG (ppm) :		431	378	441	474	389
	SHL (%) :		9.65	9.82	9.44	9.41	10.55
	ETCG (% in blanket) :		0.32	0.25	0.32	0.32	0.26
Particles	5 to 15 um :		1513	1481	3571	1947	123
Particles	15 to 25 um :		47	51	257	176	59
Particles	25 to 50 um :		6	11	79	90	13
Particles	50 to 100 um :		0	2	3	12	0
Particles	> 100 um :		0	0	1	0	0
D1533	Moisture (ppm) :		8	9	14	5	9
D1816	Dielectric BV (kV) :		33	40	26	33	37
D974	Acid Number (mg KOH/g) :		0.06	0.06	0.05	0.06	0.06
D971	Interfacial Tension (dynes/cm) :		26.2	27.1	29.7	35.0	23.1
D1500	Color Number :		<2.5	2.0	<2.5	<2.5	2.5
D924	Power Factor :		0.124	0.133	0.119	0.126	0.106
D2668	Oxidation Inhibitor (%) :		<0.010	<0.010	<0.010	<0.010	0.069
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :		<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :		<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :		<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :		<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :		<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :		>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	3 ID: 200331	3 ID: 200331	3 ID: 200331	3 ID: 200331	4 ID: 200331
	Sampler: William Crane	Sampler: David Warren	Sampler: William Crane	Sampler: David Warren	Sampler: Holly Best

Sampling Interval : Retest in three months.

Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.

Comments : Arcing and heating at higher temperatures are indicated. Paper condition is normal.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 07-31-2023
Report Number : 5080444
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink, appearing to read 'MKutzleb', written over a horizontal line.

Michelle Kutzleb, PhD
Director of Operations



*Tapchanger Activity
Signature Analysis TASA* TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation : Conservator
Compartment : Common

Date : 11/7/2023
Report Number : 5081189
Purchase Order Number:
Manufacturer : ASEA
Model : UZERN200/300

	Sample Date :	11/1/2023	3/20/2023	9/29/2022	6/8/2022	1/17/2022
Laboratory No. :		5081189	5079890	5079108	5077241	5076545
Container No. :		54473	53411	52747	45361	47734
Temperature :		11	5	19	6	3
H2	Hydrogen (ppm) :	6342	6878	5936	7954	8078
CH4	Methane (ppm) :	379	385	385	305	316
C2H6	Ethane (ppm) :	16	19	17	15	22
C2H4	Ethylene (ppm) :	461	557	505	367	335
C2H2	Acetylene (ppm) :	3644	2946	2412	3746	3778
CO	Carbon monoxide (ppm) :	314	313	308	293	299
CO2	Carbon dioxide (ppm) :	2189	1834	2138	1638	1705
N2	Nitrogen (ppm) :	68673	74805	70499	86778	88384
O2	Oxygen (ppm) :	22222	21156	18819	20659	18839
	Total (ppm) :	104240	108893	101019	121755	121756
	TDCG (ppm) :	11156	11098	9563	12680	12828
	SHL (%) :	4.00	4.01	4.02	3.99	3.99
	ETCG (% in blanket) :	12.58	12.65	11.81	12.81	12.91
Particles	5 to 15 um :	46989	63862	707	68107	94797
Particles	15 to 25 um :	197	346	37	111	403
Particles	25 to 50 um :	20	65	45	9	48
Particles	50 to 100 um :	0	2	4	0	3
Particles	> 100 um :	0	1	0	0	0
D1533	Moisture (ppm) :	9	15	17	15	9
D1816	Dielectric BV (kV) :	43	33	33	38	36
D974	Acid Number (mg KOH/g) :	0.04	0.04	<0.02	0.03	0.03
D971	Interfacial Tension (dynes/cm) :	26.8	26.8	24.9	28.4	30.9
D1500	Color Number :	<2.0	<2.0	2.0	<2.0	<2.0

Tapchanger Activity Signature Analysis Diagnostic Evaluation

TASA Assessment :	2 ID: 200331	2 ID: 200331	2 ID: 200331	2 ID: 200331	2 ID: 200331
	Sampler: David	Sampler: William	Sampler: David	Sampler: David	Sampler: Brent
	Warren Counter: 70339	Crane Counter: 69635	Warren Counter: 6819	Warren Counter: 67363	Green Counter:6639

Sampling Interval : Recommend retest within 150 days (5 months) for trending.
 Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.
 Comments : A slightly abnormal dissipation of energy is noted. This is an early indication of fault or wear activity.
 Partial discharge is indicated.
 Abnormal arcing is indicated.
 Follow guidelines for oils with high flammable gas content.



Tapchanger Activity Signature Analysis TASA TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311-LTC
Ventilation : Conservator
Compartment : Common

Date : 11/7/2023
Report Number : 5081189
Purchase Order Number:
Manufacturer : ASEA
Model : UZERN200/300

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink, appearing to read 'MKutzleb', written over a horizontal line.

Michelle Kutzleb, PhD
Director of Operations



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 11-15-2023
Report Number : 5081188
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	11/1/2023	7/13/2023	5/8/2023	3/20/2023	2/8/2023
	Laboratory No. :	5081188	5080444	5080048	5079889	5079764
	Container No. :	54464	4660	53417	53414	53323
	Temperature :	36	47	31	48	30
H2	Hydrogen (ppm) :	17	17	13	21	24
CH4	Methane (ppm) :	7	6	6	9	9
C2H6	Ethane (ppm) :	1	1	1	2	2
C2H4	Ethylene (ppm) :	34	34	31	32	32
C2H2	Acetylene (ppm) :	34	38	34	31	29
CO	Carbon monoxide (ppm) :	405	335	293	346	378
CO2	Carbon dioxide (ppm) :	2600	1919	2212	2181	2511
N2	Nitrogen (ppm) :	71485	72869	79052	79073	85398
O2	Oxygen (ppm) :	21820	27096	31024	21856	24955
	Total (ppm) :	96403	102315	112666	103551	113338
	TDCG (ppm) :	498	431	378	441	474
	SHL (%) :	10.03	9.65	9.82	9.44	9.41
	ETCG (% in blanket) :	0.39	0.32	0.25	0.32	0.32
Particles	5 to 15 um :	4895	1513	1481	3571	1947
Particles	15 to 25 um :	160	47	51	257	176
Particles	25 to 50 um :	31	6	11	79	90
Particles	50 to 100 um :	1	0	2	3	12
Particles	> 100 um :	0	0	0	1	0
D1533	Moisture (ppm) :	8	8	9	14	5
D1816	Dielectric BV (kV) :	41	33	40	26	33
D974	Acid Number (mg KOH/g) :	0.07	0.06	0.06	0.05	0.06
D971	Interfacial Tension (dynes/cm) :	24.0	26.2	27.1	29.7	35.0
D1500	Color Number :	2.0	<2.5	2.0	<2.5	<2.5
D924	Power Factor :	0.100	0.124	0.133	0.119	0.126
D2668	Oxidation Inhibitor (%) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	3 ID: 200331	3 ID: 200331	3 ID: 200331	3 ID: 200331	3 ID: 200331
	Sampler: David Warren	Sampler: William Crane	Sampler: David Warren	Sampler: William Crane	Sampler: David Warren

Sampling Interval : Retest in three months.

Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.

Comments : Arcing is indicated. Partial discharge is indicated. Paper condition is normal.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 11-15-2023
Report Number : 5081188
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink, appearing to read 'MKutzleb', written over a horizontal line.

Michelle Kutzleb, PhD
Director of Operations



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 12-01-2023
Report Number : 5081286
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

	Sample Date :	11/15/2023	11/1/2023	7/13/2023	5/8/2023	3/20/2023
Laboratory No. :		5081286	5081188	5080444	5080048	5079889
Container No. :		54497	54464	4660	53417	53414
Temperature :		32	36	47	31	48
H2	Hydrogen (ppm) :	22	17	17	13	21
CH4	Methane (ppm) :	8	7	6	6	9
C2H6	Ethane (ppm) :	2	1	1	1	2
C2H4	Ethylene (ppm) :	36	34	34	31	32
C2H2	Acetylene (ppm) :	34	34	38	34	31
CO	Carbon monoxide (ppm) :	486	405	335	293	346
CO2	Carbon dioxide (ppm) :	2865	2600	1919	2212	2181
N2	Nitrogen (ppm) :	71204	71485	72869	79052	79073
O2	Oxygen (ppm) :	14174	21820	27096	31024	21856
	Total (ppm) :	88831	96403	102315	112666	103551
	TDCG (ppm) :	588	498	431	378	441
	SHL (%) :	9.98	10.03	9.65	9.82	9.44
	ETCG (% in blanket) :	0.50	0.39	0.32	0.25	0.32
Particles	5 to 15 um :	655	4895	1513	1481	3571
Particles	15 to 25 um :	31	160	47	51	257
Particles	25 to 50 um :	9	31	6	11	79
Particles	50 to 100 um :	0	1	0	2	3
Particles	> 100 um :	0	0	0	0	1
D1533	Moisture (ppm) :	10	8	8	9	14
D1816	Dielectric BV (kV) :	30	41	33	40	26
D974	Acid Number (mg KOH/g) :	0.07	0.07	0.06	0.06	0.05
D971	Interfacial Tension (dynes/cm) :	21.9	24.0	26.2	27.1	29.7
D1500	Color Number :	2.0	2.0	<2.5	2.0	<2.5
D924	Power Factor :	0.098	0.100	0.124	0.133	0.119
D2668	Oxidation Inhibitor (%) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 HMF	5 hydroxymethyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FAL	2 furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 ACF	2 acetylfuran (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
5 MEF	5 methyl-2-furaldehyde (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
2 FOL	2 furfural (ppm) :	<0.010	<0.010	<0.010	<0.010	<0.010
	Estimated DP :	>1000	>1000	>1000	>1000	>1000

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment :	3 ID: 200331	3 ID: 200331	3 ID: 200331	3 ID: 200331	3 ID: 200331
	Sampler: David Warren	Sampler: David Warren	Sampler: William Crane	Sampler: David Warren	Sampler: William Crane

Sampling Interval : Retest in three months.

Operating Procedure : Monitor for increased arcing. Evaluate for worn or damaged components.

Comments : Arcing is indicated. Partial discharge is indicated. Paper condition is normal.

Field Comments : Fluid condition is within acceptable in-service parameters.



Transformer Condition Assessment TM

Glenn Samms
Newfoundland Power
P.O. Box 8910
55 Kenmount Road
St. John's, NF A1B 3P6

Location : Pulpit Rock
Bank & Phase : PUL-T2
Serial Number : 46311
Manufacturer : FPL
Date Mfgd : 1985
Size (kVA) : 25000
Rating kV : 66

Date : 12-01-2023
Report Number : 5081286
Fluid volume : 600
Fluid type : Mineral Oil
Preservation : Conservator
Cooling : ONAN/ONAF/ONAF
Core & coil wt. : 22589
Impedance :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received; it is recommended that samples are collected according to ASTM D923 or equivalent. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink, appearing to read 'MKutzleb', written over a horizontal line.

Michelle Kutzleb, PhD
Director of Operations