

Transmission

- Q. Reference: "2025 Capital Budget Application," Newfoundland Power Inc., June 28, 2024, Supporting Materials, Transmission: 3.1, sec. 3.0, pp. 12–20.**
- a) Please provide a breakdown of operating and maintenance costs and/or other costs utilized as inputs for the cost-benefit analysis for each alternative.**
 - b) Please provide a listing, including costs, for each of the "Future Rebuilds" referenced in the capital costs table for each alternative.**
 - c) Please confirm that there are no additional capital costs that are necessitated by each alternative, other than those listed in the capital cost tables.**
- A.
- a) See the response to Request for Information PUB-NP-032, part a).
 - b) Table 1 provides the capital costs for the future rebuilds associated with Alternatives 1 and 3.

Table 1 Alternatives 1 and 3 - Expected Future Rebuilds 2030 – 2036 Period (2025 \$000's)	
Description	Capital Cost
Rebuild Transmission Line 142L	16,600
Rebuild 22 km section of Transmission Line 114L	7,200
Refurbishment & Modernization of JON Substation	1,600
Total	25,400

Alternatives 1 and 3 are based on Transmission Line 108L being rebuilt, and the replacement for Gander ("GAN") Substation system power transformer GAN-T2 being installed at GAN Substation.

21 Table 2 provides the capital costs for the future rebuilds associated with
 22 Alternative 2.

Table 2 Alternative 2 - Expected Future Rebuilds 2030 – 2036 Period (2025 \$000's)	
Description	Capital Cost
Rebuild Transmission Line 142L	16,600
Rebuild 20 km Section of Transmission Line 114L	6,700
Total	23,300

23 Alternative 2 involves the construction of a new 138 kV transmission line between
 24 Lewisporte ("LEW") and Boyd's Cove ("BOY") substations, and the GAN-T2
 25 replacement being installed at BOY Substation.

26
 27 The 2025 to 2027 capital costs associated with Alternative 2 include rebuilding
 28 approximately 2 km of Transmission Line 114L as part of a double-circuit extension
 29 of Transmission Line 142L to facilitate the normal supply to Gander Bay ("GBY")
 30 Substation to be transferred to BOY Substation through Transmission Line 114L.¹ As
 31 a result, capital expenditures associated with rebuilding the remaining 20 km section
 32 of Transmission Line 114L between GBY and BOY substations provided in Table 2
 33 have been reduced relative to those of rebuilding the entire transmission line as
 34 provided Table 1. Similarly, Alternative 2 facilitates the retirement of Jonathan's
 35 Pond ("JON") Substation and includes costs associated with constructing a
 36 single-phase extension to supply existing JON Substation customers from Cobb's
 37 Pond ("COB") Substation distribution feeder COB-02. As a result, Table 2 also
 38 excludes costs associated with refurbishing and modernizing JON Substation.

39
 40 c) It is confirmed that the capital costs provided for each alternative assessed in report
 41 *3.1 Gander-Twillingate Transmission System Planning Study* include all expected
 42 costs associated with each alternative. For example, Alternative 2 includes provisions
 43 for: (i) constructing a single-phase extension of distribution feeder COB-02 to
 44 maintain supply to customer served by JON Substation following the retirement of
 45 the substation; (ii) a 138 kV grounding transformer to maintain a ground source at
 46 GAN Substation following the relocation of GAN-T2; (iii) extensions of existing
 47 transmission lines to maintain supply to GBY Substation and 104L; and
 48 (iv) necessary upgrades to LEW and BOY substations to facilitate the construction of
 49 the newly proposed 138 kV transmission line.

¹ In the existing transmission configuration, as well as the configurations proposed in Alternatives 1 and 3, normal supply to GBY Substation would be maintained through Transmission Line 108L served by GAN Substation system power transformer GAN-T2.