

1 **Q. Reference: NLH-NP-009 and NLH-NP-010.**
 2 **In its application, Newfoundland Power has stated that it has not considered**
 3 **repair of GAN-T2 and PUL-T2 due to the reliability risk associated with**
 4 **committing a spare transformer for an extended period of time while repairs**
 5 **are completed.**

6 **a) Without assessing the cost of repairing GAN-T2 and PUL-T2, how has**
 7 **Newfoundland Power determined that repair does not constitute an**
 8 **appropriate balance between cost and reliability?**

9 **b) Newfoundland Power states that it has multiple spares, in the form of**
 10 **spare substation transformers or portable substations, for GAN-T2 and**
 11 **PUL-T2. How many spares or backup options would be required for**
 12 **Newfoundland Power to consider committing a spare to facilitate the**
 13 **repair of a transformer?**

14 **c) Has Newfoundland Power considered increasing the number of spares or**
 15 **portable substations to enable the consideration of potential lower-cost**
 16 **options, such as equipment repair rather than replacement? If not, why**
 17 **not?**

18
 19 **A. a)** Newfoundland Power is proposing the proactive replacement of PUL-T2 and GAN-T2
 20 to reduce the immediate risks associated with the in-service failure of these units to
 21 an acceptable level. These risks exist due to the deteriorating condition of these
 22 transformers, the increasing delivery lead times of power transformers, the
 23 Company's limited emergency response capabilities, and the increased possibility of
 24 other transformer failures due to the Company's aging fleet.

25
 26 Repairing these units instead of proactively replacing them would not reduce the
 27 immediate risks associated with these transformers, nor the related risks to the
 28 power transformer fleet. Repairing PUL-T2 or GAN-T2 would require them to be
 29 removed from service for 18 to 24 months requiring the long-term installation of a
 30 portable substation or spare power transformer. Due to the Company's limited
 31 number of portable substations and spare power transformers, this would put
 32 additional pressure on the Company's emergency response capabilities, creating an
 33 unacceptable risk to customers.

34
 35 As outlined in the response to Request for Information CA-NP-119, part c), following
 36 the replacement of a power transformer, the units are assessed and, depending on
 37 the condition of the transformer, they may be used for a spare, considered for repair
 38 or scrapped. Once the PUL-T2 and GAN-T2 transformers are replaced and removed
 39 from service, Newfoundland Power will then consider the feasibility of repairing
 40 these transformers. If a repair is feasible and cost effective, the Company will then
 41 evaluate repairing these units, and following a successful repair, the units would be
 42 placed into spares for the transformer fleet.

43
 44 **b)** The exact number of additional spare transformers required to facilitate the option of
 45 repair of PUL-T2 and GAN-T2 would be dependent on several factors, including: the
 46 available spares, the spares on order, the configuration of the spares, the current
 47 lead times of transformers, the condition of the transformers being considered for
 48 repair, the health of the overall transformer fleet, among many other factors. To

1 consider committing a spare to repair an existing unit, Newfoundland Power would
2 need to ensure that additional spares are available to cover the potential failure of
3 other transformers within the fleet during the repair period.

4
5 With respect to PUL-T2, Newfoundland Power does not presently have a suitable
6 spare transformer. The spare transformer that was procured through the *Substation*
7 *Spare Transformer Inventory* project approved in the Company's *2023 Capital*
8 *Budget Application* will be a suitable spare. It is expected to arrive in the fourth
9 quarter of 2024. This spare transformer will be the only unit providing backup
10 coverage for 39 of Newfoundland Power's other power transformers. The
11 justification for this spare transformer still exists. If this spare transformer was to be
12 installed in response to an emergency failure of PUL-T2, then another spare
13 transformer would still be required as a backup to the other 39 transformers.

14
15 Newfoundland Power has one suitable spare transformer for GAN-T2. The spare
16 transformer that is capable of replacing GAN-T2 is presently installed in the Salt
17 Pond ("SPO") Substation with the designation SPO-T5, and is currently serving as an
18 in-service backup to SPO-T4.¹ SPO-T5 is the only unit providing backup coverage for
19 11 of Newfoundland Power's other power transformers. If this unit was to be used to
20 replace GAN-T2 in response to an emergency failure, there would be no spare
21 available for the other 11 transformers. SPO-T5 must also be reinstalled on the Burin
22 Peninsula once it is no longer needed for emergency use.

23
24 With present power transformer delivery times estimated between 24 and 36
25 months, and upwards of 60 months for some manufacturers, committing spares to
26 PUL-T2 and GAN-T2 would put additional risk on the Company's power transformer
27 fleet while waiting for other spare transformers to arrive.

28
29 Newfoundland Power does not consider a portable substation as a spare
30 transformer. Portable substations are typically utilized to support the Company's
31 capital and maintenance programs for substations, as well as to respond to in-
32 service equipment failures. Typically, portable substation installations are intended
33 for short-term usage.

- 34
35 c) Newfoundland Power is continuously evaluating and improving its asset
36 management practices for power transformers to ensure a balance in reliability and
37 cost-effectiveness. Due to the increasing delivery lead times of power transformers,
38 limited emergency response capabilities, and the increased possibility of failure of
39 the aging fleet, the optimal amount of spare power transformers and portable
40 substations that Newfoundland Power requires is being reviewed as part of its power
41 transformer asset management practices. At this time, Newfoundland Power is
42 proposing the proactive replacement of PUL-T2 and GAN-T2 to reduce the
43 immediate risk to an acceptable level.

¹ SPO-T5 works in tandem with power transformer SPO-T4 serving approximately 8,313 customers on the Burin Peninsula. These two power transformers provide N-1 redundancy for supplying the 66 kV transmission system.