

**2025 Capital Budget Overview**

**Q. Appendix B: Deferred, Modified and Advanced Capital Expenditures, Table B-2. For the four capital projects being deferred from 2025 to subsequent years, please provide further explanation for each project as to how it reached the stage of consideration for inclusion in the 2025 Capital Budget if sufficient engineering had not been completed, and what specifically for each project requires additional engineering assessment.**

A. The response to Request for Information PUB-NP-015 provides an explanation of how projects are identified for inclusion in the capital budget.

Five projects are listed in Appendix B, Table B-2 as deferred to future years. The four projects deferred for further engineering assessment are: (i) *Grand Falls 4160 V Conversion*; (ii) *Cape Broyle Hydro Plant Refurbishment*; (iii) *Petty Harbour Substation Refurbishment and Modernization*; and (iv) *Rose Blanche Hydro Plant Refurbishment*.

Each of the four capital projects were identified for inclusion in previous five-year capital plans. The most recent annual review of the five-year capital plan, in preparation for the *2025 Capital Budget Application*, commenced with a review of potential capital projects in the budget year. Through the annual review process it was determined that four projects required additional engineering assessment and, as a result, each project was deferred. Further explanation of the additional engineering assessment requirements for each project are included below.

*Grand Falls 4160 V Conversion*

The *Grand Falls 4160 V Conversion* project involves the conversion of legacy 4160 V to 25 kV feeders in Grand Falls. The 4160 V equipment in Grand Falls substation is nearing end of life and the 4160 V distribution system is nearing capacity.

The majority of the 4160 V distribution system is rear lot construction and was installed in the 1960s. As a result, accessing this infrastructure to perform necessary upgrades will require significant planning. A significant amount of the primary conductors on the system are installed on the same poles in a double circuit configuration. In addition, there are limited locations where the 4160 V load can be transferred to the 25 kV system. Further engineering assessment is necessary to complete a system planning study on the 25 kV system to determine the final configuration of the system and establish a conversion plan. Once the planning study is complete, a detailed engineering and construction plan will be completed to determine the cost estimate and schedule for the project.

*Cape Broyle Hydro Plant Refurbishment*

The *Cape Broyle Hydro Plant Refurbishment* project involves the refurbishment of the plant to replace obsolete equipment.

1 Accessing the plant with heavy equipment is difficult due to the plant location. Gaining  
2 access to Cape Broyle ("CAB") substation is also challenging as it is located adjacent to  
3 the plant. There is very little room to increase the square footage of the plant to  
4 accommodate the installation of the new equipment. Further engineering assessment is  
5 required to determine the least-cost approach to execute the *Cape Broyle Hydro Plant*  
6 *Refurbishment* project and to determine if a refurbishment and modernization of CAB  
7 substation should align with the work in the plant.

#### 8 9 *Petty Harbour Substation Refurbishment and Modernization*

10  
11 The *Petty Harbour Substation Refurbishment and Modernization* project will involve the  
12 refurbishment of the substation to address deteriorated and non-standard equipment in  
13 the substation.

14  
15 The Petty Harbour ("PHR") substation is connected to the electrical system via radial  
16 transmission line 3L from the Goulds ("GOU") substation. Transmission line 3L is  
17 energized at 33kV, which is a non-standard legacy transmission voltage and is the last  
18 transmission line at this voltage in the Newfoundland Power electrical system. PHR has a  
19 generation power transformer that connects three hydro generators to the electrical  
20 system and also a distribution power transformer that provides service to customers in  
21 Petty Harbour - Maddox Cove. PHR-01 is energized at 4.16kV which is a non-standard  
22 legacy distribution voltage.

23  
24 GOU substation provides service to customers in Kilbride, Southlands and the Goulds.  
25 Big Pond ("BIG") substation also provides service to customers in the Goulds and the  
26 Bay Bulls Big Pond Water Treatment Plant. BIG substation is located in the Public  
27 Protected Water Shed Area for the City of St. John's. Both GOU and BIG substations are  
28 included in the *Substation Refurbishment and Modernization Plan*<sup>1</sup> as part of the  
29 *2025-2029 Capital Plan*. Further engineering assessment is necessary to complete a  
30 system planning study of the available alternatives in order to continue to provide  
31 least-cost, reliable service to the customers in Kilbride, Southlands, Goulds and Petty  
32 Harbour – Maddox Cove while also providing a connection for the PHR substation to the  
33 electrical system.

#### 34 35 *Rose Blanche Hydro Plant Refurbishment*

36  
37 The *Rose Blanche Hydro Plant Refurbishment* project involves the modernization of the  
38 governor system as well as addressing identified deficiencies within the hydraulic power  
39 unit and the plant electrical system.

40  
41 This project was initially planned for 2024 as a direct replacement of the governor  
42 control system due to the obsolescence of its programmable logic controller. While  
43 completing the engineering assessment for this project, deficiencies were identified with  
44 the hydraulic power unit and plant electrical system. This project has been deferred to  
45 allow engineering assessments associated with the change in project scope.

---

<sup>1</sup> See Newfoundland Power's *2025 Capital Budget Application*, report 2.1 *2025 Substation Refurbishment and Modernization*, page 3, Table 1.