



Newfoundland and Labrador Hydro  
Hydro Place, 500 Columbus Drive  
P.O. Box 12400, St. John's, NL  
Canada A1B 4K7  
t. 709.737.1400 | f. 709.737.1800  
nlhydro.com

April 29, 2022

Board of Commissioners of Public Utilities  
Prince Charles Building  
120 Torbay Road, P.O. Box 21040  
St. John's, NL A1A 5B2

Attention: Ms. Cheryl Blundon  
Director of Corporate Services & Board Secretary

Dear Ms. Blundon:

**Re: Quarterly Report on Performance of Generating Units for the Twelve Months Ended  
March 31, 2022**

Please find enclosed Newfoundland and Labrador Hydro's "Quarterly Report on Performance of  
Generating Units for the Twelve Months Ended March 31, 2022."

If you have any questions or comments, please contact the undersigned.

Yours truly,

**NEWFOUNDLAND AND LABRADOR HYDRO**

Shirley A. Walsh  
Senior Legal Counsel, Regulatory  
SAW/kd

Encl.

ecc:

**Board of Commissioners of Public Utilities**  
Jacqui H. Glynn  
PUB Official Email

**Consumer Advocate**  
Dennis M. Browne, QC, Browne Fitzgerald Morgan & Avis  
Stephen F. Fitzgerald, Browne Fitzgerald Morgan & Avis  
Sarah G. Fitzgerald, Browne Fitzgerald Morgan & Avis  
Bernice Bailey, Browne Fitzgerald Morgan & Avis  
Bernard M. Coffey, QC

**Labrador Interconnected Group**  
Senwung F. Luk, Olthuis Kleer Townshend LLP  
Joshua H. Favel, Olthuis Kleer Townshend LLP

**Newfoundland Power Inc.**  
Dominic J. Foley  
Lindsay S.A. Hollett  
Regulatory Email

**Island Industrial Customer Group**  
Paul L. Coxworthy, Stewart McKelvey  
Denis J. Fleming, Cox & Palmer  
Dean A. Porter, Poole Althouse



# **Quarterly Report on Performance of Generating Units for the Twelve Months Ended March 31, 2022**

**April 29, 2022**

**A report to the Board of Commissioners of Public Utilities**



## **Contents**

1.0	Introduction .....	1
2.0	Overview for Period Ending March 31, 2022 .....	2
3.0	Generation Planning Assumptions.....	3
4.0	Hydraulic Unit DAFOR Performance .....	4
5.0	Thermal Unit DAFOR Performance .....	9
6.0	Gas Turbine UFOP Performance .....	12
7.0	Gas Turbine DAUFOP Performance .....	14
8.0	Updated Planning Assumptions/Analysis Values.....	17
9.0	Comparison of Planning Assumptions and Analysis Values.....	19

## **1.0 Introduction**

In this report, Newfoundland and Labrador Hydro (“Hydro”) provides data on forced outage rates of its generating facilities. The data provided pertains to historical forced outage rates and assumptions Hydro uses in its assessments of resource adequacy. This report covers the performance of Hydro’s generating units for the 12 months ended March 31, 2022.

This report contains forced outage rates for the current 12-month reporting period of April 1, 2021 to March 31, 2022 for individual generating units at hydraulic facilities, the Holyrood Thermal Generating Station (“Holyrood TGS”), and Hydro’s gas turbines. This report also provides, for comparison purposes, the individual generating unit data on forced outage rates for the period of April 1, 2020 to March 31, 2021. Further, total asset class data is presented based on the calendar year for the years 2006 to 2020.

The forced outage rates of Hydro’s generating units are calculated using three measures: 1) Derated Adjusted Forced Outage Rate (“DAFOR”) for the hydraulic and thermal units, 2) Utilization Forced Outage Probability (“UFOP”), and 3) Derated Adjusted Utilization Forced Outage Probability (“DAUFOP”) for the gas turbines.

DAFOR is a metric that measures the percentage of time that a unit or group of units is unable to generate at its maximum continuous rating due to forced outages or unit deratings. The DAFOR for each unit is weighted to reflect differences in generating unit sizes to provide a company total and reflect the relative impact a unit’s performance has on overall generating performance. This measure is applied to hydraulic and thermal units; however, it is not applicable to gas turbines because of their operation as standby units and their relatively low operating hours.

UFOP and DAUFOP are measures used for gas turbines. UFOP measures the percentage of time that a unit or group of units will encounter a forced outage and not be available when required. DAUFOP is a metric that measures the percentage of time that a unit or group of units will encounter a forced outage and not be available when required. This metric includes the impact of unit deratings.

The forced outage rates include outages that remove a unit from service completely, as well as instances when units are derated. If a unit’s output is reduced by more than 2%, the unit is considered derated under Canadian Electricity Association (“CEA”) guidelines. CEA guidelines require that derated levels of a

1 generating unit are calculated by converting the operating time at the derated level into an equivalent  
2 outage time.

3 In addition to forced outage rates, this report provides details for those outages that contributed  
4 materially to forced outage rates exceeding those used in Hydro’s generation planning analysis for both  
5 the near- and long-term.

6 The assumptions referred to throughout this report are the same as those reported in the 2018  
7 quarterly reports except for the new assumptions identified in Table 12. As part of its Reliability and  
8 Resource Adequacy Study, Hydro detailed the process undertaken to determine the forced outage rates  
9 most appropriate for use in its near-term reliability assessments and long-term resource adequacy  
10 analysis. The values have been updated to reflect the most current outage data and the revised forced  
11 outage rates that resulted from this process are included in Sections 8.8.0 and 9.0 of this report. The  
12 potential impacts of these revised forced outage rates on future performance reporting are also  
13 discussed. While the new assumptions form the basis of Hydro’s current planning processes, this report  
14 includes the historical assumptions and style to maintain similarity to previous reports.

## 15 **2.0 Overview for Period Ending March 31, 2022**

**Table 1: DAFOR, UFOP, and DAUFOP Overview (%)**

<b>Class of Units</b>	<b>1-Apr-2020 to 31-Mar-2021</b>	<b>1-Apr-2021 to 31-Mar-2022</b>	<b>Base Planning Assumption</b>	<b>Near-Term Planning Assumption<sup>1</sup></b>
Hydraulic (DAFOR)	0.89	3.00	0.90	2.60
Thermal (DAFOR)	6.75	33.84	9.64	14.00
Combined Gas Turbine (UFOP)	4.87	0.16	10.62	20.00
Holyrood Gas Turbine (UFOP)	7.21	0.00	5.00	5.00
Hardwoods/Stephenville Gas Turbine (DAUFOP)	5.66	1.40	-	30.00
Happy Valley Gas Turbine (DAUFOP)	9.53	0.00	-	15.00
Holyrood Gas Turbine (DAUFOP)	7.21	0.00	-	5.00

16 As shown in Table 1, hydraulic and thermal DAFOR performance declined for the current 12-month  
17 period ending March 31, 2022 compared to the 12-month period ending March 31, 2021. The UFOP and

<sup>1</sup> Refer to “Near-Term Generation Adequacy Report,” Newfoundland and Labrador Hydro, November 15, 2017, sec. 5.0 for further details.

1 DAUFOP performance for all gas turbines improved in the current period compared to the 12-month  
2 period ending March 31, 2021.

3 Hydro began reporting DAUFOP performance in January 2018 for its gas turbines.

### 4 **3.0 Generation Planning Assumptions**

5 The Reliability and Resource Adequacy Study introduced new generation planning assumptions;  
6 however, the assumptions used throughout this report are the same as reported in previous quarterly  
7 reports. The potential impacts of these revised assumptions on reporting of generation unit  
8 performance are discussed in Section 9.0 of this report. While the new assumptions form the basis of  
9 Hydro's current planning processes, this report includes the historical assumptions and style to maintain  
10 similarity to previous reports while the regulatory process surrounding the *Reliability and Resource*  
11 *Adequacy Study Review* proceeding remains underway.

12 Hydro produces reports based on comprehensive reviews of energy supply for the Island Interconnected  
13 System. This is part of Hydro's analysis of energy supply up to the Muskrat Falls interconnection. The  
14 May 2018 "Near-Term Generation Adequacy Report,"<sup>2</sup> contains an analysis based on the near-term  
15 DAFOR and DAUFOP and the resulting implications for meeting reliability criteria until the  
16 interconnection with the North American Grid. The near-term analysis has been updated since that time  
17 to reflect changes in assumptions with respect to the in-service of the Labrador-Island Link. The results  
18 of this analysis were presented to the Board of Commissioners of Public Utilities ("Board") as part of the  
19 "Labrador-Island Link In-Service Update."<sup>3</sup>

20 Hydro's DAFOR and UFOP planning assumptions are provided in Table 2. The Holyrood Gas Turbine has a  
21 lower expected rate of unavailability than the older gas turbines (5% compared to 10.62%) as the unit is  
22 newer and can be expected to have better availability than the older units.<sup>4</sup>

---

<sup>2</sup> "Near-Term Generation Adequacy Report," Newfoundland and Labrador Hydro, rev. May 30, 2018 (originally filed May 22, 2018).

<sup>3</sup> Labrador-Island Link In-Service Update," Newfoundland and Labrador Hydro, October 1, 2018.

<sup>4</sup> Hydro selected a 5% UFOP for the new Holyrood Gas Turbine following commentary on forced outage rates contained in the "Independent Supply Decision Review," Navigant Consulting Ltd., September 14, 2011, filed as Attachment 1 to Hydro's response to PUB-NLH-010 from the *Investigation and Hearing into Supply Issues and Power Outages on the Island Interconnected* proceeding.

**Table 2: 2017<sup>5</sup> DAFOR and UFOP Long-Term Planning Assumptions (%)**

	DAFOR		UFOP	
	Base Planning Assumption	Sensitivity	Base Planning Assumption	Sensitivity
Hydraulic Units	0.90	0.90	-	-
Thermal Units	9.64	11.64	-	-
Gas Turbines: Existing	-	-	10.62	20.00
Gas Turbines: New	-	-	5.0	10.0

- 1 The DAFOR and DAUFOP assumptions used in developing the May 2018 “Near-Term Generation
- 2 Adequacy Report” are noted in Table 3.

**Table 3: DAFOR and DAUFOP Near-Term Generation Adequacy Analysis Assumptions (%)**

	DAFOR Near-Term Generation Adequacy Assumption	DAUFOP Near-Term Generation Adequacy Assumption
All Hydraulic Units	2.6	-
Bay d’Espoir Hydraulic Units	3.9	-
Other Hydraulic Units	0.7	-
Holyrood TGS	14.0	-
Hardwoods and Stephenville Gas Turbines	-	30.0
Happy Valley Gas Turbine	-	15.0
Holyrood Gas Turbine	-	5.0

### 3 **4.0 Hydraulic Unit DAFOR Performance**

- 4 Detailed results for the 12-month period ending March 31, 2022 are presented in Table 4, as well as the
- 5 data for the 12-month period ending March 31, 2021. These are compared to Hydro’s short-term
- 6 generation adequacy assumptions, as used in the May 2018 “Near-Term Generation Adequacy Report,”
- 7 and Hydro’s long-term generation planning assumptions for the forced outage rate.

<sup>5</sup> Refer to “Near-Term Generation Adequacy Report,” Newfoundland and Labrador Hydro, November 15, 2017, sec. 5.0 for further details.

Table 4: Hydraulic Weighted DAFOR

Generating Unit	Maximum Continuous Unit Rating (MW)	12 Months Ending March 2021 (%)	12 months ending March 2022 (%)	Historical Base Planning Assumption (%)	Historical Near-Term Planning Assumption (%)
<i>All Hydraulic Units - weighted</i>	954.4	0.89	3.00	0.90	2.60
<b>Hydraulic Units</b>					
Bay D'Espoir 1	76.5	1.45	3.31	0.90	3.90
Bay D'Espoir 2	76.5	0.00	0.00	0.90	3.90
Bay D'Espoir 3	76.5	2.55	0.00	0.90	3.90
Bay D'Espoir 4	76.5	5.60	0.00	0.90	3.90
Bay D'Espoir 5	76.5	1.09	1.97	0.90	3.90
Bay D'Espoir 6	76.5	0.08	0.12	0.90	3.90
Bay D'Espoir 7	154.4	0.46	0.00	0.90	3.90
Cat Arm 1	67	0.15	1.44	0.90	0.70
Cat Arm 2	67	0.27	1.06	0.90	0.70
Hinds Lake	75	0.77	0.46	0.90	0.70
Upper Salmon	84	0.06	22.62	0.90	0.70
Granite Canal	40	2.22	0.57	0.90	0.70
Paradise River	8	1.31	1.15	0.90	0.70




Figure 1: Hydraulic Weighted DAFOR



1 Considering individual hydraulic unit performance, the Bay d’Espoir Unit 1 DAFOR of 3.31% did not meet  
2 the historical base planning assumption of 0.9% but is below the historical near-term planning  
3 assumption of 3.90% for an individual Bay d’Espoir unit. As previously reported, Bay d’Espoir Unit 1 has  
4 experienced two forced outages which impacted the DAFOR performance for the current period. The  
5 first, from May 14 to 20, 2021, was a forced extension of the planned outage, as a result of findings in  
6 the scheduled inspection of Penstock 1. During the inspection, a number of distinct indications of weld  
7 deterioration were identified in 16 longitudinal weld seams. The indications were similar in condition to  
8 those discovered in recent years and were shallow in depth. Weld refurbishment and final inspection  
9 were completed and the penstock was returned to service. This discovery was not unexpected given the  
10 known condition of the Bay d’Espoir penstocks. Hydro will use the information obtained through the  
11 inspection and refurbishment process to inform its long-term plan for the penstocks; the details of  
12 Hydro’s long-term plan are expected to be filed with the Board in 2022. The final outage that impacted  
13 Bay d’Espoir Unit 1 DAFOR performance occurred May 29 to June 3, 2021 when the unit was removed  
14 from service to investigate elevated governor oil temperatures. The investigation discovered  
15 misalignment of the permanent magnet generator (“PMG”) coupling which caused excessive strain and  
16 subsequent shearing of the drive pins which then contributed to the failure of a piston seal ring in the  
17 servomotor. The necessary repairs were completed and the unit returned to service. Work orders were  
18 entered to inspect other units with similar PMG couplings during the next planned outage and  
19 preventative maintenance programs were updated to include the verification of alignment of the PMG  
20 coupling. To date, inspections have been completed on Bay d’Espoir Units 4, 5 and 6 as well as the Hinds  
21 Lake Unit with no findings of concern. Remaining inspections will be completed during the 2022 annual  
22 outages.

23 The Bay d’Espoir Unit 5 DAFOR of 1.97% did not meet the historical base planning assumption of 0.9%  
24 but is below the historical near-term planning assumption of 3.90% for an individual Bay d’Espoir unit.  
25 This increase in DAFOR was the result of two forced outages experienced in March 2022. The first, on  
26 March 13, 2022 was caused by the failure of a governor pump motor. Maintenance crews replaced the  
27 failed motor with inventory spare and the unit was returned to service. The second outage occurred on  
28 March 30, 2022 and was required to address a hot connection on Phase-A of the unit manual disconnect  
29 switch, 29-5. On March 29, 2022 it was reported that Phase-A connection was showing 40 degrees  
30 higher than Phases B and C. At that time the unit was derated to 20 MW until it could be removed from  
31 service to investigate and complete necessary corrective actions. The investigation revealed

1 misalignment and poor surface contact on the affected phase. Components were replaced and the unit  
2 returned to service. Temperatures are now acceptable on the affected phase.

3 The Cat Arm Unit 1 DAFOR of 1.44% for the current period did not meet either the historical near-term  
4 planning assumption of 0.7% or the historical base planning assumption of 0.9%. This was the result of  
5 the previously reported deratings experienced through the months of September and October, as well  
6 as one forced outage experienced since the previous filing. The deratings were the result of increased  
7 generator surface air cooler temperatures due to reduced cooling capacity. The reduced cooling capacity  
8 occurred from a buildup of water contaminants in the cooler tubing, commonly referred to as fouling.  
9 Surface air coolers are cleaned annually at a set frequency during unit outages; however, this frequency  
10 was disrupted in 2021 with annual outages in Cat Arm scheduled later in the year, increasing the  
11 duration between cleaning cycles and allowing cooler fouling to progress further than normal. The  
12 coolers have since been thoroughly cleaned and the unit returned to full capacity. Additionally, the unit  
13 experienced a forced outage on February 17, 2022 while operating in synchronous condenser mode,  
14 which was caused by a low auxiliary cooling water supply to the unit, experienced when one unit is  
15 offline and the other is operating in sync condense. A capital project is planned for 2022 to upgrade the  
16 cooling water system in Cat Arm, which will include the replacement of cooling water valves.

17 The Cat Arm Unit 2 DAFOR of 1.06% for the current period did not meet either the historical near-term  
18 planning assumption of 0.7% or the historical base planning assumption of 0.9%. This was the result of  
19 four forced outages experienced in the current period. As previously reported, the first (May 25, 2021)  
20 and second (July 24, 2021) outages were both the result of failed solenoid coils on the shutdown valve  
21 assembly. The failed components were replaced and the entire valve assembly is to be replaced at the  
22 next opportunity. The third outage (August 28, 2021) was caused by a leaking governor sump cooler. A  
23 replacement cooler was installed on the unit and then the unit was returned to service. The fourth  
24 outage occurred on December 27, 2021, resulting from low governor accumulator oil level. Investigation  
25 determined there was excess air in the accumulator. This issue was addressed and the unit returned to  
26 service. It is noted that all components of this system were tested during annual maintenance activities  
27 in November 2021 with no deficiencies found. To mitigate the potential for a future forced outage,  
28 remedial actions to further inspect, test, and verify components of the accumulator system are planned  
29 for the 2022 annual maintenance outage.

30 The Upper Salmon unit DAFOR of 22.62% for the current period did not meet either the historical near-  
31 term planning assumption of 0.7% or the historical base planning assumption of 0.9%. As filed

1 previously, during the 2021 planned annual preventative maintenance inspection in August 2021, a  
2 significant crack on rim guidance block #10 was discovered. Further inspection of all rim guidance blocks  
3 revealed that over 35% (6 of 16 total blocks) of the rim guidance blocks exhibited cracking. Metallurgy  
4 analysis determined the failure mode was due to fatigue cracking. The cracking was beyond repair and  
5 the blocks were replaced. In addition, after consultation with the original equipment manufacturer  
6 (“OEM”), it was determined that adjacent blocks to the cracked blocks were subjected to higher than  
7 normal forces due to the reduced strength of the cracked blocks and would likely also suffer damage  
8 and failure. To ensure continued reliable operation of the Upper Salmon unit, all 16 blocks were  
9 replaced. This work was not included in the scope of the planned outage, thus resulting in a forced  
10 extension to the outage which lasted from August 21 to October 21, 2021. The OEM attributes the cause  
11 of this issue to be a combination of an out-of-round stator and a loose rotor rim; addressing this life  
12 extension work was not possible prior to the 2021–2022 winter season; however, replacement of the  
13 blocks before the winter operating season is considered a suitable approach by the OEM to reduce the  
14 residual risk to an acceptable level. In addition to the block replacement, the OEM has recommended  
15 implementing a non-destructive testing (“NDT”) inspection program of the blocks at 12-week intervals  
16 until life extension work is completed. This inspection program is now included in Hydro’s work plan. A  
17 NDT inspection of the blocks was completed in November 2021 when the opportunity was presented  
18 during an unplanned outage to the unit. This inspection revealed no material concerns. The first OEM  
19 recommended monitoring inspection was completed in February 2022 and revealed no issues of  
20 concern on the newly installed blocks; however, minor cracking was identified on rotor rim keys as had  
21 been seen in previous years.

22 The planned life extension is expected to be carried out to address the out-of-round stator and loose  
23 rotor rim, subject to Board approval of Hydro’s supplemental capital expenditure application.<sup>6</sup>

24 As previously reported, the Upper Salmon unit experienced two additional forced outages which  
25 contributed to this increase in DAFOR. The first, on November 5, 2021 was the result of a failed low  
26 voltage jumper on the generator step-up transformer, USL T1. The investigation into the cause of the  
27 failure is ongoing, and includes a review of the preventative maintenance program. The failed jumper  
28 was replaced and the unit returned to service on November 10, 2021. However, a short time after  
29 return to service on November 10, 2021, the unit experienced a field ground and was once again taken

---

<sup>6</sup> “Application for Approval for Rotor Rim Shrinking and Stator Recentering at the Upper Salmon Hydroelectric Generating Station,” Newfoundland and Labrador Hydro, April 26, 2022.

1 offline. Investigation discovered a ground on rotor pole #9, this pole was replaced with a spare and a  
 2 thorough inspection and cleaning of the unit was completed. The unit was returned to service on  
 3 November 17, 2021.

4 The Paradise River unit DAFOR of 1.15% did not meet either the historical near-term planning  
 5 assumption of 0.7% or the historical base planning assumption of 0.9%. The Paradise River unit was  
 6 unavailable due to a forced outage from October 17 to 19, 2021. This outage was the result of a failed  
 7 servomotor seal. This seal was original and has been in service since the unit was first commissioned.  
 8 The seal was replaced and the unit returned to service.

## 9 **5.0 Thermal Unit DAFOR Performance**

10 Detailed results for the 12-month period ending March 31, 2022 and the 12-month period ending  
 11 March 31, 2021 are presented in Table 5. These results are compared to Hydro’s short-term generation  
 12 adequacy assumptions, as used in the May 2018 “Near-Term Generation Adequacy Report,” and Hydro’s  
 13 long-term generation planning assumptions for the forced outage rate.

**Table 5: Thermal DAFOR**

<b>Generating Unit</b>	<b>Maximum Continuous Unit Rating (MW)</b>	<b>12 Months Ending March 2021 (%)</b>	<b>12 months ending March 2022 (%)</b>	<b>Historical Base Planning Assumption (%)</b>	<b>Historical Near- Term Planning Assumption (%)</b>
<i>All Thermal Units - weighted</i>	490	6.75	33.84	9.64	14.00
<b>Thermal Units</b>					
Holyrood 1	170	4.85	33.40	9.64	15.00
Holyrood 2	170	7.80	31.67	9.64	10.00
Holyrood 3	150	7.82	37.15	9.64	18.00




Figure 2: Thermal DAFOR

1 For the 12-month period ending March 31, 2022, the weighted DAFOR for all thermal units of 33.84% is  
 2 above the historical base planning assumption DAFOR value of 9.64% and the historical near-term  
 3 planning assumption of 14.00%.

4 Unit 1 DAFOR was 33.40%, which is above both the historical base planning assumption of 9.64% and  
 5 the historical near-term planning assumption of 15.00%. The increase in Unit 1 DAFOR is a result of two  
 6 significant events as reported in the previous filing; a forced extension of the planned annual  
 7 maintenance outage and a water hammer event that caused damage to the cold reheat line between  
 8 the turbine and the boiler during start-up of the unit upon completion of the annual outage.

9 The annual maintenance outage was planned to be completed on September 10, 2021 but the unit  
 10 remained on maintenance outage until October 20, 2021. This forced extension was caused by a number  
 11 of significant findings during the execution of the planned major turbine overhaul. Most significant was  
 12 the additional time required to replace the high temperature studs that connect the upper half of the  
 13 turbine to the lower half at the horizontal joint. Also significant was damage found on the rotor and  
 14 diaphragms, which had to be corrected at site by GE experts, and alignment issues that required  
 15 correction. COVID-19 protocols associated with bringing experts to site further contributed to the  
 16 schedule delay.

1 On October 25, 2021, the unit experienced a water hammer event in the cold reheat pipe while  
2 restarting following successful completion of overspeed testing. The overspeed testing was required to  
3 verify turbine operation after completion of the overhaul work. Damage to the supports and insulation  
4 on this line was evident and start-up efforts ceased to allow an investigation of the cause of the event  
5 and assessment of the associated damage.

6 The investigating team, which included expert consultation from GE and Hatch, determined that water  
7 had been leaking into the cold reheat pipe through a spray station that is designed to control reheat  
8 steam temperature when online. The presence of this water during start-up led to a water hammer  
9 event, which caused the observed damage.

10 After completion of all remedial work, the unit was returned to service on December 1, 2021. A root  
11 cause investigation has been completed and a copy of the report was provided to the Board on March 4,  
12 2022. For each of the three units, the spray stations have been confirmed to be isolated, and spray  
13 station valves will be refurbished or replaced as required during the 2022 annual outage season.

14 Unit 2 DAFOR was 31.67 %, which is above the historical base planning assumption of 9.64% and the  
15 historical near-term assumption of 10.00%. This increase in DAFOR is the result of a failure of power  
16 transformer T2, which was discussed in the previous filing. The failure occurred on November 12, 2021  
17 and the unit was returned to service utilizing a spare transformer on January 13, 2022. With the spare  
18 transformer installed, Unit 2 has been proven to an output capacity of 150 MW which will be the  
19 capacity of the unit thorough the remainder of the 2021–2022 winter operating season. Efforts are  
20 ongoing to increase the unit output in advance of the 2022–2023 winter operating season, if these  
21 efforts are successful the capacity will be adjusted to reflect. Investigation into the cause of the T2  
22 power transformer failure is ongoing, Hydro has engaged outside technical support through both Hitachi  
23 Energy (ABB) and Doble Engineering to assist with this investigation.

24 Unit 3 DAFOR was 37.15%, which is above the historical base planning assumption of 9.64% and the  
25 historical near-term planning assumption of 18.00%. This increase in DAFOR is the result of a forced  
26 outage caused by a cold-side tube leak on the east side of the Unit 3 boiler, which was discussed in the  
27 previous filing. The leak occurred on September 11, 2021 during return to service after completion of  
28 the planned annual outage. The unit remained on forced outage until November 19, 2021 to allow for a  
29 complete investigation of the failure and an assessment of the condition of the remaining boiler tubes.

1 Hydro followed the recommendations from the boiler OEM (B&W), the boiler service provider (GE) and  
 2 an independent metallurgical engineering company. Hydro also engaged a specialized boiler tube  
 3 inspection company (TesTex) to complete the tube inspections. Investigation determined that the failure  
 4 was related to large structural attachments to tubes that are found in eight locations on this particular  
 5 boiler. All affected tubes were inspected and any found to have surface indications of depth beyond the  
 6 fit for service criteria established by the experts in accordance with applicable codes were replaced with  
 7 new tube material.

8 The current period DAFOR for all three Holyrood units has declined over the 12-month period ending  
 9 March 31, 2021.

## 10 **6.0 Gas Turbine UFOP Performance**

11 The combined UFOP for the Hardwoods, Happy Valley, and Stephenville Gas Turbines was 0.16% for the  
 12 12-month period ending March 31, 2022 (Table 6 and Figure 3). This performance is better than the  
 13 base planning assumption of 10.62% and the near-term assumption of 20.00% and is improved over  
 14 performance during the 12-month period ending March 31, 2021. The Stephenville Gas Turbine UFOP  
 15 for the current period is 0.45%, as compared to the historical base planning assumption of 10.62%. The  
 16 Hardwoods Gas Turbine UFOP for the current period is 0.12%, as compared to the base planning  
 17 assumption of 10.62%. The Happy Valley Gas Turbine UFOP is 0.00% for the current period, as compared  
 18 to the base planning assumption of 10.62%. On an individual unit basis, gas turbine UFOP performance  
 19 for the current period has improved for the Hardwoods, Stephenville, and Happy Valley units over the  
 20 12-month period ending March 31, 2021.

**Table 6: Gas Turbine UFOP**

Gas Turbine Units	Maximum Continuous Unit Rating (MW)	12 Months Ending March 2021 (%)	12 months ending March 2022 (%)	Historical Base Planning Assumption (%)	Historical Near-Term Planning Assumption (%)
<i>Combined Gas Turbines</i>	125	4.87	0.16	10.62	20.00
Stephenville	50	3.80	0.45	10.62	20.00
Hardwoods	50	3.37	0.12	10.62	20.00
Happy Valley	25	9.53	0.00	10.62	20.00




Figure 3: Gas Turbine UFOP: Hardwoods/Happy Valley/Stephenville Units

- 1 The Holyrood Gas Turbine UFOP for the current period is 0.00%, which is below the historical base and
- 2 near-term planning assumptions of 5.00% (Table 7 and Figure 4) and has improved when compared to
- 3 the 12-month period ending March 31, 2021.

Table 7: Holyrood Gas Turbine UFOP

Gas Turbine Units	Maximum Continuous Unit Rating (MW)	12 Months Ending March 2021 (%)	12 months ending March 2022 (%)	Historical Base Planning Assumption (%)	Historical Near-Term Planning Assumption (%)
Holyrood GT	123.5	7.21	0.00	5.00	5.00






Figure 4: Gas Turbine UFOP: Holyrood Unit

## 1 7.0 Gas Turbine DAUFOP Performance

2 The combined DAUFOP for the Hardwoods and Stephenville Gas Turbines was 1.40% for the 12-month  
 3 period ending March 31, 2022 (Table 8 and Figure 5). This is below the near-term planning assumption  
 4 of 30.00%. The Stephenville Gas Turbine DAUFOP for the current period is 1.31%, which is below the  
 5 near-term planning assumption of 30.00%. The Hardwoods Gas Turbine DAUFOP for the current period  
 6 is 1.42%, which is below the near-term planning assumption of 30.00%. On a per unit basis, this  
 7 indicates an improvement in performance over the 12-month period ending March 31, 2021 for both  
 8 units.

Table 8: Hardwoods/Stephenville Gas Turbine DAUFOP

Gas Turbine Units	Maximum Continuous Unit Rating (MW)	12 Months Ending March 2021 (%)	12 months ending March 2022 (%)	Historical Near-Term Planning Assumption (%)
<i>Gas Turbines (HWD/SVL)</i>	100	5.66	1.40	30.00
Stephenville	50	3.80	1.31	30.00
Hardwoods	50	6.37	1.42	30.00




Figure 5: Gas Turbine DAUFOP: Hardwoods/Stephenville Units

- 1 The DAUFOP for the Happy Valley Gas Turbine was 0.00% for the 12-month period ending March 31,
- 2 2022 (Table 9 and Figure 6). This is below the near-term planning assumption of 15.00%, and shows an
- 3 improvement in performance over the 12-month period ending March 31, 2021.

Table 9: Happy Valley Gas Turbine DAUFOP

Gas Turbine Units	Maximum Continuous Unit Rating (MW)	12 Months Ending March 2021 (%)	12 months ending March 2022 (%)	Historical Near-Term Planning Assumption (%)
Happy Valley	25	9.53	0.00	15.00




Figure 6: Gas Turbine DAUFOP: Happy Valley Unit

- 1 The Holyrood Gas Turbine DAUFOP of 0.00% for the current period is below the near-term planning
- 2 assumption of 5.00% (Table 10 and Figure 7) and has improved from the 12-month period ending
- 3 March 31, 2021.

Table 10: Holyrood Gas Turbine DAUFOP

Gas Turbine Units	Maximum Continuous Unit Rating (MW)	12 Months Ending March 2021 (%)	12 months ending March 2022 (%)	Historical Near-Term Planning Assumption (%)
Holyrood GT	123.5	7.21	0.00	5.00




Figure 7: Gas Turbine DAUFOP: Holyrood Unit

## 1 8.0 Updated Planning Assumptions/Analysis Values

2 As part of the Reliability and Resource Adequacy Study, Hydro detailed the process undertaken for  
 3 determining the forced outage rates most appropriate for use in its near-term reliability assessments  
 4 and long-term resource adequacy analysis. Table 11 summarizes the most recent forced outage rate  
 5 assumptions as calculated using the forced outage rate methodology.<sup>7</sup>

Table 11: Hydro’s Reliability and Resource Adequacy Study Analysis Values

Unit Type	Measure	Near-Term Analysis Value (%)	Resource Planning Analysis Value (%)
Hydraulic	DAFOR	2.6	2.1
Thermal	DAFOR	15.0	N/A
Gas Turbines	-	-	-
Happy Valley	DAUFOP	12.0	9.7
Hardwoods and Stephenville	DAUFOP	30.0	N/A
Holyrood	DAUFOP	4.9	1.7

<sup>7</sup> Values indicated for Hydro’s near-term analysis reflect those used in the “Reliability and Resource Adequacy Study 2020 Update: Volume II: Near-Term Reliability Report,” Newfoundland and Labrador Hydro, November 18, 2020.

1 A five-year, capacity-weighted average was applied to the hydroelectric units (Bay d’Espoir, Cat Arm,  
2 Hinds Lake, Granite Canal, Upper Salmon, and Paradise River) for the near-term analysis, resulting in a  
3 DAFOR of 2.6%,<sup>8</sup> while a ten-year, capacity-weighted average was applied for use in the resource  
4 planning model, resulting in a DAFOR of 2.1%. The DAFOR value was based on historical data reflective  
5 of Hydro’s maintenance program over the long term.

6 DAFORs of 15%, 18%, and 20% were applied to each of the units at the Holyrood TGS to determine the  
7 sensitivity of the system to Holyrood TGS availability in the near term. This is consistent with the May  
8 2018 “Near-Term Generation Adequacy Report.” As the Holyrood TGS units are being retired from  
9 generation mode in the near term, the units were not included in the long-term analysis; therefore,  
10 there is no resource planning analysis value listed for these units. For the total plant, an all units  
11 weighted value of 15% is used for the near term.

12 As the gas turbines in the existing fleet are in varied condition, each was considered on an individual  
13 basis rather than applying a weighted average across all units. For the Happy Valley Gas Turbine, a  
14 three-year, capacity-weighted average was applied to the unit for the near-term analysis, resulting in a  
15 DAUFOP of 12%, while a ten-year, capacity-weighted average was applied for use in the resource  
16 planning model resulting in a DAUFOP of 9.7%. The DAUFOP values were based on historical data  
17 founded upon the unit’s past reliable performance. For the Holyrood Gas Turbine, a scenario-based  
18 approach was used to estimate an appropriate value for the near-term analysis, resulting in a DAUFOP  
19 of 4.9%. For the Hardwoods and Stephenville Gas Turbines, a DAUFOP of 30% was used for the near-  
20 term analysis, consistent with the metrics that were considered in Hydro’s May 2018 “Near-Term  
21 Generation Adequacy Report.” As the Hardwoods and Stephenville Gas Turbines are being considered  
22 for retirement in the near term, these units were not included in the long-term analysis; therefore, there  
23 is no resource planning analysis value listed for these facilities.

---

<sup>8</sup> In its most recent Near-term Reliability Report, filed November 15, 2021, Hydro deviated from the FOR methodology as described when selecting FORs for its hydroelectric units as the result of the prescribed methodology did not accurately represent the risk of unit outage. For the hydroelectric units, Hydro maintained the capacity-weight average DAFOR from its Near-term Reliability Report filed in May 2021, which is higher than the 5-year DAFOR, increasing the FOR to more appropriately represent the risk of failure in the near term.

## 9.0 Comparison of Planning Assumptions and Analysis Values

As Hydro’s reliability and adequacy planning assumptions have historically been used in reporting on the performance of Hydro’s generating units, a comparison of the historical values to those used in the most recent analysis is provided in Table 12 for clarity.

Hydro notes that the Reliability and Resource Adequacy Study did not utilize UFOP in its analysis. The analysis instead utilized the DAUFOP measure with changes as shown in Table 12.

**Table 12: Comparison of Hydro’s Planning Assumptions (%)**

Generating Unit Type	Measure	Historical Planning Assumptions		Reliability and Resource Planning Assumptions	
		Historical Base Planning Assumption	Historical Near-Term Planning Assumption	Near-Term Analysis Value	Resource Planning Analysis Value
Hydraulic	DAFOR	0.9	2.6	2.6	2.1
Thermal	DAFOR	9.64	14.0	15.0	N/A
Gas Turbines					
Happy Valley	DAUFOP	-	15.0	12.0	9.7
Hardwoods and Stephenville	DAUFOP	-	30.0	30.0	N/A
Holyrood	DAUFOP	-	5.0	4.9	1.7

The generating unit performance presented earlier in this report is again presented in Tables 13 to 17 with comparison to the previous assumptions, as well as the recently revised values. Hydro notes that on an asset class basis, the 12-month rolling performance of its generating units has violations of Hydro’s current planning assumptions pertaining to asset availability for both Hydraulic and Thermal units. Details of what contributed to these violations are included in Sections 4.0 and 5.0 of this report.

Table 13: Hydraulic Weighted DAFOR Performance Comparison

Generating Unit	Maximum Continuous Unit Rating (MW)	12 months ending March 2021 (%)	12 months ending March 2022 (%)	May 2018		November 2020	
				Historic Base Planning Assumption (%)	Historic Near-Term Planning Assumption (%)	Near-Term Planning Analysis Value (%)	Resource Planning Analysis Value (%)
<b>All Hydraulic Units - weighted</b>	954.4	0.89	3.00	0.90	2.60	2.60	2.10
<b>Hydraulic Units</b>							
Bay D'Espoir 1	76.5	1.45	3.31	0.90	3.90	2.60	2.10
Bay D'Espoir 2	76.5	0.00	0.00	0.90	3.90	2.60	2.10
Bay D'Espoir 3	76.5	2.55	0.00	0.90	3.90	2.60	2.10
Bay D'Espoir 4	76.5	5.60	0.00	0.90	3.90	2.60	2.10
Bay D'Espoir 5	76.5	1.09	1.97	0.90	3.90	2.60	2.10
Bay D'Espoir 6	76.5	0.08	0.12	0.90	3.90	2.60	2.10
Bay D'Espoir 7	154.4	0.46	0.00	0.90	3.90	2.60	2.10
Cat Arm 1	67	0.15	1.44	0.90	0.70	2.60	2.10
Cat Arm 2	67	0.27	1.06	0.90	0.70	2.60	2.10
Hinds Lake	75	0.77	0.46	0.90	0.70	2.60	2.10
Upper Salmon	84	0.06	22.62	0.90	0.70	2.60	2.10
Granite Canal	40	2.22	0.57	0.90	0.70	2.60	2.10
Paradise River	8	1.31	1.15	0.90	0.70	2.60	2.10

Table 14: Thermal DAFOR Performance Comparison

Generating Unit	Maximum Continuous Unit Rating (MW)	12 months ending March 2021 (%)	12 months ending March 2022 (%)	May 2018		November 2020	
				Historic Base Planning Assumption (%)	Historic Near-Term Planning Assumption (%)	Near-Term Planning Analysis Value (%)	Resource Planning Analysis Value (%)
<b>All Thermal Units - weighted</b>	490	6.75	33.84	9.64	14.00	15.00	N/A
<b>Thermal Units</b>							
Holyrood 1	170	4.85	33.40	9.64	15.00	15.00	-
Holyrood 2	170	7.80	31.67	9.64	10.00	15.00	-
Holyrood 3	150	7.82	37.15	9.64	18.00	15.00	-

Table 15: Hardwoods/Stephenville Gas Turbine DAUFOP Performance Comparison

Gas Turbine Units	Maximum Continuous Unit Rating (MW)	12 months ending March 2021 (%)	12 months ending March 2022 (%)	May 2018		November 2020	
				Historic Base Planning Assumption (%)	Historic Near-Term Planning Assumption (%)	Near-Term Planning Analysis Value (%)	Resource Planning Analysis Value (%)
<b>Gas Turbines (HWD/SVL)</b>	100	5.66	1.40	N/A	30.00	30.00	N/A
Stephenville	50	3.80	1.31	N/A	30.00	30.00	N/A
Hardwoods	50	6.37	1.42	N/A	30.00	30.00	N/A

**Table 16: Happy Valley Gas Turbine DAUFOP Performance Comparison**

Gas Turbine Units	Maximum Continuous Unit Rating (MW)	12 months ending March 2021 (%)	12 months ending March 2022 (%)	May 2018		November 2020	
				Historic Base Planning Assumption (%)	Historic Near-Term Planning Assumption (%)	Near-Term Planning Analysis Value (%)	Resource Planning Analysis Value (%)
Happy Valley	25	9.53	0.00	N/A	15.00	12.00	9.70

**Table 17: Holyrood Gas Turbine DAUFOP Performance Comparison**

Gas Turbine Units	Maximum Continuous Unit Rating (MW)	12 months ending March 2021 (%)	12 months ending March 2022 (%)	May 2018		November 2020	
				Historic Base Planning Assumption (%)	Historic Near-Term Planning Assumption (%)	Near-Term Planning Analysis Value (%)	Resource Planning Analysis Value (%)
Holyrood GT	123.5	7.21	0.00	N/A	5.00	4.90	1.70