

February 1, 2021

The Board of Commissioners of Public Utilities
Prince Charles Building
120 Torbay Road, P.O. Box 21040
St. John's, NL A1A 5B2

Attention: Ms. Cheryl Blundon
Director Corporate Services & Board Secretary

Dear Ms. Blundon:

**Re: Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro –
2020 Annual Report**

Please find enclosed a copy of Newfoundland and Labrador Hydro's "Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report." The analysis contained within the enclosed report encompasses data from the period of January 1, 2020 to December 31, 2020.

If you have any questions or comments please contact the undersigned.

Yours truly,

NEWFOUNDLAND AND LABRADOR HYDRO



Shirley A. Walsh
Senior Legal Counsel, Regulatory
SAW/sk

ecc: **Board of Commissioners of Public Utilities**
Jacqui Glynn
PUB Official Email

Newfoundland Power
Gerard M. Hayes
Regulatory Email

Consumer Advocate
Dennis M. Browne, Q.C., Browne Fitzgerald Morgan & Avis
Stephen F. Fitzgerald, Browne Fitzgerald Morgan & Avis
Sarah G. Fitzgerald, Browne Fitzgerald Morgan & Avis
Bernice Bailey, Browne Fitzgerald Morgan & Avis

Industrial Customer Group
Paul L. Coxworthy, Stewart McKelvey
Denis J. Fleming, Cox & Palmer
Dean A. Porter, Poole Althouse

Ms. C. Blundon
Public Utilities Board

2

Teck Resources Limited
Shawn Kinsella

Praxair Canada Inc.
Sheryl E. Nisenbaum



Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report

February 1, 2021

A report to the Board of Commissioners of Public Utilities



Contents

1	Nostradamus Load Forecasting.....	1
1.1	Nostradamus.....	1
1.2	Short-Term Load Forecasting.....	1
1.2.1	Utility Load.....	1
1.2.2	Industrial Load.....	3
1.2.3	Supply and Demand Status Reporting.....	3
1.3	Potential Sources of Variance.....	4
2	Forecast Accuracy Summary.....	4
2.1	Analysis.....	4
2.2	Data Adjustments and Forecast Issues.....	5
2.3	Days of High Error.....	7
2.3.1	January 2, 2020 and January 3, 2020.....	7
2.3.2	January 6, 2020.....	8
2.3.3	February 2, 2020.....	9
2.3.4	February 15, 2020.....	10
2.3.5	February 26, 2020.....	10
2.3.6	March 9, 2020.....	11
2.3.7	March 18, 2020.....	12
2.3.8	March 23, 2020.....	13
2.3.9	April 2, 2020.....	13
2.3.10	April 14, 2020.....	14
2.3.11	April 19, 2020.....	15
2.3.12	May 1, 2020.....	16
2.3.13	May 12, 2020.....	16
2.3.14	May 24, 2020.....	17
2.3.15	June 5, 2020.....	18
2.3.16	June 12, 2020.....	18
2.3.17	June 29, 2020.....	19
2.3.18	July 8, 2020.....	20
2.3.19	July 18, 2020 and July 19, 2020.....	21

2.3.20	August 9, 2020	21
2.3.21	August 10, 2020	22
2.3.22	August 27, 2020	23
2.3.23	September 8, 2020.....	23
2.3.24	September 9, 2020.....	24
2.3.25	September 11, 2020.....	25
2.3.26	October 1, 2020	25
2.3.27	October 18, 2020	26
2.3.28	October 21, 2020	27
2.3.29	November 14, 2020	27
2.3.30	November 17, 2020	28
2.3.31	November 19, 2020	29
2.3.32	December 10, 2020.....	30
2.3.33	December 19, 2020.....	31
2.3.34	December 30, 2020.....	32
3	Forecast Accuracy Review.....	32

List of Appendices

Appendix A: Tables and Figures

1 Nostradamus Load Forecasting

1.1 Nostradamus

Newfoundland and Labrador Hydro (“Hydro”) uses software called Nostradamus¹ for short-term load forecasting with a time frame of seven days. The Nostradamus user guide provides the following description of the software, stating:

The Nostradamus Neural Network Forecasting system is a flexible neural network-based forecasting tool developed specifically for utility demand forecasting. Unlike conventional computing processes, which are programmed, neural networks use sophisticated mathematical techniques to train a network of inputs and outputs. Neural networks recognize and learn the joint relationships (linear or non-linear) between the ranges of variables considered. Once the network learns these intricate relationships, this knowledge can then easily be extended to produce accurate forecasts.²

The Nostradamus model is trained using a sequence of continuous historic periods of hourly weather and demand data. The model then forecasts system demand for a seven day horizon using predictions of weather parameters.

1.2 Short-Term Load Forecasting

Hydro uses its short-term load forecast to manage the power system and ensure adequate generating resources are available to meet customer demand.

1.2.1 Utility Load

Hydro has a contract with Wood PLC³ (“Wood”) to provide the weather parameters in the form of hourly weather forecasts that are provided twice daily for the proceeding seven days. At the same time as the weather forecast data are provided, Wood also provides recent observed data at the same locations as used in the forecasts.⁴ The actual and forecast data are automatically retrieved from Wood and input to the Nostradamus database.

Nostradamus can use a variety of weather parameters for forecasting, provided a sufficient historical record is available for training. Hydro currently uses air temperature, wind speed, and cloud cover.

Nostradamus can use each variable more than once, for example both the current and forecasted air

¹ The product is provided by Ventyx (an ABB Company).

² “Nostradamus User Guide,” Ventyx (an ABB Company), Release 8.2, EMDDB-0170-1405-06, May 2014.

³ Formerly Amec Foster Wheeler.

⁴ St. John’s, Gander, and Deer Lake.

1 temperatures are used in forecasting load. Wind chill is not explicitly used, as the neural network
2 function of Nostradamus forms its own relationships between load, wind, and temperature.

3 Nostradamus uses weather data for St. John's, Gander, and Deer Lake as well as a parameter that
4 indicates daily daylight hours. Training and verification⁵ periods are selected to provide a sufficiently
5 long period to ensure that a range of weather parameters are included (e.g., high and low temperatures)
6 but short enough that the historic load is still representative of loads that can be expected in the future.
7 Historically, data included in the training period has consisted of three years of training data compared
8 to up to one year of verification data. However, following this methodology would have resulted in
9 verifying data that includes the effects of the COVID-19 pandemic on the short-term load against a
10 training time period pre-pandemic. This would have resulted in a forecast that was unable to properly
11 map the inputs (i.e., the load affected by the pandemic) to the outputs (i.e., the new load forecast); thus
12 not improving the short-term forecast. To properly account for the effects of the pandemic on system
13 load⁶ and to improve the short-term forecast, Hydro worked with Nostradamus software support to
14 modify the defined period traditionally used in training. The result is a forecast that has been trained to
15 create a strong relationship between inputs and outputs, thus improving the short-term forecast during
16 the ongoing COVID-19 pandemic. The most recent training and validation exercises used data from
17 October 16, 2019 to October 31, 2020.

18 Demand data for the Island Interconnected System⁷ is automatically input to Nostradamus each hour.
19 Newfoundland Power and Hydro's total utility load (conforming)⁸ is input in the Nostradamus model.
20 Industrial load (non-conforming),⁹ which is not a function of weather, is forecast outside of the
21 Nostradamus program and added to the forecasts provided by Nostradamus to derive the total load
22 forecast.

⁵ Nostradamus will automatically perform verification over a designated historical time period upon completion of training. The verification period is used to evaluate the accuracy of the forecast using data that the model has not trained on. This ensures that the model is not memorizing the correct answer.

⁶ While the impacts of the pandemic on system load are not able to be fully quantified, the implementation of public health measures through the year may have contributed to increases in non-uniform customer behaviour that may have resulted in a small impact on the overall load and load shape.

⁷ Load forecasts for the Avalon Peninsula are still generated but are no longer a focus since the in-service of the third transmission line from Bay d'Espoir (TL 267).

⁸ Conforming load refers to load which changes consistently with the load pattern of an area.

⁹ Non-conforming load refers to load which changes abnormally with respect to the load pattern of an area.

1 The Nostradamus model creates separate sub-models for weekdays, weekends, and holidays during the
2 training process to account for the variation in customer use of electricity. Nostradamus has separate
3 holiday groups for statutory holidays and for days that are known to have unusual loads, for instance,
4 the days between Christmas and New Year’s Day, and schools’ Easter break.¹⁰

5 **1.2.2 Industrial Load**

6 Industrial load tends to be almost constant as industrial processes are independent of weather. Under
7 the current procedure, the Power on Order for each industrial customer plus the expected owned
8 generation from Corner Brook Pulp and Paper Limited (“CBPP”) are used as the industrial load forecasts.
9 Industrial customer loads can be modified based on some knowledge of customer loads, for instance, a
10 decrease in requirements due to reduced oil refining production at the North Atlantic Refinery in Come
11 by Chance¹¹ or a ramp up in the load expected at Vale Newfoundland and Labrador Limited. The
12 expected load can be modified in any given hour of the seven day forecast, or the default value can be
13 modified to be used indefinitely.¹²

14 **1.2.3 Supply and Demand Status Reporting**

15 Since December 2014, Hydro has submitted periodic reports on the accuracy of Nostradamus load
16 forecasting in relation to the Board of Commissioners of Public Utilities (“Board”) Investigation and
17 Hearing into Supply Issues and Power Outages on the Island Interconnected System. Direction from the
18 Board on January 18, 2018 indicated that the reporting frequency should change to annually
19 commencing in November 2018.¹³ The daily forecast peak, as of 7:20 a.m., is reported to the Board in
20 the daily Supply and Demand Status Report.

21 The weather forecast for the next seven days and the observed weather data for the previous day are
22 input into Nostradamus at approximately 5:00 a.m. and 2:00 p.m. Nostradamus is then run in every hour
23 of the day, and the outputted forecast is made available for reference in monitoring and managing both

¹⁰ Training the Nostradamus model is a process that is performed on an approximately annual basis. The goal is to improve the forecasting accuracy by providing Nostradamus with updated data and trends of recent loads and weather. This helps ensure that variables such as load growth and extreme weather are properly accounted for when predicting future load requirements.

¹¹ Approximately 28 MW was subtracted from the expected industrial customer load for April through December 2020 associated with the decrease in production at the North Atlantic refinery.

¹² In Hydro’s Energy Management System, there is functionality to modify the industrial load value when the Newfoundland and Labrador System Operator is aware of circumstances where an industrial customer will be reducing load. For example, if an industrial customer is completing maintenance, the forecast load can be modified to provide a more accurate load forecast.

¹³ On November 6, 2018, the Board accepted Hydro's request to change the annual filing date of this report to January 31 which allows the report to cover the previous calendar year.

1 available and spinning reserves. The within-day forecast updates are primarily used to manage operating
2 reserve, in particular in advance of the forecast system peaks.

3 **1.3 Potential Sources of Variance**

4 As with any forecasting analysis, there will be discrepancies between the forecasted and actual values.

5 Typical sources of variance in the load forecasting are as follows:

- 6 • Differences in the industrial load forecast due to unexpected changes in industrial customer
7 loads. For example, if an industrial customer were to undergo maintenance or increase
8 production to meet customer demand, the actual load would deviate from the scheduled load;
- 9 • Inaccuracies in the weather forecast, particularly temperature, wind speed, or cloud cover; and
- 10 • Non-uniform customer behaviour, which results in unpredictability. The impacts of the COVID-
11 19 pandemic on the load in 2020 can be considered non-uniform behaviour.

12 Occasional exports over the Maritime Link have occurred prior to 2020; however, export activity
13 materially increased this year. Decisions regarding exports during peak periods are carefully coordinated
14 and include conservative consideration of Hydro's native load forecast and available supply. The forecast
15 at peak as reported by 7:20 a.m. each day does not always account for exports as exports can be
16 contracted at any time throughout the day. As such, comparing a peak forecast for the day early each
17 morning against an actual peak that includes real-time exports has resulted in more days of high error as
18 a result of export activity over the Maritime Link.

19 **2 Forecast Accuracy Summary**

20 **2.1 Analysis**

21 This report examines the accuracy of the Hydro forecasting process for January 2020 through December
22 2020. All tables and figures referenced throughout the report are contained in Appendix A. Table 1
23 presents the daily forecast total peak, the actual total peak, and the available Island supply, as included
24 in Hydro's daily Supply and Demand Status Reports submitted to the Board. The data are also presented
25 in Figure 1(a) and (b).

26 The total peak load during the period varied between 590 MW (August 8, 2020) and 1,656 MW
27 (February 21, 2020). The available Island supply varied from 1,150 MW to 2,209 MW. Island
28 Interconnected System reserves were sufficient throughout the period.

1 Table 2 presents error statistics for the total peak forecasts for the forecast period. Figure 2 (a) and (b) is
2 a plot of the total forecast and actual total peaks, as shown in Figure 1, but with the addition of a bar
3 chart showing the difference between the two data series, in MW. In both the tables and the figures, a
4 positive error is an overestimate and a negative error is an underestimate.

5 Figure 2 reveals that the forecasting process consistently overestimates the peak of the total load. This is
6 typically a result of an overestimate in industrial load forecast, and/or export activity over the Maritime
7 Link.

8 Table 3 presents error statistics for the peak utility forecast (i.e., the portion of the forecast actually
9 determined by the Nostradamus model). Neither the industrial forecast nor the Maritime Link export
10 activity is included in the values presented in Table 3. Figure 3 (a) and (b) plots the data and error for the
11 utility peak. Examination of the utility forecast provides more insight into the accuracy of Nostradamus,
12 as error in the industrial forecast and export activity introduces error to the total forecast, making the
13 total forecast appear worse or, at times, better than it is.

14 **2.2 Data Adjustments and Forecast Issues**

15 In analysing the data there are instances that require adjustments for a variety of reasons. In these
16 instances, the data for affected hours is replaced using interpolation so that in the future, when the data
17 for this period is used in training, Nostradamus will use a value not affected by the event.

18 At midnight on January 1, 2020, Nostradamus stopped importing actual load data until January 3, 2020
19 due to some scheduled tasks deleting at the start of the New Year, resulting in a system error in the
20 executable file. The issue was corrected on January 3, 2020 and actual load data for that time period
21 was imported, correcting the load forecast going forward.

22 From January 2020 to April 2020, Nostradamus would infrequently forecast either a large increase or
23 decrease in load which was inconsistent with expectations based on system conditions. The error would
24 persist through weather forecast updates, pushing the erroneous value out by one hour at a time.

25 Meetings with Nostradamus support occurred on a number of occasions and the issue was permanently
26 fixed by manually running a forecast within the program. Nostradamus support concluded that the issue
27 was likely due to an error in the Nostradamus program and unrelated to Hydro's system or its usage of
28 the program. Another training exercise was completed in October 2020. Since then, the issue has not
29 occurred.

1 On January 6, 2020, Nostradamus stopped importing actual load data for eight hours due to a
2 calculation problem in Hydro’s database which caused an inaccurate load forecast. The calculation error
3 was corrected and the erroneous data was replaced with the last accurate forecast values so that in the
4 future, when the data during this period is used for training, Nostradamus will use a value that is not
5 affected by the erroneous data.

6 Between 2:35 p.m. and 5:04 p.m. on September 9, 2020, the Upper Salmon unit was offline; however,
7 the Supervisor Control and Data Acquisition (“SCADA”) data indicated the unit output was -60 MW. This
8 resulted in a reduction in Island load values by 60 MW for those hours. To correct the actual values, 60
9 MW was added to the Island load from 3:00 p.m. through 5:00 p.m. to offset the erroneous unit output
10 data.

11 On October 20, 2020, a SCADA system upgrade took place and, as a result, erroneous and/or missing
12 actual load values from October 20, 2020 to October 22, 2020 occurred in the development version of
13 Nostradamus. Actual load data was taken from the production version to replace the incorrect values
14 for the affected hours; however, small errors remained in the actual load data in the production system.
15 This issue did not impact the production version of Nostradamus as severely; therefore, the impact to
16 the load forecast used by the Newfoundland and Labrador System Operator (“NLSO”) was minimal.

17 From October 27, 2020 to October 28, 2020 some actual load data was missing from the development
18 version of Nostradamus for an unknown reason. Correct actual load data was taken from the production
19 version to replace the missing data for the affected hours. This did not impact the production version;
20 therefore, there was no impact to the load forecast as used by the NLSO. The correction was made for
21 training purposes only.

22 On November 26, 2020, Bay d’Espoir Unit 7 was offline for a planned outage; however, for less than an
23 hour, SCADA data indicated the unit was online at 134 MW. Therefore, 134 MW was removed from the
24 Island load values to offset the erroneous unit output data.

25 On December 9, 2020, the Labrador-Island Link (“LIL”) came online at 8:33 a.m. at 45 MW; however, the
26 data point measured at Soldiers Pond did not update until 10:00 a.m. and appeared as a load loss on the
27 system. Therefore, 45 MW was added to the island generation values to reflect the LIL deliveries.

1 **2.3 Days of High Error¹⁴**

2 The bolded dates in Tables 2 and 3 indicate the days of high error in the load forecast. The days with the
3 highest error (up to three days per month) are selected for more detailed analysis, which includes the
4 days of:

- 5 • January 2, 3, and 6, 2020;
- 6 • February 2, 15, and 26, 2020;
- 7 • March 9, 18, and 23, 2020;
- 8 • April 2, 14, and 19, 2020;
- 9 • May 1, 12, and 24, 2020;
- 10 • June 5, 12, and 29, 2020;
- 11 • July 8, 18, and 19, 2020;
- 12 • August 9, 10, and 27, 2020;
- 13 • September 8, 9, and 11, 2020;
- 14 • October 1, 18, and 21, 2020;
- 15 • November 14, 17, and 19, 2020; and
- 16 • December 10, 19, and 30, 2020.

17 **2.3.1 January 2, 2020 and January 3, 2020**

18 As noted in Section 2.2, on December 31, 2019 at midnight, Nostradamus stopped importing actual load
19 data until January 3, 2020 due to some scheduled tasks deleting at the start of the New Year, resulting in
20 a system error in the executable file. This error resulted in the forecast not updating properly during
21 those days. The issue was corrected and actual load data for that time period was imported, correcting
22 the load forecast going forward.

23 On January 2, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,135 MW; the actual
24 reported peak was 1,282 MW. The absolute difference was 147 MW, 11.5% of the actual peak. Figure 4

¹⁴ All plots showing the hourly distribution of the load forecast compared to the actual total load do not include Maritime Link export activity to aid in determining other sources of differences between actual and forecast loads.

1 includes an hourly plot of the load forecast and the actual load for January 2, 2020 to observe the
2 differences between actual and forecast loads.

3 Figure 4(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
4 forecast predicted a 6:00 p.m. peak of 1,134 MW; the actual peak was 1,279 MW¹⁵ and it occurred at
5 5:00 p.m. The total load forecast at the time was 844 MW, resulting in an underestimation of 34.0%.

6 On January 3, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,165 MW; the actual
7 reported peak was 1,295 MW. The absolute difference was 130 MW, 10.0% of the actual peak. Figure 5
8 includes an hourly plot of the load forecast and the actual load for January 3, 2020 to observe the
9 differences between actual and forecast loads.

10 Figure 5(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
11 forecast predicted a 6:00 p.m. peak of 1,165 MW; the actual peak was 1,289 MW and it occurred at 5:00
12 p.m. The total load forecast at the time was 813 MW, resulting in an underestimation of 36.9%.

13 Figures 4(b), (c), (d), and (e) and Figures 5(b), (c), (d), and (e) are provided for context; however, the
14 discrepancy between actual and forecast load for January 2, 2020 and January 3, 2020 was due to the
15 executable file not running, negatively impacting the program's ability to provide an accurate forecast.
16 The forecast improved on January 3, 2020 at 10:20 a.m. after the scheduled tasks were corrected and
17 the executable file ran.

18 **2.3.2 January 6, 2020**

19 On January 6, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,475 MW; the actual
20 reported peak was 1,373 MW. The absolute difference was 102 MW, 7.4% of the actual peak. Figure 6
21 includes an hourly plot of the load forecast for January 6, 2020, as well as actual load chart to assist in
22 determining the sources of the differences between actual and forecast loads.

23 Figure 6(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
24 forecast predicted a 5:00 p.m. peak of 1,473 MW; the actual peak was 1,370 MW and occurred at 5:00
25 p.m.

¹⁵ The actual total peak reported in the daily Supply and Demand Status Reports is based on a five minute time step; however, Nostradamus reports on an hourly time step, sometimes resulting in a different peak value.

1 Figure 6(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
2 industrial component removed). The error in the forecast of the utility load was significantly lower than
3 the error in the forecast of total load, meaning that the error in the industrial load forecast contributed
4 to the error in the total load forecast. The hourly forecast predicted a utility peak at 5:00 p.m. of 1,314
5 MW; the actual peak was 1,280 MW and occurred at 5:00 p.m.

6 Figures 6(c), (d), and (e) are provided for context; however, the discrepancy between actual and forecast
7 load for January 6, 2020 was primarily a result of error in the industrial load forecast contributing to
8 error in the total load forecast. An overestimation of the load results in more than enough reserve being
9 available.

10 **2.3.3 February 2, 2020**

11 On February 2, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,420 MW; the actual
12 reported peak was 1,498 MW. The absolute difference was 78 MW, 5.2% of the actual peak. Figure 7
13 includes an hourly plot of the load forecast for February 2, 2020, as well as actual load chart to assist in
14 determining the sources of the differences between actual and forecast loads.

15 Figure 7(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
16 forecast predicted a 10:00 a.m. peak of 1,418 MW; the actual peak was 1,495 MW and occurred at
17 12:00 p.m. The total load forecast at the time was 1,378 MW resulting in an underestimate of 7.8%.

18 Figure 7(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
19 industrial component removed). The error in the forecast of the utility load was higher than the error in
20 the forecast of total load, meaning that error in the industrial load forecast did not contribute to the
21 error in the total load forecast. The hourly forecast predicted a utility peak at 10:00 a.m. of 1,226 MW;
22 the actual peak was 1,343 MW and occurred at 12:00 p.m.

23 Figure 7(c) shows the actual temperature in St. John's compared to the forecast. The forecast was fairly
24 aligned with the actual temperature until 8:00 a.m., when it was approximately 1°C cooler than forecast
25 for the remainder of the day. This variation could have contributed to the underestimation of load
26 forecast at peak.

27 Figure 7(d) shows the actual wind speed in St. John's compared to the forecast. The forecast wind speed
28 was underestimated during daylight hours until 2:00 p.m., when lower winds than forecast occurred.

1 This could have also contributed to the underestimation of load forecast at peak. Figure 7(e) shows the
2 actual cloud cover in St. John's compared to the forecast. Cloud cover was accurate during daylight
3 hours.

4 The discrepancy between actual and forecast load for February 2, 2020 was likely a result of error in the
5 temperature, wind speed forecast, and non-uniform customer behaviour, as this day occurred during a
6 weekend. The forecast improved by 6:00 p.m. for the remainder of the day.

7 **2.3.4 February 15, 2020**

8 On February 15, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,665 MW; the
9 actual reported peak was 1,529 MW. The absolute difference was 136 MW, 8.9% of the actual peak.
10 Figure 8 includes an hourly plot of the load forecast for February 15, 2020 as well as several plots to
11 assist in determining the sources of the differences between actual and forecast loads.

12 Figure 8(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
13 forecast predicted a 9:00 a.m. peak of 1,666 MW; the actual peak was 1,523 MW and occurred 8:00 a.m.
14 The total load forecast at the time was 1,646 MW resulting in an overestimate of 8.1%.

15 Figure 8(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
16 industrial component removed). The error in the forecast of the utility load was significantly lower than
17 the error in the forecast of total load, meaning that error in the industrial load forecast contributed to
18 the error in the total load forecast. The hourly forecast predicted a utility peak at 9:00 a.m. of 1,474
19 MW; the actual peak was 1,437 MW and occurred at 8:00 a.m.

20 Figures 8(c), (d), and (e) are provided for context; however, the discrepancy between actual and forecast
21 load for February 15, 2020 was primarily a result of error in industrial load forecast contributing to error
22 in the total load forecast as well as non uniform customer behaviour, as this day occurred during a
23 weekend. An overestimate of the load results in more than enough reserve being available. The forecast
24 improved by 2:00 p.m.

25 **2.3.5 February 26, 2020**

26 On February 26, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,330 MW; the
27 actual reported peak was 1,246 MW. The absolute difference was 84 MW, 6.7% of the actual peak.

1 Figure 9 includes an hourly plot of the load forecast for February 26, 2020 as well as actual load chart to
2 assist in determining the sources of the differences between actual and forecast loads.

3 Figure 9(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
4 forecast predicted a 10:00 a.m. peak of 1,328 MW; the actual peak was 1,246 MW and occurred at 8:00
5 a.m. The total load forecast at the time was 1,291 MW, resulting in an overestimate of 3.6%. After the
6 morning peak occurred at 8:00 a.m., there was a discrepancy between actual and forecast utility load
7 due to an error in the Nostradamus program.¹⁶ A manual forecast was run and the forecast was
8 corrected in advance of the evening peak.

9 Figure 9(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
10 industrial component removed). The error in the forecast of the utility load was lower than the error in
11 the forecast of total load, meaning that error in the industrial load forecast contributed to the error in
12 the total load forecast. The hourly forecast predicted a utility peak at 10:00 a.m. of 1,142 MW; the
13 actual peak was 1,092 MW and occurred at 8:00 a.m.

14 Figures 9(c), (d), and (e) are provided for context; however, the discrepancy between actual and forecast
15 load for February 26, 2020 was primarily a result of error in the Nostradamus program as well as error in
16 industrial load forecast contributing to error in the total load forecast. An overestimate of the load
17 results in more than enough reserve being available. The forecast improved by 6:00 p.m.

18 **2.3.6 March 9, 2020**

19 On March 9, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,590 MW; the actual
20 reported peak was 1,465 MW. The absolute difference was 125 MW, 8.5% of the actual peak. Figure 10
21 includes an hourly plot of the load forecast for March 9, 2020, as well as several plots to assist in
22 determining the sources of the differences between actual and forecast loads.

23 Figure 10(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
24 forecast predicted a 12:00 p.m. peak of 1,589 MW; the actual peak was 1,462 MW and it occurred at
25 9:00 p.m. The total load forecast at the time was 1,571 MW, resulting in an overestimate of 7.5%.

¹⁶ This error was discussed in detail in Section 2.2 Data Adjustments and Forecast Issues.

1 Figure 10(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
2 industrial component removed). The error in the forecast of the utility load was slightly lower than the
3 error in the forecast of total load, meaning that error in the industrial load forecast contributed to the
4 error in the total load forecast. The hourly forecast predicted a utility peak at 12:00 p.m. of 1,402 MW;
5 the actual peak was 1,311 MW and occurred at 9:00 p.m.

6 Figures 10(c), (d), and (e) are provided for context; however, the discrepancy between actual and
7 forecast load for March 9, 2020 was primarily a result of Nostradamus incorrectly forecasting a large
8 increase in load. The issue was corrected within Nostradamus by manually running a new forecast. The
9 new forecast predicted an overestimation of the utility load at peak by only 14.6 MW. The total load
10 forecast at peak was overestimated by 50.3 MW, indicating that error in industrial load forecast
11 contributing to error in the total load forecast. An overestimate of the load results in more than enough
12 reserve being available.

13 **2.3.7 March 18, 2020**

14 On March 18, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,375 MW; the actual
15 reported peak was 1,302 MW. The absolute difference was 73 MW, 5.6% of the actual peak. Figure 11
16 includes an hourly plot of the load forecast for March 18, 2020, as well as actual load chart to assist in
17 determining the sources of the differences between actual and forecast loads.

18 Figure 11(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
19 forecast predicted a 10:00 a.m. peak of 1,374 MW; the actual peak was 1,298 MW and it occurred at
20 9:00 a.m. The total load forecast at the time was 1,372 MW, resulting in an overestimate of 5.7%. The
21 forecast improved in the afternoon, but deviated again in the evening.

22 Figure 11(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
23 industrial component removed). The error in the forecast of the utility load was significantly lower than
24 the error in the forecast of total load, meaning that error in the industrial load forecast contributed to
25 the error in the total load forecast. The hourly forecast predicted a utility peak at 10:00 a.m. of 1,188
26 MW; the actual peak was 1,155 MW and occurred at 9:00 a.m.

27 Figures 11(c), (d), and (e) are provided for context; however, the discrepancy between actual and
28 forecast load for March 18, 2020 was primarily a result of error in industrial load forecast contributing to

1 error in the total load forecast. An overestimate of the load results in more than enough reserve being
2 available.

3 **2.3.8 March 23, 2020**

4 On March 23, 2020, the forecast peak at 6:20 a.m.,¹⁷ as reported to the Board, was 1,515 MW; the
5 actual reported peak was 1,437 MW. The absolute difference was 78 MW, 5.4% of the actual peak.
6 Figure 12 includes an hourly plot of the load forecast for March 23, 2020, as well as actual load chart to
7 assist in determining the sources of the differences between actual and forecast loads.

8 Figure 12(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
9 forecast predicted an 8:00 a.m. peak of 1,468 MW; the actual peak of 1,436 MW occurred at 8:00 a.m.

10 Figure 12(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
11 industrial component removed). The error in the forecast of the utility load was lower than the error in
12 the forecast of total load, meaning that error in the industrial load forecast contributed to the error in
13 the total load forecast. The hourly forecast predicted a utility peak at 8:00 a.m. of 1,281 MW; the actual
14 peak was 1,270 MW.

15 Figures 12(c), (d), and (e) are provided for context; however, the discrepancy between actual and
16 forecast load for March 23, 2020 was primarily a result of the load forecast not updating between 6:20
17 a.m. and 9:44 a.m. Once the forecast was corrected and updated, the load forecast for the remainder of
18 the day was accurate.

19 **2.3.9 April 2, 2020**

20 On April 2, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,115 MW; the actual
21 reported peak was 1,032 MW. The absolute difference was 83 MW, 8.0% of the actual peak. Figure 13
22 includes an hourly plot of the load forecast for April 2, 2020, as well as actual load chart to assist in
23 determining the sources of the differences between actual and forecast loads.

24 Figure 13(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
25 forecast predicted a 9:00 a.m. peak of 1,116 MW; the actual peak of 1,031 MW occurred at 8:00 a.m.

¹⁷ The forecast wasn't available between 6:20 a.m. and 9:44 a.m.; therefore, the forecast peak at 7:20 a.m. could not be provided.

1 Figure 13(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
2 industrial component removed). The error in the forecast of the utility load was negligible. The hourly
3 forecast predicted a utility peak at 8:00 a.m. of 954 MW; the actual peak was 946 MW and occurred at
4 8:00 a.m.

5 Figures 13(c), (d), and (e) are provided for context; however, the discrepancy between actual and
6 forecast load for April 2, 2020 was primarily a result of error in industrial load forecast contributing to
7 error in the total load forecast. An overestimate of the load results in more than enough reserve being
8 available. The forecast did not improve throughout the day.

9 **2.3.10 April 14, 2020**

10 On April 14, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,130 MW; the actual
11 reported peak was 1,018 MW. The absolute difference was 112 MW, 11.0% of the actual peak. Figure 14
12 includes an hourly plot of the load forecast for April 14, 2020, as well as actual load chart to assist in
13 determining the sources of the differences between actual and forecast loads.

14 Figure 14(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
15 forecast predicted an 11:00 a.m. peak of 1,131 MW; the actual peak was 1,017 MW and occurred at
16 12:00 p.m. The total load forecast at the time was 1,129 MW, resulting in an overestimate of 11.0%.

17 Figure 14(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
18 industrial component removed). The error in the forecast of the utility load was lower than the error in
19 the forecast of total load at peak, suggesting that industrial load forecast contributed to the error in the
20 total load forecast. The hourly forecast predicted a utility peak at 11:00 a.m. of 968 MW; the actual peak
21 was 889 MW and occurred at 12:00 p.m.

22 Figure 14(c) shows the actual temperature in St. John's compared to the forecast. The temperature
23 forecast was underestimated during daylight hours, being 4 °C warmer than forecast at peak. This could
24 have contributed to the load forecast error at peak.

25 Figure 14(d) shows the actual wind speed in St. John's compared to the forecast. The actual wind speed
26 was relatively consistent with the forecast wind speed for the entire day. Figure 14(e) shows the actual
27 cloud cover in St. John's compared to the forecast. During daylight hours the forecast was accurate.

1 The discrepancy between actual and forecast load for April 14, 2020 was likely a combination of error in
2 industrial load forecast contributing to error in the total load forecast and error in the temperature
3 forecast resulting in the overestimation of the load forecast. In addition, non-uniform customer
4 behaviour could have contributed to the error as this day occurred during the week of Easter break. An
5 overestimate of the load results in more than enough reserve being available. Updates improved the
6 forecast by 5:00 p.m.

7 **2.3.11 April 19, 2020**

8 On April 19, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,220 MW; the actual
9 reported peak was 1,317 MW. The absolute difference was 97 MW, 7.4% of the actual peak. Figure 15
10 includes an hourly plot of the load forecast for April 19, 2020, as well as actual load chart to assist in
11 determining the sources of the differences between actual and forecast loads.

12 Figure 15(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
13 forecast predicted a 12:00 p.m. peak of 1,221 MW; the actual peak was 1,300 MW and occurred at 5:00
14 p.m. The total load forecast at the time was 1,216 MW, resulting in an underestimate of 6.5%.

15 Figure 15(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
16 industrial component removed). The error in the forecast of the utility load was slightly higher than the
17 error in the forecast of total load, suggesting that industrial load forecast did not contribute to the error
18 in the total load forecast. The hourly forecast predicted a utility peak at 12:00 p.m. of 1,058 MW; the
19 actual peak was 1,161 MW and occurred at 5:00 p.m.

20 Figure 15(c) shows the actual temperature in St. John's compared to the forecast. The temperature was
21 relatively accurate during daylight hours. This would not have contributed to the load forecast error.

22 Figure 15(d) shows the actual wind speed in St. John's compared to the forecast. Through the entire day
23 the actual wind speed was slightly lower than forecast, but this would not contribute to the forecast
24 error. Figure 15(e) shows the actual cloud cover in St. John's compared to the forecast. Cloud cover was
25 accurate during daylight hours.

26 The discrepancy between actual and forecast load for April 19, 2020 was likely due to non-uniform
27 customer behaviour as this day occurred during the week of Easter break, as well as on a weekend,
28 which resulted in the underestimated load forecast at peak. Updates improved the forecast by 8:00 p.m.

1 **2.3.12 May 1, 2020**

2 On May 1, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 960 MW; the actual
3 reported peak was 871 MW. The absolute difference was 89 MW, 10.2% of the actual peak. Figure 16
4 includes an hourly plot of the load forecast for May 1, 2020, as well as several plots to assist in
5 determining the sources of the differences between actual and forecast loads.

6 Figure 16(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
7 forecast predicted a 9:00 a.m. peak of 962 MW; the actual peak was 862 MW and occurred at 8:00 a.m.
8 The total load forecast at the time was 952 MW, resulting in an overestimate of 10.4%.

9 Figure 16(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
10 industrial component removed). The error in the forecast of the utility load was negligible compared to
11 the error in the forecast of total load, meaning that error in the industrial load forecast contributed to
12 the error in the total load forecast. The hourly forecast predicted a utility peak at 9:00 a.m. of 800 MW;
13 the actual peak was 781 MW and occurred at 8:00 a.m.

14 Figures 16(c), (d), and (e) are provided for context; however, the discrepancy between actual and
15 forecast load for May 1, 2020 was primarily a result of error in industrial load forecast contributing to
16 error in the total load forecast. An overestimate of the load results in more than enough reserve being
17 available. The forecast did not improve throughout the day.

18 **2.3.13 May 12, 2020**

19 On May 12, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1000 MW; the actual
20 reported peak was 1070 MW. The peak of 1070 MW, as reported to the Board, includes a Maritime Link
21 export of approximately 53 MW, which occurred from 3:00 p.m. until 6:00 p.m. The absolute difference,
22 inclusive of export, was 70 MW, 6.5% of the actual peak. Figure 17 includes an hourly plot of the load
23 forecast for May 12, 2020, as well as several plots to assist in determining the sources of the differences
24 between actual and forecast loads.

25 Figure 17(a) shows the hourly distribution of the load forecast compared to the actual load, exclusive of
26 export activity. The hourly forecast predicted a 9:00 a.m. peak of 1,000 MW; the actual peak was 1,013
27 MW and occurred at 5:00 p.m. At approximately 10:00 a.m. a discrepancy between actual and forecast

1 utility load occurred due to an error in the Nostradamus program.¹⁸ A manual forecast was run and the
2 forecast was corrected in advance of the evening peak.

3 Figure 17(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
4 industrial and export components removed). The error in the forecast of the utility load was higher than
5 the error in the forecast of total load, meaning that error in the industrial load forecast did not
6 contribute to the error in the total load forecast. The hourly forecast predicted a utility peak at 9:00 a.m.
7 of 838 MW; the actual peak was 906 MW and occurred at 5:00 p.m.

8 Figures 17(c), (d), and (e) are provided for context; however, the discrepancy between actual and
9 forecast load was primarily attributable to error in the Nostradamus program as well as export activity
10 over the Maritime Link.

11 **2.3.14 May 24, 2020**

12 On May 24, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 965 MW; the actual
13 reported peak was 854 MW. The absolute difference was 111 MW, 13.0% of the actual peak. Figure 18
14 includes an hourly plot of the load forecast for May 24, 2020, as well as several plots to assist in
15 determining the sources of the differences between actual and forecast loads.

16 Figure 18(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
17 forecast predicted a 12:00 p.m. peak of 964 MW; the actual peak was 848 MW and occurred at 11:00
18 a.m. The total load forecast at the time was 960 MW, resulting in an overestimate of 13.2%.

19 Figure 18(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
20 industrial component removed). The error in the forecast of the utility load was lower than the error in
21 the forecast of total load, meaning that error in the industrial load forecast contributed to the error in
22 the total load forecast. The hourly forecast predicted a utility peak at 12:00 p.m. of 801 MW; the actual
23 peak was 727 MW and occurred at 10:00 a.m.

24 Figures 18(c), (d), and (e) are provided for context; however, the discrepancy between actual and
25 forecast load was primarily attributable to a combination of error in industrial load forecast contributing
26 to error in the total load forecast as well as non-uniform customer behaviour as this day occurred on a

¹⁸ This error was discussed in detail in Section 2.2 Data Adjustments and Forecast Issues.

1 weekend before the Victoria Day holiday. An overestimate of the load results in more than enough
2 reserve being available. The accuracy of the forecast did not improve through the day.

3 **2.3.15 June 5, 2020**

4 On June 5, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 820 MW; the actual
5 reported peak was 767 MW. The peak of 767 MW, as reported to the Board, includes a Maritime Link
6 export of approximately 42 MW. Exports occurred through the day, with a maximum export of 54 MW.
7 The absolute difference, inclusive of export, was 53 MW, 6.9% of the actual peak. Figure 19 includes an
8 hourly plot of the load forecast for June 5, 2020, as well as several plots to assist in determining the
9 sources of the differences between actual and forecast loads.

10 Figure 19(a) shows the hourly distribution of the load forecast compared to the actual load, exclusive of
11 export activity. The hourly forecast predicted a 12:00 p.m. peak of 778 MW; the actual peak was 723
12 MW and occurred at 10:00 a.m. The total load forecast at the time was 769 MW, resulting in an
13 overestimate of 6.4%.

14 Figure 19(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
15 industrial and export components removed). The error in the forecast of the utility load was negligible
16 compared to the error in the forecast of total load, meaning that error in the industrial load forecast
17 contributed significantly to the error in the total load forecast in addition to export activity. The hourly
18 forecast predicted a utility peak at 12:00 p.m. of 616 MW; the actual peak was 608 MW and occurred at
19 10:00 a.m.

20 Figures 19(c), (d), and (e) are provided for context; however, the discrepancy between actual and
21 forecast load was primarily attributable to export activity over the Maritime Link and error in the
22 industrial load forecast. An overestimation of the load results in more than enough reserve being
23 available.

24 **2.3.16 June 12, 2020**

25 On June 12, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 840 MW; the actual
26 reported peak was 726 MW. The peak of 726 MW, as reported to the Board, includes a Maritime Link
27 export of 22 MW. Exports occurred from 8:00 a.m. until midnight, with a maximum export of 48 MW.
28 The absolute difference, inclusive of exports, was 114 MW, 15.7% of the actual peak. Figure 20 includes

1 an hourly plot of the load forecast for June 12, 2020, as well as several plots to assist in determining the
2 sources of the differences between actual and forecast loads.

3 Figure 20(a) shows the hourly distribution of the load forecast compared to the actual load, exclusive of
4 export activity. The hourly forecast predicted a 10:00 a.m. peak of 817 MW; the actual peak was 692
5 MW and occurred at 10:00 a.m.

6 Figure 20(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
7 industrial and export components removed). Excluding export activity during peak, the error in the
8 forecast of the utility load was significantly lower than the error in the forecast of total load, meaning
9 that error in the industrial load forecast contributed to the error in the total load forecast in addition to
10 export activity. The hourly forecast predicted a utility peak at 10:00 a.m. of 655 MW; the actual peak
11 was 627 MW and occurred at 10:00 a.m.

12 Figures 20(c), (d), and (e) are provided for context; however, the discrepancy between actual and
13 forecast load was a combination of error in industrial load forecast contributing to error in the total load
14 forecast as well as export activity over the Maritime Link. An overestimation of the load results in more
15 than enough reserve being available.

16 **2.3.17 June 29, 2020**

17 On June 29, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 835 MW; the actual
18 reported peak was 750 MW. The peak of 750 MW, as reported to the Board, includes a Maritime Link
19 export of 54 MW, which occurred from 8:00 a.m. until 11:00 p.m. The absolute difference, inclusive of
20 the export, was 85 MW, 11.3% of the actual peak. Figure 21 includes an hourly plot of the load forecast
21 for June 29, 2020, as well as several plots to assist in determining the sources of the differences
22 between actual and forecast loads.

23 Figure 21(a) shows the hourly distribution of the load forecast compared to the actual load, exclusive of
24 export activity. The hourly forecast predicted a 5:00 p.m. peak of 751 MW; the actual peak was 694 MW
25 and occurred at 5:00 p.m.

26 Figure 21(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
27 industrial and export components removed). Excluding export activity at peak, the error in the forecast
28 of the utility load was negligible, meaning that error in the industrial load forecast contributed to the

1 error in the total load forecast in addition to export activity. The hourly forecast predicted a utility peak
2 at 5:00 p.m. of 589 MW; the actual peak was 592 MW and occurred at 12:00 p.m.

3 Figures 21(c), (d), and (e) are provided for context; however, the discrepancy between actual and
4 forecast load was a combination of error in industrial load forecast contributing to error in the total load
5 forecast as well as export activity over the Maritime Link. An overestimation of the load results in more
6 than enough reserve being available.

7 **2.3.18 July 8, 2020**

8 On July 8, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 745 MW; the actual
9 reported peak was 669 MW. The absolute difference was 76 MW, 11.4% of the actual peak. Figure 22
10 includes an hourly plot of the load forecast for July 8, 2020, as well as several plots to assist in
11 determining the sources of the differences between actual and forecast loads.

12 Figure 22(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
13 forecast predicted a 12:00 p.m. peak of 744 MW; the actual peak was 668 MW and occurred at 12:00
14 p.m.

15 Figure 22(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
16 industrial component removed). The error in the forecast of the utility load was negligible, meaning that
17 error in the industrial load forecast materially contributed to the error in the total load forecast. The
18 hourly forecast predicted a utility peak at 12:00 p.m. of 582 MW; the actual peak was 573 MW and
19 occurred at 12:00 p.m.

20 Figures 22(c), (d), and (e) are provided for context; however, the discrepancy between actual and
21 forecast utility load for July 8, 2020 was primarily due to the errors in industrial load forecast.

22 Discrepancy in weather is not expected to have impacted the total actual load during the summer
23 season. The forecast did not improve through the day. An overestimate of the load results in more than
24 enough reserve being available.

1 **2.3.19 July 18, 2020 and July 19, 2020**

2 On July 18, 2020, the forecast peak at 6:20 a.m.,¹⁹ as reported to the Board, was 740 MW; the actual
3 reported peak was 677 MW. The absolute difference was 63 MW, 9.3% of the actual peak. Figure 23
4 includes an hourly plot of the load forecast for July 18, 2020, as well as several plots to assist in
5 determining the sources of the differences between actual and forecast loads.

6 Figure 23(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
7 forecast predicted a 12:00 p.m. peak of 739 MW; the actual peak was 677 MW and occurred at 10:00
8 a.m. The total load forecast at the time was 717 MW, resulting in an overestimate of 5.9%.

9 On July 19, 2020, the forecast peak at 7:20 a.m.,²⁰ as reported to the Board, was 730 MW; the actual
10 reported peak was 651 MW. The absolute difference was 79 MW, 12.1% of the actual peak. Figure 24
11 includes an hourly plot of the load forecast for July 19, 2020, as well as several plots to assist in
12 determining the sources of the differences between actual and forecast loads.

13 Figure 24(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
14 forecast predicted a 12:00 p.m. peak of 728 MW; the actual peak was 642 MW and occurred at 5:00
15 p.m. The total load forecast at the time was 688 MW, resulting in an overestimate of 7.0%.

16 Figures 23(b), (c), (d), and (e) and Figures 24(b), (c), (d), and (e) are provided for context; however, the
17 discrepancy between actual and forecast utility load for both July 18, 2020 and July 19, 2020 was
18 primarily a result of the load forecast not updating after 6:20 a.m. on July 18, 2020. Discrepancy in
19 weather against forecast is not expected to have impacted the total actual load during the summer
20 season. The forecast improved on July 20, 2020 at 8:40 a.m. after the forecast was corrected.

21 **2.3.20 August 9, 2020**

22 On August 9, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 700 MW; the actual
23 reported peak was 606 MW. The absolute difference was 94 MW, 15.5% of the actual peak. Figure 25
24 includes an hourly plot of the load forecast for August 9, 2020, as well as several plots to assist in
25 determining the sources of the differences between actual and forecast loads.

¹⁹ The forecast wasn't available after 6:20 a.m. for the remainder of the day, therefore the forecast peak at 7:20 a.m. could not be provided.

²⁰ The last forecast update had occurred on July 18, 2020 at 6:20 a.m.

1 Figure 25(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
2 forecast predicted a 12:00 p.m. peak of 698 MW; the actual peak was 605 MW and occurred at 12:00
3 p.m.

4 Figure 25(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
5 industrial component removed). The error in the forecast of the utility load was negligible, meaning that
6 error in the industrial load forecast materially contributed to the error in the total load forecast. The
7 hourly forecast predicted a utility peak at 12:00 p.m. of 536 MW; the actual peak was 548 MW and
8 occurred at 12:00 p.m.

9 Figures 25(c), (d), and (e) are provided for context; however, the discrepancy between actual and
10 forecast utility load for August 9, 2020 was primarily due to error in the industrial load forecast.
11 Discrepancy in weather is not expected to have impacted the total actual load during the summer
12 season. The forecast remained poor through the day. An overestimate of the load results in more than
13 enough reserve being available.

14 **2.3.21 August 10, 2020**

15 On August 10, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 755 MW; the actual
16 reported peak was 669 MW. The absolute difference was 86 MW, 12.9% of the actual peak. Figure 26
17 includes an hourly plot of the load forecast for August 10, 2020, as well as several plots to assist in
18 determining the sources of the differences between actual and forecast loads.

19 Figure 26(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
20 forecast predicted a 12:00 p.m. peak of 753 MW; the actual peak was 665 MW and occurred at 5:00
21 p.m. The total load forecast at the time was 737 MW, resulting in an overestimate of 10.8%.

22 Figure 26(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
23 industrial component removed). The error in the forecast of the utility load was negligible. This suggests
24 the error in the industrial load forecast materially contributed to the error in the total load forecast. The
25 hourly forecast predicted a utility peak at 12:00 p.m. of 591 MW; the actual peak was 582 MW and
26 occurred at 5:00 p.m.

27 Figures 26(c), (d), and (e) are provided for context; however, the discrepancy between actual and
28 forecast utility load for August 10, 2020 was primarily due to error in the industrial load forecast.

1 Discrepancy in weather is not expected to have impacted the total actual load during the summer
2 season. The forecast improved slightly after peak. An overestimate of the load results in more than
3 enough reserve being available.

4 **2.3.22 August 27, 2020**

5 On August 27, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 740 MW; the actual
6 reported peak was 673 MW. The absolute difference was 67 MW, 10.0% of the actual peak. Figure 27
7 includes an hourly plot of the load forecast for August 27, 2020, as well as several plots to assist in
8 determining the sources of the differences between actual and forecast loads.

9 Figure 27(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
10 forecast predicted a 5:00 p.m. peak of 740 MW; the actual peak was 667 MW and occurred at 9:00 p.m.
11 The total load forecast at the time was 707 MW, resulting in an overestimate of 6.0%.

12 Figure 27(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
13 industrial component removed). The error in the forecast of the utility load was negligible. This suggests
14 the error in the industrial load forecast materially contributed to the error in the total load forecast. The
15 hourly forecast predicted a utility peak at 5:00 p.m. of 578 MW; the actual peak was 572 MW and
16 occurred at 5:00 p.m.

17 Figures 27(c), (d), and (e) are provided for context; however, the discrepancy between actual and
18 forecast utility load for August 27, 2020 was primarily due to error in the industrial load forecast.
19 Discrepancy in weather is not expected to have impacted the total actual load during the summer
20 season. The forecast remained poor through the day. An overestimate of the load results in more than
21 enough reserve being available.

22 **2.3.23 September 8, 2020**

23 On September 8, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 715 MW; the
24 actual reported peak was 773 MW. The peak of 773 MW, as reported to the Board, includes a Maritime
25 Link export of 52 MW, which occurred from 4:00 p.m. until midnight. The absolute difference, inclusive
26 of the export, was 58 MW, 7.5% of the actual peak. Figure 28 includes an hourly plot of the load forecast
27 for September 8, 2020, as well as several plots to assist in determining the sources of the differences
28 between actual and forecast loads.

1 Figure 28(a) shows the hourly distribution of the load forecast compared to the actual load, exclusive of
2 export activity. The hourly forecast predicted a 5:00 p.m. peak of 713 MW; the actual peak was 617 MW
3 and occurred at 8:00 p.m. The total load forecast at the time was 693 MW, resulting in an
4 underestimate of 3.3%.

5 Figure 28(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
6 industrial and export components removed). The hourly forecast predicted a utility peak at 5:00 p.m. of
7 551 MW; the actual peak was 573 MW and occurred at 5:00 p.m., resulting in an underestimate of 3.8%.

8 Figures 28(c), (d), and (e) are provided for context; however, the discrepancy between actual and
9 forecast load was primarily the result of export activity over the Maritime Link since error in both the
10 total load forecast, exclusive of exports, and the utility load forecast was low.

11 **2.3.24 September 9, 2020**

12 On September 9, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 690 MW; the
13 actual reported peak was 794 MW. The peak of 794 MW, as reported to the Board, includes a Maritime
14 Link export of 53 MW, which occurred from 5:00 p.m. until 11:00 p.m. The absolute difference, inclusive
15 of the export, was 104 MW, 13.1% of the actual peak. Figure 29 includes an hourly plot of the load
16 forecast for September 9, 2020, as well as several plots to assist in determining the sources of the
17 differences between actual and forecast loads.

18 Figure 29(a) shows the hourly distribution of the load forecast compared to the actual load, exclusive of
19 export activity. The hourly forecast predicted a 12:00 p.m. peak of 688 MW; the actual peak was 743
20 MW and occurred at 5:00 p.m. The total load forecast at the time was 685 MW, resulting in an
21 underestimate of 7.8%.

22 Figure 29(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
23 industrial and export components removed). Excluding export activity during peak, the error in the
24 forecast of the utility load was slightly lower than the error in the forecast of total load, meaning that
25 error in the industrial load forecast likely did not contribute significantly to the error in the total load
26 forecast in addition to export activity. The hourly forecast predicted a utility peak at 12:00 p.m. of 554
27 MW; the actual peak was 591 MW and occurred at 5:00 p.m. The utility load forecast at the time was
28 551 MW, resulting in an underestimate of 6.8%.

1 Figures 29(c), (d), and (e) are provided for context; however, the discrepancy between actual and
2 forecast load was primarily the result of SCADA data incorrectly reporting the Upper Salmon unit output
3 of -60 MW between 2:35 p.m. and 5:04 p.m., as noted in Section 2.2. The hours prior to peak
4 incorporated actual load that was 60 MW lower than it should have been, thus influencing the hourly
5 forecast updates to underestimate the load leading up to peak. It is not believed that export activity
6 over the Maritime Link was the source of error at peak as the addition of 53 MW to the load at time of
7 peak would have helped to compensate for the incorrect reduction in load at that hour.

8 **2.3.25 September 11, 2020**

9 On September 11, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 795 MW; the
10 actual reported peak was 713 MW. The absolute difference was 82 MW, 11.5% of the actual peak.
11 Figure 30 includes an hourly plot of the load forecast for September 11, 2020, as well as several plots to
12 assist in determining the sources of the differences between actual and forecast loads.

13 Figure 30(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
14 forecast predicted a 5:00 p.m. peak of 786 MW; the actual peak was 691 MW and occurred at 8:00 p.m.
15 The total load forecast at the time was 761 MW, resulting in an overestimate of 10.1%.

16 Figure 30(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
17 industrial component removed). The error in the forecast of the utility load was higher than the error in
18 the forecast of total load, suggesting that industrial load forecast contributed to the error in the total
19 load forecast. The hourly forecast predicted a utility peak at 5:00 p.m. of 623 MW; the actual peak was
20 599 MW and occurred at 5:00 p.m.

21 Figures 30(c), (d), and (e) are provided for context; however, the discrepancy between actual and
22 forecast load for September 11, 2020 was primarily a result of error in industrial load forecast
23 contributing to error in the total load forecast. An overestimate of the load results in more than enough
24 reserve being available. The forecast did not improve throughout the day.

25 **2.3.26 October 1, 2020**

26 On October 1, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 730 MW; the actual
27 reported peak was 664 MW. The absolute difference was 66 MW, 9.9% of the actual peak. Figure 31
28 includes an hourly plot of the load forecast for October 1, 2020, as well as several plots to assist in
29 determining the sources of the differences between actual and forecast loads.

1 Figure 31(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
2 forecast predicted a 12:00 p.m. peak of 729 MW; the actual peak was 651 MW and occurred at 8:00
3 p.m. The total load forecast at the time was 720 MW, resulting in an overestimate of 9.6%.

4 Figure 31(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
5 industrial component removed). The error in the forecast of the utility load was negligible. This suggests
6 the error in the industrial load forecast materially contributed to the error in the total load forecast. The
7 hourly forecast predicted a utility peak at 12:00 p.m. of 567 MW; the actual peak was 582 MW and
8 occurred at 5:00 p.m.

9 Figures 31(c), (d), and (e) are provided for context; however, the discrepancy between actual and
10 forecast utility load for October 1, 2020 was primarily a result of error in industrial load forecast. An
11 overestimate of the load results in more than enough reserve being available. The forecast did not
12 improve through the day.

13 **2.3.27 October 18, 2020**

14 On October 18, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 817 MW; the actual
15 reported peak was 730 MW. The peak of 730 MW, as reported to the Board, includes a Maritime Link
16 export of approximately 53 MW, which occurred from 12:00 p.m. until midnight. The absolute
17 difference, inclusive of export, was 87 MW, 10.6% of the actual peak. Figure 32 includes an hourly plot
18 of the load forecast for October 18, 2020, as well as several plots to assist in determining the sources of
19 the differences between actual and forecast loads.

20 Figure 32(a) shows the hourly distribution of the load forecast compared to the actual load, exclusive of
21 export activity. The hourly forecast predicted a 10:00 a.m. peak of 775 MW; the actual peak was 760
22 MW and occurred at 7:00 p.m. The total load forecast at the time was 771 MW, resulting in an
23 overestimate of 1.4%.

24 Figure 32(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
25 industrial and export components removed). The hourly forecast predicted a utility peak at 10:00 a.m. of
26 613 MW; the actual peak was 635 MW and occurred at 7:00 p.m. The forecast at time of peak was 609
27 MW, resulting in an underestimate of 4.1%.

1 Figures 32(c), (d), and (e) are provided for context; however, the discrepancy between actual and
2 forecast load was primarily attributable to export activity over the Maritime Link since error in both the
3 total load forecast, exclusive of exports, and the utility load forecast was low. An overestimation of the
4 load results in more than enough reserve being available. Hourly updates improved the load forecast as
5 the day progressed.

6 **2.3.28 October 21, 2020**

7 On October 21, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 850 MW; the actual
8 reported peak was 786 MW. The absolute difference was 64 MW, 8.1% of the actual peak. Figure 33
9 includes an hourly plot of the load forecast for October 21, 2020, as well as several plots to assist in
10 determining the sources of the differences between actual and forecast loads.

11 Figure 33(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
12 forecast predicted a 7:00 p.m. peak of 848 MW; the actual peak was 779 MW and occurred at 7:00 p.m.

13 Figure 33(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
14 industrial component removed). The error in the forecast of the utility load at time of peak was
15 negligible. This suggests the error in the industrial load forecast materially contributed to the error in
16 the total load forecast. The hourly forecast predicted a utility peak at 7:00 p.m. of 686 MW; the actual
17 peak was 712 MW and occurred at 5:00 p.m.

18 Figures 33(c), (d), and (e) are provided for context; however, the discrepancy between actual and
19 forecast utility load for October 21, 2020 is primarily a result of error in industrial load forecast. An
20 overestimate of the load results in more than enough reserve being available. The forecast did not
21 improve through the day. Note that the utility load actuals included in Figure 33(c) have been influenced
22 by the SCADA system upgrade discussed in Section 2.2. Following the system upgrade, erroneous and/or
23 missing actual load values resulted in unusable forecasts in the Nostradamus development system. Load
24 data was taken from the production version to replace the missing values; however, small errors
25 remained in the actual load data in the production system, resulting in an abnormal load shape.

26 **2.3.29 November 14, 2020**

27 On November 14, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,170 MW; the
28 actual reported peak was 1,242 MW. The absolute difference was 72 MW, 5.8% of the actual peak.

1 Figure 34 includes an hourly plot of the load forecast for November 14, 2020, as well as several plots to
2 assist in determining the sources of the differences between actual and forecast loads.

3 Figure 34(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
4 forecast predicted a 5:00 p.m. peak of 1,171 MW; the actual peak was 1,240 MW and occurred at 5:00
5 p.m.

6 Figure 34(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
7 industrial component removed). The error in the forecast of the utility load was higher than the error in
8 the forecast of total load, meaning that error in the industrial load forecast did not contribute to the
9 error in the total load forecast. The hourly forecast predicted a utility peak at 5:00 p.m. of 1,009 MW;
10 the actual peak was 1,089 MW and occurred at 5:00 p.m.

11 Figure 34(c) shows the actual temperature in St. John's compared to the forecast. The temperature was
12 overestimated by 1°C to 2°C from 10:00 a.m. onwards. The cooler than forecast temperatures likely
13 contributed to the load forecast error.

14 Figure 34(d) shows the actual wind speed in St. John's compared to the forecast. The actual wind speed
15 was slightly lower than forecast until 2:00 p.m. The actual wind speed then varied from the forecast
16 wind speed and was slightly higher than forecast at time of peak. The slightly higher forecast wind speed
17 at peak likely would not have contributed to the load forecast error. Figure 34(e) shows the forecast and
18 actual cloud cover. The forecast was relatively accurate during daylight hours.

19 The discrepancy between actual and forecast utility load for November 14, 2020 was likely a result of
20 non-uniform customer behaviour, as this day occurred on a weekend, and error in the temperature
21 forecast. The forecast improved after peak.

22 **2.3.30 November 17, 2020**

23 On November 17, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,095 MW; the
24 actual reported peak was 1,029 MW. The absolute difference was 66 MW, 6.4% of the actual peak.

25 Figure 35 includes an hourly plot of the load forecast for November 17, 2020, as well as several plots to
26 assist in determining the sources of the differences between actual and forecast loads.

1 Figure 35(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
2 forecast predicted a 6:00 p.m. peak of 1,096 MW; the actual peak was 1,023 MW and occurred at 5:00
3 p.m. The total load forecast at the time was 1,085 MW, resulting in an overestimate of 6.1%.

4 Figure 35(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
5 industrial component removed). The error in the forecast of the utility load was lower than the error in
6 the forecast of total load, suggesting that industrial load forecast contributed to the error in the total
7 load forecast. The hourly forecast predicted a utility peak at 6:00 p.m. of 934 MW; the actual peak was
8 886 MW and occurred at 5:00 p.m.

9 Figure 35(c) shows the actual temperature in St. John's compared to the forecast. The temperature
10 forecast was accurate at peak, and therefore likely did not contribute to the error in the total load
11 forecast.

12 Figure 35(d) shows the actual wind speed in St. John's compared to the forecast. The forecast wind
13 speed was overestimated for the majority of the day which likely contributed to the error in the total
14 load forecast. Figure 35(e) shows the actual cloud cover in St. John's compared to the forecast. The
15 forecast cloud cover was slightly underestimated during daylight hours; however, this would likely not
16 counteract the reduction in actual wind speed.

17 The discrepancy between actual and forecast utility load for November 17, 2020 was primarily a result
18 of error in the industrial load forecast and was further influenced by error in the wind speed forecast.
19 The forecast did not improve after peak for the remainder of the day.

20 **2.3.31 November 19, 2020**

21 On November 19, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,245 MW; the
22 actual reported peak was 1,346 MW. The peak of 1,346 MW, as reported to the Board, includes a
23 Maritime Link export of approximately 53 MW, which occurred from 8:00 a.m. until 7:00 p.m. The
24 absolute difference, inclusive of export, was 101 MW, 7.5% of the actual peak. Figure 36 includes an
25 hourly plot of the load forecast for November 19, 2020, as well as several plots to assist in determining
26 the sources of the differences between actual and forecast loads.

27 Figure 36(a) shows the hourly distribution of the load forecast compared to the actual load, exclusive of
28 exports. The hourly forecast predicted a 6:00 p.m. peak of 1,247 MW; the actual peak was 1,288 MW

1 and occurred at 5:00 p.m. The total load forecast at the time was 1,246 MW, resulting in an
2 underestimate of 3.2%.

3 Figure 36(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
4 industrial and export components removed). The hourly forecast predicted a utility peak at 6:00 p.m. of
5 1,084 MW; the actual peak was 1,152 MW and occurred at 5:00 p.m., resulting in an underestimate of
6 5.9%.

7 Figure 36(c) shows the actual temperature in St. John's compared to the forecast. The temperature
8 forecast was underestimated until 2:00 p.m. when it was overestimated for the remainder of the day.
9 Colder than forecast temperatures in the afternoon could have contributed to the load forecast error
10 leading up to peak.

11 Figure 36(d) shows the actual wind speed in St. John's compared to the forecast. Through the entire day
12 the actual wind speed was slightly lower than forecast, however not likely enough to contribute to the
13 forecast error. Figure 36(e) shows the actual cloud cover in St. John's compared to the forecast. Cloud
14 cover was underestimated for the entire day. More cloud cover than forecast combined with colder
15 temperatures than forecast in the afternoon could have contributed to the load forecast underestimate
16 at peak.

17 The discrepancy between actual and forecast load for November 19, 2020 was primarily a result of
18 export activity over the Maritime Link, and further influenced by error in the temperature and cloud
19 cover forecast. The forecast improved after peak.

20 **2.3.32 December 10, 2020**

21 On December 10, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,210 MW; the
22 actual reported peak was 1,128 MW. The absolute difference was 82 MW, 7.3% of the actual peak.

23 Figure 37 includes an hourly plot of the load forecast for December 10, 2020, as well as several plots to
24 assist in determining the sources of the differences between actual and forecast loads.

25 Figure 37(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
26 forecast predicted a 5:00 p.m. peak of 1,248 MW; the actual peak was 1,169 MW and occurred at 5:00
27 p.m.

1 Figure 37(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
2 industrial component removed). The error in the forecast of the utility load was materially lower than
3 the error in the forecast of total load. This suggests the error in the industrial load forecast materially
4 contributed to the error in the total load forecast. The hourly forecast predicted a utility peak at 5:00
5 p.m. of 1,086 MW; the actual peak of 1,067 MW occurred at 5:00 p.m.

6 Figures 37(c), (d), and (e) are provided for context; however, the discrepancy between actual and
7 forecast utility load for December 10, 2020 was primarily a result of errors in industrial load forecast.
8 The forecast did not improve as the day went on. An overestimate of the load results in more than
9 enough reserve being available.

10 **2.3.33 December 19, 2020**

11 On December 19, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,510 MW; the
12 actual reported peak was 1,398 MW. The peak of 1,398 MW, as reported to the Board, includes a
13 Maritime Link export of approximately 27 MW, which occurred from 5:00 p.m. until 8:00 p.m., reaching
14 up to 52 MW. The absolute difference, inclusive of export, was 112 MW, 8.0% of the actual peak. Figure
15 38 includes an hourly plot of the load forecast for December 19, 2020, as well as several plots to assist in
16 determining the sources of the differences between actual and forecast loads.

17 Figure 38(a) shows the hourly distribution of the load forecast compared to the actual load, exclusive of
18 export activity. The hourly forecast predicted a 5:00 p.m. peak of 1,345 MW; the actual peak was 1,294
19 MW and occurred at 5:00 p.m., resulting in an overestimate of 3.9%.

20 Figure 38(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
21 industrial and export components removed). The error in the forecast of the utility load was materially
22 lower than the error in the forecast of total load. This suggests the error in the industrial load forecast
23 materially contributed to the error in the total load forecast. The hourly forecast predicted a utility peak
24 at 5:00 p.m. of 1,184 MW; the actual peak of 1,174 MW occurred at 5:00 p.m.

25 Figures 38(c), (d), and (e) are provided for context; however, the discrepancy between actual and
26 forecast load is primarily the result of export activity over the Maritime Link. An overestimation of the
27 load results in more than enough reserve being available. The forecast did not improve for the
28 remainder of the day.

1 **2.3.34 December 30, 2020**

2 On December 30, 2020, the forecast peak at 7:20 a.m., as reported to the Board, was 1,425 MW; the
3 actual reported peak was 1,352 MW. The absolute difference was 73 MW, 5.4% of the actual peak.
4 Figure 39 includes an hourly plot of the load forecast for December 30, 2020, as well as several plots to
5 assist in determining the sources of the differences between actual and forecast loads.

6 Figure 39(a) shows the hourly distribution of the load forecast compared to the actual load. The hourly
7 forecast predicted a 5:00 p.m. peak of 1,429 MW; the actual peak was 1,371 MW and occurred at 5:00
8 p.m.

9 Figure 39(b) shows the hourly distribution of the utility load forecast only (i.e., the load forecast with the
10 industrial component removed). The error in the forecast of the utility load was lower than the error in
11 the forecast of total load, meaning that error in the industrial load forecast contributed to the error in
12 the total load forecast. The hourly forecast predicted a utility peak at 5:00 p.m. of 1,268 MW; the actual
13 peak of 1,227 MW occurred at 5:00 p.m.

14 Figures 39(c), (d), and (e) are provided for context; however, the discrepancy between actual and
15 forecast utility load for December 30, 2020 was primarily a result of error in industrial load. As the day
16 occurred during Christmas break, non-uniform customer behaviour could also have been a contributor.
17 An overestimate of the load results in more than enough reserve being available. The forecast did not
18 improve through the day.

19 **3 Forecast Accuracy Review**

20 Table 4 summarizes the average error in the peak of the utility load forecast by month in 2020. The
21 absolute percent error at peak each month varied between 1.6% (February 2020) and 3.5% (December
22 2020) with an average of 2.5%. For reference, Hydro considers error below 4.95% to be within
23 acceptable forecasting limits. Comparing absolute percent error, there does not appear to be any
24 seasonal correlation. The average error was negative in eight months of the year and positive in four
25 months of the year. On average, the forecast typically underestimates the load though the average
26 understatement is -0.6% of actual peak. The average absolute error in 2020 was 23 MW, which
27 compares to the average absolute error in 2019 of 20 MW. The slight increase in average error at peak is
28 likely due to an increase in non-uniform customer behaviour as a result of the COVID-19 pandemic.


1 Table 5 summarizes the maximum error in the peak of the utility load forecast by month in 2020. The
2 maximum absolute error varied between 4.2% (August 2020) and 13.4% (July 2020). Comparing absolute
3 percent error, there does not appear to be any seasonal correlation. The maximum errors were positive
4 in all 12 months. For monthly maximum errors, the forecast typically overestimates (rather than
5 underestimates) the load. The largest absolute error at peak in 2020 was 158 MW and occurred on
6 January 2, 2020 when an external technology error impacted the program's ability to provide an
7 accurate forecast. As previously noted, this error was not a result of the Nostradamus program.
8 Therefore, the largest absolute error at peak was 116 MW and occurred in February 2020. This was an
9 improvement compared to the largest error at peak in 2019 of 121 MW which occurred in January.


10 Table 6 summarizes the error at the ten highest utility loads during the reporting period. The highest
11 loads in this reporting period occurred in January (four instances), February (five instances), and March
12 (one instance). Four of the ten highest loads were overestimated and six were underestimated. The
13 percent error varied from -3.7% to 2.6%; the overall average was -0.4%. The absolute percent error
14 varied from 0.8% to 3.7%, with an average of 1.7%. These statistics confirm that there is no correlation
15 between high load and high error in the load forecast and that Nostradamus is forecasting high load at
16 peak well within the acceptable forecasting limit of less than 4.95% error.


17 Table 7 summarizes the result of the investigations into instances of high forecast error. Most errors
18 occur as a result of errors in the industrial forecast and error due to export activity over the Maritime
19 Link. Less frequently, errors occur due to the weather forecast, largely driven by errors in temperature
20 and wind speed forecasting. Some errors remain unexplained; they result from unpredictable customer
21 behavior that can occur on a weekend or during a statutory holiday that is not modelled by
22 Nostradamus. An additional source of non-conforming error is the impact the COVID-19 pandemic had
23 on the load beginning March 2020 through year end. While the impacts are not able to be fully
24 quantified, the implementation of public health measures through the year may have contributed to
25 increases in non-uniform customer behaviour that may have resulted in a small impact on the overall
26 load and load shape. Of the 36 included instances of high forecast error, 10 occurred on a weekend, and
27 26 occurred on a weekday.

Appendix A


Tables and Figures











**Figure 2(b): Peak Forecast, Total Load and Error
 May 2020 through December 2020**



























Figure 11 Accuracy Analysis - Mar 18, 2020






Figure 13 Accuracy Analysis - Apr 02, 2020








Figure 14 Accuracy Analysis - Apr 14, 2020


















































Figure 31 Accuracy Analysis - Oct 01, 2020














Figure 36 Accuracy Analysis - Nov 19, 2020








Figure 39 Accuracy Analysis - Dec 30, 2020




Table 1: Load Forecasting Data (MW)²¹

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
1-Jan-2020	1,250	1,305	2,025	775
2-Jan-2020	1,135	1,282	2,015	880
3-Jan-2020	1,165	1,295	2,020	855
4-Jan-2020	1,250	1,240	1,975	725
5-Jan-2020	1,280	1,305	1,962	682
6-Jan-2020	1,475	1,373	1,950	475
7-Jan-2020	1,425	1,338	1,960	535
8-Jan-2020	1,410	1,401	1,955	545
9-Jan-2020	1,525	1,432	1,975	450
10-Jan-2020	1,620	1,619	1,970	350
11-Jan-2020	1,355	1,333	1,920	565
12-Jan-2020	1,500	1,451	2,005	505
13-Jan-2020	1,505	1,496	1,995	490
14-Jan-2020	1,555	1,528	1,990	435
15-Jan-2020	1,645	1,620	1,975	330
16-Jan-2020	1,550	1,501	1,970	420
17-Jan-2020	1,525	1,543	2,000	475
18-Jan-2020	1,635	1,549	1,745	110
19-Jan-2020	1,560	1,555	1,815	255
20-Jan-2020	1,395	1,385	1,965	570
21-Jan-2020	1,460	1,462	1,960	500
22-Jan-2020	1,615	1,568	1,980	365
23-Jan-2020	1,485	1,464	1,965	480
24-Jan-2020	1,405	1,349	1,915	510
25-Jan-2020	1,470	1,485	2,083	613
26-Jan-2020	1,410	1,376	2,103	693
27-Jan-2020	1,330	1,292	2,050	720
28-Jan-2020	1,330	1,299	2,035	705
29-Jan-2020	1,400	1,355	2,134	734
30-Jan-2020	1,405	1,355	2,144	739
31-Jan-2020	1,480	1,457	2,134	654
Minimum	1,135	1,240	1,745	110
Average	1,437	1,420	1,990	553
Maximum	1,645	1,620	2,144	880

²¹ Forecast Reserve does not include adjustments for interruptible load, the impact of voltage reduction, or scheduled off-Island imports.

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
1-Feb-2020	1,475	1,441	2,139	664
2-Feb-2020	1,420	1,498	2,159	739
3-Feb-2020	1,495	1,446	2,134	639
4-Feb-2020	1,435	1,410	2,039	604
5-Feb-2020	1,455	1,413	2,154	699
6-Feb-2020	1,555	1,529	2,070	515
7-Feb-2020	1,430	1,423	2,044	614
8-Feb-2020	1,485	1,427	1,887	402
9-Feb-2020	1,470	1,459	2,070	600
10-Feb-2020	1,555	1,532	2,140	585
11-Feb-2020	1,360	1,343	2,083	723
12-Feb-2020	1,440	1,379	2,150	710
13-Feb-2020	1,480	1,444	2,185	705
14-Feb-2020	1,685	1,606	2,070	385
15-Feb-2020	1,665	1,529	2,045	380
16-Feb-2020	1,450	1,476	2,205	755
17-Feb-2020	1,355	1,288	2,140	785
18-Feb-2020	1,500	1,439	2,055	555
19-Feb-2020	1,525	1,471	2,209	684
20-Feb-2020	1,605	1,587	2,095	490
21-Feb-2020	1,705	1,656	2,040	335
22-Feb-2020	1,545	1,516	2,150	605
23-Feb-2020	1,320	1,279	2,125	805
24-Feb-2020	1,420	1,401	2,095	675
25-Feb-2020	1,305	1,273	2,015	710
26-Feb-2020	1,330	1,246	2,086	756
27-Feb-2020	1,450	1,399	2,125	675
28-Feb-2020	1,440	1,403	2,135	695
29-Feb-2020	1,280	1,241	2,139	859
Minimum	1,280	1,241	1,887	335
Average	1,470	1,433	2,103	633
Maximum	1,705	1,656	2,209	859
1-Mar-2020	1,365	1,353	2,015	650
2-Mar-2020	1,415	1,356	2,114	699
3-Mar-2020	1,530	1,488	2,180	650
4-Mar-2020	1,270	1,226	2,140	870
5-Mar-2020	1,320	1,334	1,915	595
6-Mar-2020	1,360	1,309	2,199	839

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
7-Mar-2020	1,390	1,411	2,175	785
8-Mar-2020	1,375	1,348	2,190	815
9-Mar-2020	1,590	1,465	2,118	528
10-Mar-2020	1,650	1,647	2,144	494
11-Mar-2020	1,430	1,449	2,029	599
12-Mar-2020	1,380	1,358	2,044	664
13-Mar-2020	1,440	1,455	2,104	664
14-Mar-2020	1,385	1,395	2,166	781
15-Mar-2020	1,350	1,296	2,189	839
16-Mar-2020	1,465	1,459	2,104	639
17-Mar-2020	1,540	1,561	2,089	549
18-Mar-2020	1,375	1,302	2,159	784
19-Mar-2020	1,390	1,329	2,094	704
20-Mar-2020	1,385	1,391	2,110	725
21-Mar-2020	1,245	1,216	2,144	899
22-Mar-2020	1,445	1,376	2,155	710
23-Mar-2020	1,515	1,437	2,084	569
24-Mar-2020	1,380	1,332	2,140	760
25-Mar-2020	1,320	1,301	2,089	769
26-Mar-2020	1,345	1,298	2,094	749
27-Mar-2020	1,290	1,302	2,164	874
28-Mar-2020	1,185	1,161	2,115	930
29-Mar-2020	1,260	1,276	2,124	864
30-Mar-2020	1,325	1,316	2,049	724
31-Mar-2020	1,220	1,173	2,079	859
Minimum	1,185	1,161	1,915	494
Average	1,385	1,359	2,113	728
Maximum	1,650	1,647	2,199	930
1-Apr-2020	1,155	1,086	1,900	745
2-Apr-2020	1,115	1,032	2,029	914
3-Apr-2020	1,185	1,181	1,995	810
4-Apr-2020	1,160	1,169	1,885	725
5-Apr-2020	1,165	1,168	1,875	710
6-Apr-2020	1,250	1,167	1,865	615
7-Apr-2020	1,200	1,179	1,810	610
8-Apr-2020	1,255	1,191	1,830	575
9-Apr-2020	1,220	1,176	1,855	635
10-Apr-2020	1,280	1,260	1,880	600

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
11-Apr-2020	1,080	1,046	1,888	808
12-Apr-2020	1,025	1,046	1,904	879
13-Apr-2020	1,100	1,049	1,860	760
14-Apr-2020	1,130	1,018	1,775	645
15-Apr-2020	1,015	988	1,740	725
16-Apr-2020	1,040	1,069	1,675	635
17-Apr-2020	1,160	1,156	1,705	545
18-Apr-2020	1,080	1,055	1,745	665
19-Apr-2020	1,220	1,317	1,775	555
20-Apr-2020	1,120	1,113	1,765	645
21-Apr-2020	1,150	1,122	1,865	715
22-Apr-2020	1,115	1,050	1,795	680
23-Apr-2020	1,055	1,051	1,895	840
24-Apr-2020	1,075	1,042	1,845	770
25-Apr-2020	1,085	1,068	1,805	720
26-Apr-2020	1,020	973	1,795	775
27-Apr-2020	1,065	1,044	1,825	760
28-Apr-2020	1,115	1,074	1,785	670
29-Apr-2020	1,145	1,119	1,800	655
30-Apr-2020	1,090	1,100	1,850	760
Minimum	1,015	973	1,675	545
Average	1,129	1,104	1,834	705
Maximum	1,280	1,317	2,029	914
1-May-2020	960	871	1,840	880
2-May-2020	920	873	1,705	785
3-May-2020	945	987	1,720	775
4-May-2020	1,040	1,054	1,655	615
5-May-2020	1,145	1,150	1,650	505
6-May-2020	1,030	1,033	1,645	615
7-May-2020	1,055	1,062	1,650	595
8-May-2020	1,015	1,034	1,620	605
9-May-2020	920	952	1,630	710
10-May-2020	1,035	1,030	1,675	640
11-May-2020	1,030	1,041	1,670	640
12-May-2020	1,000	1,070	1,635	635
13-May-2020	1,025	1,036	1,635	610
14-May-2020	1,075	1,036	1,665	590
15-May-2020	1,050	1,067	1,645	595

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
16-May-2020	985	928	1,625	640
17-May-2020	1,015	1,015	1,630	615
18-May-2020	990	949	1,635	645
19-May-2020	1,055	1,038	1,635	580
20-May-2020	1,040	1,011	1,545	505
21-May-2020	905	889	1,550	645
22-May-2020	895	855	1,670	775
23-May-2020	965	927	1,670	705
24-May-2020	965	854	1,630	665
25-May-2020	890	901	1,580	690
26-May-2020	850	823	1,600	750
27-May-2020	835	817	1,365	530
28-May-2020	830	841	1,570	740
29-May-2020	770	725	1,680	910
30-May-2020	730	713	1,705	975
31-May-2020	735	715	1,585	850
Minimum	730	713	1,365	505
Average	958	945	1,636	678
Maximum	1,145	1,150	1,840	975
1-Jun-2020	800	815	1,480	680
2-Jun-2020	840	891	1,495	655
3-Jun-2020	845	862	1,425	580
4-Jun-2020	865	846	1,540	675
5-Jun-2020	820	767	1,580	760
6-Jun-2020	795	746	1,475	680
7-Jun-2020	880	895	1,395	515
8-Jun-2020	890	932	1,415	525
9-Jun-2020	995	957	1,390	395
10-Jun-2020	910	869	1,385	475
11-Jun-2020	850	829	1,370	520
12-Jun-2020	840	726	1,365	525
13-Jun-2020	735	696	1,385	650
14-Jun-2020	785	778	1,425	640
15-Jun-2020	845	844	1,420	575
16-Jun-2020	775	774	1,430	655
17-Jun-2020	810	763	1,445	635
18-Jun-2020	755	780	1,385	630
19-Jun-2020	790	750	1,455	665

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
20-Jun-2020	830	816	1,375	545
21-Jun-2020	780	768	1,355	575
22-Jun-2020	790	790	1,370	580
23-Jun-2020	770	740	1,375	605
24-Jun-2020	745	748	1,365	620
25-Jun-2020	755	720	1,300	545
26-Jun-2020	740	738	1,355	615
27-Jun-2020	705	691	1,365	660
28-Jun-2020	695	717	1,360	665
29-Jun-2020	835	750	1,535	700
30-Jun-2020	800	769	1,540	740
Minimum	695	691	1,300	395
Average	809	792	1,419	610
Maximum	995	957	1,580	760
1-Jul-2020	770	751	1,550	780
2-Jul-2020	790	741	1,270	480
3-Jul-2020	790	805	1,550	760
4-Jul-2020	760	739	1,365	605
5-Jul-2020	750	741	1,360	610
6-Jul-2020	780	743	1,315	535
7-Jul-2020	750	704	1,300	550
8-Jul-2020	745	669	1,170	425
9-Jul-2020	750	719	1,210	460
10-Jul-2020	740	708	1,205	465
11-Jul-2020	695	677	1,200	505
12-Jul-2020	695	681	1,300	605
13-Jul-2020	755	709	1,310	555
14-Jul-2020	740	691	1,285	545
15-Jul-2020	770	806	1,315	545
16-Jul-2020	815	856	1,405	590
17-Jul-2020	775	775	1,385	610
18-Jul-2020	740	677	1,435	695
19-Jul-2020	730	651	1,435	705
20-Jul-2020	755	725	1,455	700
21-Jul-2020	745	806	1,465	720
22-Jul-2020	735	745	1,395	660
23-Jul-2020	730	699	1,360	630
24-Jul-2020	740	711	1,370	630

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
25-Jul-2020	695	660	1,490	795
26-Jul-2020	710	703	1,505	795
27-Jul-2020	750	724	1,435	685
28-Jul-2020	735	702	1,430	695
29-Jul-2020	735	708	1,440	705
30-Jul-2020	765	727	1,390	625
31-Jul-2020	730	710	1,425	695
Minimum	695	651	1,170	425
Average	747	725	1,372	625
Maximum	815	856	1,550	795
1-Aug-2020	725	671	1,420	695
2-Aug-2020	715	680	1,440	725
3-Aug-2020	645	608	1,430	785
4-Aug-2020	650	648	1,450	800
5-Aug-2020	615	606	1,370	755
6-Aug-2020	625	639	1,420	795
7-Aug-2020	625	624	1,400	775
8-Aug-2020	585	590	1,410	825
9-Aug-2020	700	606	1,380	680
10-Aug-2020	755	669	1,390	635
11-Aug-2020	745	693	1,265	520
12-Aug-2020	745	719	1,425	680
13-Aug-2020	750	733	1,410	660
14-Aug-2020	735	703	1,275	540
15-Aug-2020	710	650	1,435	725
16-Aug-2020	685	674	1,420	735
17-Aug-2020	740	718	1,365	625
18-Aug-2020	730	689	1,380	650
19-Aug-2020	715	694	1,385	670
20-Aug-2020	720	711	1,370	650
21-Aug-2020	725	688	1,460	735
22-Aug-2020	685	672	1,440	755
23-Aug-2020	685	679	1,375	690
24-Aug-2020	735	725	1,345	610
25-Aug-2020	720	695	1,300	580
26-Aug-2020	765	733	1,390	625
27-Aug-2020	740	673	1,375	635
28-Aug-2020	725	673	1,385	660

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
29-Aug-2020	695	654	1,410	715
30-Aug-2020	760	745	1,395	635
31-Aug-2020	765	745	1,290	525
Minimum	585	590	1,265	520
Average	707	678	1,387	680
Maximum	765	745	1,460	825
1-Sep-2020	735	685	1,435	700
2-Sep-2020	710	696	1,420	710
3-Sep-2020	685	710	1,385	700
4-Sep-2020	730	717	1,390	660
5-Sep-2020	700	695	1,450	750
6-Sep-2020	680	681	1,445	765
7-Sep-2020	705	688	1,435	730
8-Sep-2020	715	773	1,280	565
9-Sep-2020	690	794	1,280	590
10-Sep-2020	755	769	1,270	515
11-Sep-2020	795	713	1,295	500
12-Sep-2020	730	711	1,295	565
13-Sep-2020	725	720	1,440	715
14-Sep-2020	770	756	1,275	505
15-Sep-2020	760	722	1,185	425
16-Sep-2020	770	767	1,150	380
17-Sep-2020	740	743	1,185	445
18-Sep-2020	745	763	1,185	440
19-Sep-2020	770	760	1,295	525
20-Sep-2020	790	789	1,280	490
21-Sep-2020	855	838	1,365	510
22-Sep-2020	835	820	1,325	490
23-Sep-2020	780	747	1,350	570
24-Sep-2020	755	724	1,360	605
25-Sep-2020	760	733	1,270	510
26-Sep-2020	750	743	1,355	605
27-Sep-2020	720	714	1,300	580
28-Sep-2020	755	734	1,375	620
29-Sep-2020	735	732	1,265	530
30-Sep-2020	735	739	1,270	535
Minimum	680	681	1,150	380
Average	746	739	1,320	574

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
Maximum	855	838	1,450	765
1-Oct-2020	730	664	1,295	565
2-Oct-2020	710	696	1,200	490
3-Oct-2020	710	726	1,290	580
4-Oct-2020	775	785	1,260	485
5-Oct-2020	845	856	1,335	490
6-Oct-2020	910	877	1,310	400
7-Oct-2020	825	806	1,325	500
8-Oct-2020	820	793	1,374	554
9-Oct-2020	910	861	1,555	645
10-Oct-2020	835	805	1,550	715
11-Oct-2020	780	784	1,420	640
12-Oct-2020	850	850	1,405	555
13-Oct-2020	930	938	1,390	460
14-Oct-2020	910	908	1,439	529
15-Oct-2020	780	759	1,585	805
16-Oct-2020	770	782	1,515	745
17-Oct-2020	720	748	1,510	790
18-Oct-2020	730	817	1,460	730
19-Oct-2020	865	849	1,480	615
20-Oct-2020	860	834	1,445	585
21-Oct-2020	850	786	1,475	625
22-Oct-2020	860	812	1,557	697
23-Oct-2020	945	902	1,480	535
24-Oct-2020	915	922	1,563	648
25-Oct-2020	935	919	1,684	749
26-Oct-2020	1,055	1,036	1,545	490
27-Oct-2020	1,085	1,026	1,674	589
28-Oct-2020	1,080	1,059	1,510	430
29-Oct-2020	1,170	1,149	1,545	375
30-Oct-2020	1,145	1,111	1,640	495
31-Oct-2020	1,165	1,131	1,630	465
Minimum	710	664	1,200	375
Average	886	871	1,466	580
Maximum	1,170	1,149	1,684	805
1-Nov-2020	1,080	1,081	1,630	550
2-Nov-2020	1,020	1,034	1,645	625
3-Nov-2020	1,080	1,073	1,565	485

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
4-Nov-2020	1,310	1,257	1,750	440
5-Nov-2020	1,270	1,218	1,705	435
6-Nov-2020	1,075	1,033	1,726	651
7-Nov-2020	1,000	1,002	1,800	800
8-Nov-2020	1,105	1,084	1,720	615
9-Nov-2020	1,190	1,182	1,705	515
10-Nov-2020	1,050	994	1,655	605
11-Nov-2020	1,055	1,015	1,696	641
12-Nov-2020	955	933	1,645	690
13-Nov-2020	1,005	1,021	1,610	605
14-Nov-2020	1,170	1,242	1,710	540
15-Nov-2020	1,220	1,154	1,795	575
16-Nov-2020	1,195	1,202	1,895	700
17-Nov-2020	1,095	1,029	1,910	815
18-Nov-2020	1,120	1,147	1,935	815
19-Nov-2020	1,245	1,346	1,945	700
20-Nov-2020	1,285	1,265	1,985	700
21-Nov-2020	1,085	1,098	2,010	925
22-Nov-2020	1,265	1,290	1,980	715
23-Nov-2020	1,365	1,353	2,055	690
24-Nov-2020	1,150	1,138	1,890	740
25-Nov-2020	1,355	1,329	2,000	645
26-Nov-2020	1,245	1,252	2,015	770
27-Nov-2020	1,070	1,096	1,810	740
28-Nov-2020	985	989	1,890	905
29-Nov-2020	1,130	1,148	1,760	630
30-Nov-2020	1,195	1,219	2,045	850
Minimum	955	933	1,565	435
Average	1146	1,141	1,816	670
Maximum	1365	1,353	2,055	925
1-Dec-2020	1,255	1,320	2,005	750
2-Dec-2020	1,400	1,375	1,980	580
3-Dec-2020	1,365	1,313	1,995	630
4-Dec-2020	1,205	1,171	2,040	835
5-Dec-2020	1,235	1,229	1,885	650
6-Dec-2020	1,275	1,229	1,970	695
7-Dec-2020	1,335	1,320	1,990	655
8-Dec-2020	1,390	1,400	1,985	595

Date	Forecast Total Peak	Actual Total Peak	Available Island Supply	Forecast Reserve
9-Dec-2020	1,410	1,351	2,000	590
10-Dec-2020	1,210	1,128	2,010	800
11-Dec-2020	1,260	1,195	1,985	725
12-Dec-2020	1,405	1,437	1,965	560
13-Dec-2020	1,565	1,564	2,000	435
14-Dec-2020	1,425	1,386	1,860	435
15-Dec-2020	1,230	1,171	1,872	642
16-Dec-2020	1,470	1,486	1,925	455
17-Dec-2020	1,570	1,492	2,025	455
18-Dec-2020	1,505	1,451	1,970	465
19-Dec-2020	1,510	1,398	1,975	465
20-Dec-2020	1,440	1,419	2,010	570
21-Dec-2020	1,390	1,365	2,060	670
22-Dec-2020	1,500	1,477	2,020	520
23-Dec-2020	1,495	1,500	1,995	500
24-Dec-2020	1,420	1,352	2,015	595
25-Dec-2020	1,305	1,322	2,040	735
26-Dec-2020	1,360	1,359	2,040	680
27-Dec-2020	1,380	1,344	2,050	670
28-Dec-2020	1,315	1,321	2,010	695
29-Dec-2020	1,305	1,303	2,025	720
30-Dec-2020	1,425	1,352	2,020	595
31-Dec-2020	1,355	1,316	2,015	660
Minimum	1,205	1,128	1,860	435
Average	1,378	1,350	1,992	614
Maximum	1,570	1,564	2,060	835

Table 2: Analysis of Total Forecast Error²²

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
1-Jan-2020	1,305	1,250	-55	55	-4.2%	4.2%	-4.4%
2-Jan-2020	1,282	1,135	-147	147	-11.5%	11.5%	-13.0%
3-Jan-2020	1,295	1,165	-130	130	-10.0%	10.0%	-11.2%
4-Jan-2020	1,240	1,250	10	10	0.8%	0.8%	0.8%
5-Jan-2020	1,305	1,280	-25	25	-1.9%	1.9%	-2.0%
6-Jan-2020	1,373	1,475	102	102	7.4%	7.4%	6.9%
7-Jan-2020	1,338	1,425	87	87	6.5%	6.5%	6.1%
8-Jan-2020	1,401	1,410	9	9	0.6%	0.6%	0.6%
9-Jan-2020	1,432	1,525	93	93	6.5%	6.5%	6.1%
10-Jan-2020	1,619	1,620	1	1	0.1%	0.1%	0.1%
11-Jan-2020	1,333	1,355	22	22	1.7%	1.7%	1.6%
12-Jan-2020	1,451	1,500	49	49	3.4%	3.4%	3.3%
13-Jan-2020	1,496	1,505	9	9	0.6%	0.6%	0.6%
14-Jan-2020	1,528	1,555	27	27	1.8%	1.8%	1.7%
15-Jan-2020	1,620	1,645	25	25	1.5%	1.5%	1.5%
16-Jan-2020	1,501	1,550	49	49	3.3%	3.3%	3.2%
17-Jan-2020	1,543	1,525	-18	18	-1.2%	1.2%	-1.2%
18-Jan-2020	1,549	1,635	86	86	5.6%	5.6%	5.3%
19-Jan-2020	1,555	1,560	5	5	0.3%	0.3%	0.3%
20-Jan-2020	1,385	1,395	10	10	0.7%	0.7%	0.7%
21-Jan-2020	1,462	1,460	-2	2	-0.1%	0.1%	-0.1%
22-Jan-2020	1,568	1,615	47	47	3.0%	3.0%	2.9%
23-Jan-2020	1,464	1,485	21	21	1.4%	1.4%	1.4%
24-Jan-2020	1,349	1,405	56	56	4.2%	4.2%	4.0%
25-Jan-2020	1,485	1,470	-15	15	-1.0%	1.0%	-1.0%
26-Jan-2020	1,376	1,410	34	34	2.5%	2.5%	2.4%
27-Jan-2020	1,292	1,330	38	38	2.9%	2.9%	2.9%
28-Jan-2020	1,299	1,330	31	31	2.4%	2.4%	2.3%
29-Jan-2020	1,355	1,400	45	45	3.3%	3.3%	3.2%
30-Jan-2020	1,355	1,405	50	50	3.7%	3.7%	3.6%
31-Jan-2020	1,457	1,480	23	23	1.6%	1.6%	1.6%
Minimum	1,240	1,135	-147	1	-11.5%	0.1%	-13.0%
Average	1,420	1,437	17	43	1.2%	3.1%	1.0%
Maximum	1,620	1,645	102	147	7.4%	11.5%	6.9%

²² Lines that have been bolded indicate further examination of the hourly forecast was provided in this report.

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
1-Feb-2020	1,441	1,475	34	34	2.4%	2.4%	2.3%
2-Feb-2020	1,498	1,420	-78	78	-5.2%	5.2%	-5.5%
3-Feb-2020	1,446	1,495	49	49	3.4%	3.4%	3.3%
4-Feb-2020	1,410	1,435	25	25	1.8%	1.8%	1.7%
5-Feb-2020	1,413	1,455	42	42	3.0%	3.0%	2.9%
6-Feb-2020	1,529	1,555	26	26	1.7%	1.7%	1.7%
7-Feb-2020	1,423	1,430	7	7	0.5%	0.5%	0.5%
8-Feb-2020	1,427	1,485	58	58	4.1%	4.1%	3.9%
9-Feb-2020	1,459	1,470	11	11	0.8%	0.8%	0.7%
10-Feb-2020	1,532	1,555	23	23	1.5%	1.5%	1.5%
11-Feb-2020	1,343	1,360	17	17	1.3%	1.3%	1.3%
12-Feb-2020	1,379	1,440	61	61	4.4%	4.4%	4.2%
13-Feb-2020	1,444	1,480	36	36	2.5%	2.5%	2.4%
14-Feb-2020	1,606	1,685	79	79	4.9%	4.9%	4.7%
15-Feb-2020	1,529	1,665	136	136	8.9%	8.9%	8.2%
16-Feb-2020	1,476	1,450	-26	26	-1.8%	1.8%	-1.8%
17-Feb-2020	1,288	1,355	67	67	5.2%	5.2%	4.9%
18-Feb-2020	1,439	1,500	61	61	4.2%	4.2%	4.1%
19-Feb-2020	1,471	1,525	54	54	3.7%	3.7%	3.5%
20-Feb-2020	1,587	1,605	18	18	1.1%	1.1%	1.1%
21-Feb-2020	1,656	1,705	49	49	3.0%	3.0%	2.9%
22-Feb-2020	1,516	1,545	29	29	1.9%	1.9%	1.9%
23-Feb-2020	1,279	1,320	41	41	3.2%	3.2%	3.1%
24-Feb-2020	1,401	1,420	19	19	1.4%	1.4%	1.3%
25-Feb-2020	1,273	1,305	32	32	2.5%	2.5%	2.5%
26-Feb-2020	1,246	1,330	84	84	6.7%	6.7%	6.3%
27-Feb-2020	1,399	1,450	51	51	3.6%	3.6%	3.5%
28-Feb-2020	1,403	1,440	37	37	2.6%	2.6%	2.6%
29-Feb-2020	1,241	1,280	39	39	3.1%	3.1%	3.0%
Minimum	1,241	1,280	-78	7	-5.2%	0.5%	-5.5%
Average	1,433	1,470	37	44	2.6%	3.1%	2.5%
Maximum	1,656	1,705	136	136	8.9%	8.9%	8.2%
1-Mar-2020	1,353	1,365	12	12	0.9%	0.9%	0.9%
2-Mar-2020	1,356	1,415	59	59	4.4%	4.4%	4.2%
3-Mar-2020	1,488	1,530	42	42	2.8%	2.8%	2.7%
4-Mar-2020	1,226	1,270	44	44	3.6%	3.6%	3.5%
5-Mar-2020	1,334	1,320	-14	14	-1.0%	1.0%	-1.1%

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
6-Mar-2020	1,309	1,360	51	51	3.9%	3.9%	3.8%
7-Mar-2020	1,411	1,390	-21	21	-1.5%	1.5%	-1.5%
8-Mar-2020	1,348	1,375	27	27	2.0%	2.0%	2.0%
9-Mar-2020	1,465	1,590	125	125	8.5%	8.5%	7.9%
10-Mar-2020	1,647	1,650	3	3	0.2%	0.2%	0.2%
11-Mar-2020	1,449	1,430	-19	19	-1.3%	1.3%	-1.3%
12-Mar-2020	1,358	1,380	22	22	1.6%	1.6%	1.6%
13-Mar-2020	1,455	1,440	-15	15	-1.0%	1.0%	-1.0%
14-Mar-2020	1,395	1,385	-10	10	-0.7%	0.7%	-0.7%
15-Mar-2020	1,296	1,350	54	54	4.2%	4.2%	4.0%
16-Mar-2020	1,459	1,465	6	6	0.4%	0.4%	0.4%
17-Mar-2020	1,561	1,540	-21	21	-1.3%	1.3%	-1.4%
18-Mar-2020	1,302	1,375	73	73	5.6%	5.6%	5.3%
19-Mar-2020	1,329	1,390	61	61	4.6%	4.6%	4.4%
20-Mar-2020	1,391	1,385	-6	6	-0.4%	0.4%	-0.4%
21-Mar-2020	1,216	1,245	29	29	2.4%	2.4%	2.3%
22-Mar-2020	1,376	1,445	69	69	5.0%	5.0%	4.8%
23-Mar-2020	1,437	1,515	78	78	5.4%	5.4%	5.1%
24-Mar-2020	1,332	1,380	48	48	3.6%	3.6%	3.5%
25-Mar-2020	1,301	1,320	19	19	1.5%	1.5%	1.4%
26-Mar-2020	1,298	1,345	47	47	3.6%	3.6%	3.5%
27-Mar-2020	1,302	1,290	-12	12	-0.9%	0.9%	-0.9%
28-Mar-2020	1,161	1,185	24	24	2.1%	2.1%	2.0%
29-Mar-2020	1,276	1,260	-16	16	-1.3%	1.3%	-1.3%
30-Mar-2020	1,316	1,325	9	9	0.7%	0.7%	0.7%
31-Mar-2020	1,173	1,220	47	47	4.0%	4.0%	3.9%
Minimum	1,161	1,185	-21	3	-1.5%	0.2%	-1.5%
Average	1,359	1,385	26	35	2.0%	2.6%	1.9%
Maximum	1,647	1,650	125	125	8.5%	8.5%	7.9%
1-Apr-2020	1,086	1,155	69	69	6.4%	6.4%	6.0%
2-Apr-2020	1,032	1,115	83	83	8.0%	8.0%	7.4%
3-Apr-2020	1,181	1,185	4	4	0.3%	0.3%	0.3%
4-Apr-2020	1,169	1,160	-9	9	-0.8%	0.8%	-0.8%
5-Apr-2020	1,168	1,165	-3	3	-0.3%	0.3%	-0.3%
6-Apr-2020	1,167	1,250	83	83	7.1%	7.1%	6.6%
7-Apr-2020	1,179	1,200	21	21	1.8%	1.8%	1.8%
8-Apr-2020	1,191	1,255	64	64	5.4%	5.4%	5.1%

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
9-Apr-2020	1,176	1,220	44	44	3.7%	3.7%	3.6%
10-Apr-2020	1,260	1,280	20	20	1.6%	1.6%	1.6%
11-Apr-2020	1,046	1,080	34	34	3.3%	3.3%	3.1%
12-Apr-2020	1,046	1,025	-21	21	-2.0%	2.0%	-2.0%
13-Apr-2020	1,049	1,100	51	51	4.9%	4.9%	4.6%
14-Apr-2020	1,018	1,130	112	112	11.0%	11.0%	9.9%
15-Apr-2020	988	1,015	27	27	2.7%	2.7%	2.7%
16-Apr-2020	1,069	1,040	-29	29	-2.7%	2.7%	-2.8%
17-Apr-2020	1,156	1,160	4	4	0.3%	0.3%	0.3%
18-Apr-2020	1,055	1,080	25	25	2.4%	2.4%	2.3%
19-Apr-2020	1,317	1,220	-97	97	-7.4%	7.4%	-8.0%
20-Apr-2020	1,113	1,120	7	7	0.6%	0.6%	0.6%
21-Apr-2020	1,122	1,150	28	28	2.5%	2.5%	2.4%
22-Apr-2020	1,050	1,115	65	65	6.2%	6.2%	5.8%
23-Apr-2020	1,051	1,055	4	4	0.4%	0.4%	0.4%
24-Apr-2020	1,042	1,075	33	33	3.2%	3.2%	3.1%
25-Apr-2020	1,068	1,085	17	17	1.6%	1.6%	1.6%
26-Apr-2020	973	1,020	47	47	4.8%	4.8%	4.6%
27-Apr-2020	1,044	1,065	21	21	2.0%	2.0%	2.0%
28-Apr-2020	1,074	1,115	41	41	3.8%	3.8%	3.7%
29-Apr-2020	1,119	1,145	26	26	2.3%	2.3%	2.3%
30-Apr-2020	1,100	1,090	-10	10	-0.9%	0.9%	-0.9%
Minimum	973	1,015	-97	3	-7.4%	0.3%	-8.0%
Average	1,104	1,129	25	37	2.4%	3.3%	2.2%
Maximum	1,317	1,280	112	112	11.0%	11.0%	9.9%
1-May-2020	871	960	89	89	10.2%	10.2%	9.3%
2-May-2020	873	920	47	47	5.4%	5.4%	5.1%
3-May-2020	987	945	-42	42	-4.3%	4.3%	-4.4%
4-May-2020	1,054	1,040	-14	14	-1.3%	1.3%	-1.3%
5-May-2020	1,150	1,145	-5	5	-0.4%	0.4%	-0.4%
6-May-2020	1,033	1,030	-3	3	-0.3%	0.3%	-0.3%
7-May-2020	1,062	1,055	-7	7	-0.7%	0.7%	-0.7%
8-May-2020	1,034	1,015	-19	19	-1.8%	1.8%	-1.9%
9-May-2020	952	920	-32	32	-3.4%	3.4%	-3.5%
10-May-2020	1,030	1,035	5	5	0.5%	0.5%	0.5%
11-May-2020	1,041	1,030	-11	11	-1.1%	1.1%	-1.1%
12-May-2020	1,070	1,000	-70	70	-6.5%	6.5%	-7.0%

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
13-May-2020	1,036	1,025	-11	11	-1.1%	1.1%	-1.1%
14-May-2020	1,036	1,075	39	39	3.8%	3.8%	3.6%
15-May-2020	1,067	1,050	-17	17	-1.6%	1.6%	-1.6%
16-May-2020	928	985	57	57	6.1%	6.1%	5.8%
17-May-2020	1,015	1,015	0	0	0.0%	0.0%	0.0%
18-May-2020	949	990	41	41	4.3%	4.3%	4.1%
19-May-2020	1,038	1,055	17	17	1.6%	1.6%	1.6%
20-May-2020	1,011	1,040	29	29	2.9%	2.9%	2.8%
21-May-2020	889	905	16	16	1.8%	1.8%	1.8%
22-May-2020	855	895	40	40	4.7%	4.7%	4.5%
23-May-2020	927	965	38	38	4.1%	4.1%	3.9%
24-May-2020	854	965	111	111	13.0%	13.0%	11.5%
25-May-2020	901	890	-11	11	-1.2%	1.2%	-1.2%
26-May-2020	823	850	27	27	3.3%	3.3%	3.2%
27-May-2020	817	835	18	18	2.2%	2.2%	2.2%
28-May-2020	841	830	-11	11	-1.3%	1.3%	-1.3%
29-May-2020	725	770	45	45	6.2%	6.2%	5.8%
30-May-2020	713	730	17	17	2.4%	2.4%	2.3%
31-May-2020	715	735	20	20	2.8%	2.8%	2.7%
Minimum	713	730	-70	0	-6.5%	0.0%	-7.0%
Average	945	958	13	29	1.6%	3.2%	1.4%
Maximum	1,150	1,145	111	111	13.0%	13.0%	11.5%
1-Jun-2020	815	800	-15	15	-1.8%	1.8%	-1.9%
2-Jun-2020	891	840	-51	51	-5.7%	5.7%	-6.1%
3-Jun-2020	862	845	-17	17	-2.0%	2.0%	-2.0%
4-Jun-2020	846	865	19	19	2.2%	2.2%	2.2%
5-Jun-2020	767	820	53	53	6.9%	6.9%	6.5%
6-Jun-2020	746	795	49	49	6.6%	6.6%	6.2%
7-Jun-2020	895	880	-15	15	-1.7%	1.7%	-1.7%
8-Jun-2020	932	890	-42	42	-4.5%	4.5%	-4.7%
9-Jun-2020	957	995	38	38	4.0%	4.0%	3.8%
10-Jun-2020	869	910	41	41	4.7%	4.7%	4.5%
11-Jun-2020	829	850	21	21	2.5%	2.5%	2.5%
12-Jun-2020	726	840	114	114	15.7%	15.7%	13.6%
13-Jun-2020	696	735	39	39	5.6%	5.6%	5.3%
14-Jun-2020	778	785	7	7	0.9%	0.9%	0.9%
15-Jun-2020	844	845	1	1	0.1%	0.1%	0.1%

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
16-Jun-2020	774	775	1	1	0.1%	0.1%	0.1%
17-Jun-2020	763	810	47	47	6.2%	6.2%	5.8%
18-Jun-2020	780	755	-25	25	-3.2%	3.2%	-3.3%
19-Jun-2020	750	790	40	40	5.3%	5.3%	5.1%
20-Jun-2020	816	830	14	14	1.7%	1.7%	1.7%
21-Jun-2020	768	780	12	12	1.6%	1.6%	1.5%
22-Jun-2020	790	790	0	0	0.0%	0.0%	0.0%
23-Jun-2020	740	770	30	30	4.1%	4.1%	3.9%
24-Jun-2020	748	745	-3	3	-0.4%	0.4%	-0.4%
25-Jun-2020	720	755	35	35	4.9%	4.9%	4.6%
26-Jun-2020	738	740	2	2	0.3%	0.3%	0.3%
27-Jun-2020	691	705	14	14	2.0%	2.0%	2.0%
28-Jun-2020	717	695	-22	22	-3.1%	3.1%	-3.2%
29-Jun-2020	750	835	85	85	11.3%	11.3%	10.2%
30-Jun-2020	769	800	31	31	4.0%	4.0%	3.9%
Minimum	691	695	-51	0	-5.7%	0.0%	-6.1%
Average	792	809	17	29	2.3%	3.8%	2.0%
Maximum	957	995	114	114	15.7%	15.7%	13.6%
1-Jul-2020	751	770	19	19	2.5%	2.5%	2.5%
2-Jul-2020	741	790	49	49	6.6%	6.6%	6.2%
3-Jul-2020	805	790	-15	15	-1.9%	1.9%	-1.9%
4-Jul-2020	739	760	21	21	2.8%	2.8%	2.8%
5-Jul-2020	741	750	9	9	1.2%	1.2%	1.2%
6-Jul-2020	743	780	37	37	5.0%	5.0%	4.7%
7-Jul-2020	704	750	46	46	6.5%	6.5%	6.1%
8-Jul-2020	669	745	76	76	11.4%	11.4%	10.2%
9-Jul-2020	719	750	31	31	4.3%	4.3%	4.1%
10-Jul-2020	708	740	32	32	4.5%	4.5%	4.3%
11-Jul-2020	677	695	18	18	2.7%	2.7%	2.6%
12-Jul-2020	681	695	14	14	2.1%	2.1%	2.0%
13-Jul-2020	709	755	46	46	6.5%	6.5%	6.1%
14-Jul-2020	691	740	49	49	7.1%	7.1%	6.6%
15-Jul-2020	806	770	-36	36	-4.5%	4.5%	-4.7%
16-Jul-2020	856	815	-41	41	-4.8%	4.8%	-5.0%
17-Jul-2020	775	775	0	0	0.0%	0.0%	0.0%
18-Jul-2020	677	740	63	63	9.3%	9.3%	8.5%
19-Jul-2020	651	730	79	79	12.1%	12.1%	10.8%

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
20-Jul-2020	725	755	30	30	4.1%	4.1%	4.0%
21-Jul-2020	806	745	-61	61	-7.6%	7.6%	-8.2%
22-Jul-2020	745	735	-10	10	-1.3%	1.3%	-1.4%
23-Jul-2020	699	730	31	31	4.4%	4.4%	4.2%
24-Jul-2020	711	740	29	29	4.1%	4.1%	3.9%
25-Jul-2020	660	695	35	35	5.3%	5.3%	5.0%
26-Jul-2020	703	710	7	7	1.0%	1.0%	1.0%
27-Jul-2020	724	750	26	26	3.6%	3.6%	3.5%
28-Jul-2020	702	735	33	33	4.7%	4.7%	4.5%
29-Jul-2020	708	735	27	27	3.8%	3.8%	3.7%
30-Jul-2020	727	765	38	38	5.2%	5.2%	5.0%
31-Jul-2020	710	730	20	20	2.8%	2.8%	2.7%
Minimum	651	695	-61	0	-7.6%	0.0%	-8.2%
Average	725	747	23	33	3.3%	4.6%	3.1%
Maximum	856	815	79	79	12.1%	12.1%	10.8%
1-Aug-2020	671	725	54	54	8.0%	8.0%	7.4%
2-Aug-2020	680	715	35	35	5.1%	5.1%	4.9%
3-Aug-2020	608	645	37	37	6.1%	6.1%	5.7%
4-Aug-2020	648	650	2	2	0.3%	0.3%	0.3%
5-Aug-2020	606	615	9	9	1.5%	1.5%	1.5%
6-Aug-2020	639	625	-14	14	-2.2%	2.2%	-2.2%
7-Aug-2020	624	625	1	1	0.2%	0.2%	0.2%
8-Aug-2020	590	585	-5	5	-0.8%	0.8%	-0.9%
9-Aug-2020	606	700	94	94	15.5%	15.5%	13.4%
10-Aug-2020	669	755	86	86	12.9%	12.9%	11.4%
11-Aug-2020	693	745	52	52	7.5%	7.5%	7.0%
12-Aug-2020	719	745	26	26	3.6%	3.6%	3.5%
13-Aug-2020	733	750	17	17	2.3%	2.3%	2.3%
14-Aug-2020	703	735	32	32	4.6%	4.6%	4.4%
15-Aug-2020	650	710	60	60	9.2%	9.2%	8.5%
16-Aug-2020	674	685	11	11	1.6%	1.6%	1.6%
17-Aug-2020	718	740	22	22	3.1%	3.1%	3.0%
18-Aug-2020	689	730	41	41	6.0%	6.0%	5.6%
19-Aug-2020	694	715	21	21	3.0%	3.0%	2.9%
20-Aug-2020	711	720	9	9	1.3%	1.3%	1.3%
21-Aug-2020	688	725	37	37	5.4%	5.4%	5.1%
22-Aug-2020	672	685	13	13	1.9%	1.9%	1.9%

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
23-Aug-2020	679	685	6	6	0.9%	0.9%	0.9%
24-Aug-2020	725	735	10	10	1.4%	1.4%	1.4%
25-Aug-2020	695	720	25	25	3.6%	3.6%	3.5%
26-Aug-2020	733	765	32	32	4.4%	4.4%	4.2%
27-Aug-2020	673	740	67	67	10.0%	10.0%	9.1%
28-Aug-2020	673	725	52	52	7.7%	7.7%	7.2%
29-Aug-2020	654	695	41	41	6.3%	6.3%	5.9%
30-Aug-2020	745	760	15	15	2.0%	2.0%	2.0%
31-Aug-2020	745	765	20	20	2.7%	2.7%	2.6%
Minimum	590	585	-14	1	-2.2%	0.2%	-2.2%
Average	678	707	29	31	4.4%	4.5%	4.0%
Maximum	745	765	94	94	15.5%	15.5%	13.4%
1-Sep-2020	685	735	50	50	7.3%	7.3%	6.8%
2-Sep-2020	696	710	14	14	2.0%	2.0%	2.0%
3-Sep-2020	710	685	-25	25	-3.5%	3.5%	-3.6%
4-Sep-2020	717	730	13	13	1.8%	1.8%	1.8%
5-Sep-2020	695	700	5	5	0.7%	0.7%	0.7%
6-Sep-2020	681	680	-1	1	-0.1%	0.1%	-0.1%
7-Sep-2020	688	705	17	17	2.5%	2.5%	2.4%
8-Sep-2020	773	715	-58	58	-7.5%	7.5%	-8.1%
9-Sep-2020	794	690	-104	104	-13.1%	13.1%	-15.1%
10-Sep-2020	769	755	-14	14	-1.8%	1.8%	-1.9%
11-Sep-2020	713	795	82	82	11.5%	11.5%	10.3%
12-Sep-2020	711	730	19	19	2.7%	2.7%	2.6%
13-Sep-2020	720	725	5	5	0.7%	0.7%	0.7%
14-Sep-2020	756	770	14	14	1.9%	1.9%	1.8%
15-Sep-2020	722	760	38	38	5.3%	5.3%	5.0%
16-Sep-2020	767	770	3	3	0.4%	0.4%	0.4%
17-Sep-2020	743	740	-3	3	-0.4%	0.4%	-0.4%
18-Sep-2020	763	745	-18	18	-2.4%	2.4%	-2.4%
19-Sep-2020	760	770	10	10	1.3%	1.3%	1.3%
20-Sep-2020	789	790	1	1	0.1%	0.1%	0.1%
21-Sep-2020	838	855	17	17	2.0%	2.0%	2.0%
22-Sep-2020	820	835	15	15	1.8%	1.8%	1.8%
23-Sep-2020	747	780	33	33	4.4%	4.4%	4.2%
24-Sep-2020	724	755	31	31	4.3%	4.3%	4.1%
25-Sep-2020	733	760	27	27	3.7%	3.7%	3.6%

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
26-Sep-20	743	750	7	7	0.9%	0.9%	0.9%
27-Sep-20	714	720	6	6	0.8%	0.8%	0.8%
28-Sep-20	734	755	21	21	2.9%	2.9%	2.8%
29-Sep-20	732	735	3	3	0.4%	0.4%	0.4%
30-Sep-20	739	735	-4	4	-0.5%	0.5%	-0.5%
Minimum	681	680	-104	1	-13.1%	0.1%	-15.1%
Average	739	746	7	22	1.0%	3.0%	0.8%
Maximum	838	855	82	104	11.5%	13.1%	10.3%
1-Oct-2020	664	730	66	66	9.9%	9.9%	9.0%
2-Oct-2020	696	710	14	14	2.0%	2.0%	2.0%
3-Oct-2020	726	710	-16	16	-2.2%	2.2%	-2.3%
4-Oct-2020	785	775	-10	10	-1.3%	1.3%	-1.3%
5-Oct-2020	856	845	-11	11	-1.3%	1.3%	-1.3%
6-Oct-2020	877	910	33	33	3.8%	3.8%	3.6%
7-Oct-2020	806	825	19	19	2.4%	2.4%	2.3%
8-Oct-2020	793	820	27	27	3.4%	3.4%	3.3%
9-Oct-2020	861	910	49	49	5.7%	5.7%	5.4%
10-Oct-2020	805	835	30	30	3.7%	3.7%	3.6%
11-Oct-2020	784	780	-4	4	-0.5%	0.5%	-0.5%
12-Oct-2020	850	850	0	0	0.0%	0.0%	0.0%
13-Oct-2020	938	930	-8	8	-0.9%	0.9%	-0.9%
14-Oct-2020	908	910	2	2	0.2%	0.2%	0.2%
15-Oct-2020	759	780	21	21	2.8%	2.8%	2.7%
16-Oct-2020	782	770	-12	12	-1.5%	1.5%	-1.6%
17-Oct-2020	748	720	-28	28	-3.7%	3.7%	-3.9%
18-Oct-2020	817	730	-87	87	-10.6%	10.6%	-11.9%
19-Oct-2020	849	865	16	16	1.9%	1.9%	1.8%
20-Oct-2020	834	860	26	26	3.1%	3.1%	3.0%
21-Oct-2020	786	850	64	64	8.1%	8.1%	7.5%
22-Oct-2020	812	860	48	48	5.9%	5.9%	5.6%
23-Oct-2020	902	945	43	43	4.8%	4.8%	4.6%
24-Oct-2020	922	915	-7	7	-0.8%	0.8%	-0.8%
25-Oct-2020	919	935	16	16	1.7%	1.7%	1.7%
26-Oct-2020	1,036	1,055	19	19	1.8%	1.8%	1.8%
27-Oct-2020	1,026	1,085	59	59	5.8%	5.8%	5.4%
28-Oct-2020	1,059	1,080	21	21	2.0%	2.0%	1.9%
29-Oct-2020	1,149	1,170	21	21	1.8%	1.8%	1.8%

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
30-Oct-2020	1,111	1,145	34	34	3.1%	3.1%	3.0%
31-Oct-2020	1,131	1,165	34	34	3.0%	3.0%	2.9%
Minimum	664	710	-87	0	-10.6%	0.0%	-11.9%
Average	871	886	15	27	1.7%	3.2%	1.6%
Maximum	1,149	1,170	66	87	9.9%	10.6%	9.0%
1-Nov-2020	1,081	1,080	-1	1	-0.1%	0.1%	-0.1%
2-Nov-2020	1,034	1,020	-14	14	-1.4%	1.4%	-1.4%
3-Nov-2020	1,073	1,080	7	7	0.7%	0.7%	0.6%
4-Nov-2020	1,257	1,310	53	53	4.2%	4.2%	4.0%
5-Nov-2020	1,218	1,270	52	52	4.3%	4.3%	4.1%
6-Nov-2020	1,033	1,075	42	42	4.1%	4.1%	3.9%
7-Nov-2020	1,002	1,000	-2	2	-0.2%	0.2%	-0.2%
8-Nov-2020	1,084	1,105	21	21	1.9%	1.9%	1.9%
9-Nov-2020	1,182	1,190	8	8	0.7%	0.7%	0.7%
10-Nov-2020	994	1,050	56	56	5.6%	5.6%	5.3%
11-Nov-2020	1,015	1,055	40	40	3.9%	3.9%	3.8%
12-Nov-2020	933	955	22	22	2.4%	2.4%	2.3%
13-Nov-2020	1,021	1,005	-16	16	-1.6%	1.6%	-1.6%
14-Nov-2020	1,242	1,170	-72	72	-5.8%	5.8%	-6.2%
15-Nov-2020	1,154	1,220	66	66	5.7%	5.7%	5.4%
16-Nov-2020	1,202	1,195	-7	7	-0.6%	0.6%	-0.6%
17-Nov-2020	1,029	1,095	66	66	6.4%	6.4%	6.0%
18-Nov-2020	1,147	1,120	-27	27	-2.4%	2.4%	-2.4%
19-Nov-2020	1,346	1,245	-101	101	-7.5%	7.5%	-8.1%
20-Nov-2020	1,265	1,285	20	20	1.6%	1.6%	1.6%
21-Nov-2020	1,098	1,085	-13	13	-1.2%	1.2%	-1.2%
22-Nov-2020	1,290	1,265	-25	25	-1.9%	1.9%	-2.0%
23-Nov-2020	1,353	1,365	12	12	0.9%	0.9%	0.9%
24-Nov-2020	1,138	1,150	12	12	1.1%	1.1%	1.0%
25-Nov-2020	1,329	1,355	26	26	2.0%	2.0%	1.9%
26-Nov-2020	1,252	1,245	-7	7	-0.6%	0.6%	-0.6%
27-Nov-2020	1,096	1,070	-26	26	-2.4%	2.4%	-2.4%
28-Nov-2020	989	985	-4	4	-0.4%	0.4%	-0.4%
29-Nov-2020	1,148	1,130	-18	18	-1.6%	1.6%	-1.6%
30-Nov-2020	1,219	1,195	-24	24	-2.0%	2.0%	-2.0%
Minimum	933	955	-101	1	-7.5%	0.1%	-8.1%
Average	1141	1146	5	29	0.5%	2.5%	0.4%

Date	Actual Total Peak (MW)	Forecast Total Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
Maximum	1,353	1,365	66	101	6.4%	7.5%	6.0%
1-Dec-2020	1,320	1,255	-65	65	-4.9%	4.9%	-5.2%
2-Dec-2020	1,375	1,400	25	25	1.8%	1.8%	1.8%
3-Dec-2020	1,313	1,365	52	52	4.0%	4.0%	3.8%
4-Dec-2020	1,171	1,205	34	34	2.9%	2.9%	2.8%
5-Dec-2020	1,229	1,235	6	6	0.5%	0.5%	0.5%
6-Dec-2020	1,229	1,275	46	46	3.7%	3.7%	3.6%
7-Dec-2020	1,320	1,335	15	15	1.1%	1.1%	1.1%
8-Dec-2020	1,400	1,390	-10	10	-0.7%	0.7%	-0.7%
9-Dec-2020	1,351	1,410	59	59	4.4%	4.4%	4.2%
10-Dec-2020	1,128	1,210	82	82	7.3%	7.3%	6.8%
11-Dec-2020	1,195	1,260	65	65	5.4%	5.4%	5.2%
12-Dec-2020	1,437	1,405	-32	32	-2.2%	2.2%	-2.3%
13-Dec-2020	1,564	1,565	1	1	0.1%	0.1%	0.1%
14-Dec-2020	1,386	1,425	39	39	2.8%	2.8%	2.7%
15-Dec-2020	1,171	1,230	59	59	5.0%	5.0%	4.8%
16-Dec-2020	1,486	1,470	-16	16	-1.1%	1.1%	-1.1%
17-Dec-2020	1,492	1,570	78	78	5.2%	5.2%	5.0%
18-Dec-2020	1,451	1,505	54	54	3.7%	3.7%	3.6%
19-Dec-2020	1,398	1,510	112	112	8.0%	8.0%	7.4%
20-Dec-2020	1,419	1,440	21	21	1.5%	1.5%	1.5%
21-Dec-2020	1,365	1,390	25	25	1.8%	1.8%	1.8%
22-Dec-2020	1,477	1,500	23	23	1.6%	1.6%	1.5%
23-Dec-2020	1,500	1,495	-5	5	-0.3%	0.3%	-0.3%
24-Dec-2020	1,352	1,420	68	68	5.0%	5.0%	4.8%
25-Dec-2020	1,322	1,305	-17	17	-1.3%	1.3%	-1.3%
26-Dec-2020	1,359	1,360	1	1	0.1%	0.1%	0.1%
27-Dec-2020	1,344	1,380	36	36	2.7%	2.7%	2.6%
28-Dec-2020	1,321	1,315	-6	6	-0.5%	0.5%	-0.5%
29-Dec-2020	1,303	1,305	2	2	0.2%	0.2%	0.2%
30-Dec-2020	1,352	1,425	73	73	5.4%	5.4%	5.1%
31-Dec-2020	1,316	1,355	39	39	3.0%	3.0%	2.9%
Minimum	1,128	1,205	-65	1	-4.9%	0.1%	-5.2%
Average	1,350	1,378	28	38	2.1%	2.8%	2.0%
Maximum	1,564	1,570	112	112	8.0%	8.0%	7.4%

Table 3: Analysis of Utility Forecast Error²³

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
1-Jan-2020	1,218	1,149	-69	69	-5.6%	5.6%	-6.0%
2-Jan-2020	1,193	1,035	-158	158	-13.2%	13.2%	-15.3%
3-Jan-2020	1,204	1,066	-137	137	-11.4%	11.4%	-12.9%
4-Jan-2020	1,153	1,157	4	4	0.4%	0.4%	0.4%
5-Jan-2020	1,223	1,225	2	2	0.1%	0.1%	0.1%
6-Jan-2020	1,280	1,314	34	34	2.7%	2.7%	2.6%
7-Jan-2020	1,233	1,233	0	0	0.0%	0.0%	0.0%
8-Jan-2020	1,281	1,235	-46	46	-3.6%	3.6%	-3.7%
9-Jan-2020	1,313	1,343	30	30	2.3%	2.3%	2.3%
10-Jan-2020	1,461	1,439	-22	22	-1.5%	1.5%	-1.5%
11-Jan-2020	1,179	1,173	-5	5	-0.4%	0.4%	-0.4%
12-Jan-2020	1,311	1,317	6	6	0.5%	0.5%	0.5%
13-Jan-2020	1,363	1,346	-17	17	-1.3%	1.3%	-1.3%
14-Jan-2020	1,397	1,395	-2	2	-0.1%	0.1%	-0.1%
15-Jan-2020	1,484	1,472	-12	12	-0.8%	0.8%	-0.8%
16-Jan-2020	1,368	1,366	-2	2	-0.2%	0.2%	-0.2%
17-Jan-2020	1,413	1,334	-78	78	-5.5%	5.5%	-5.9%
18-Jan-2020	1,414	1,443	30	30	2.1%	2.1%	2.1%
19-Jan-2020	1,419	1,367	-53	53	-3.7%	3.7%	-3.8%
20-Jan-2020	1,264	1,205	-59	59	-4.7%	4.7%	-4.9%
21-Jan-2020	1,351	1,267	-84	84	-6.2%	6.2%	-6.6%
22-Jan-2020	1,440	1,423	-18	18	-1.2%	1.2%	-1.2%
23-Jan-2020	1,317	1,292	-24	24	-1.8%	1.8%	-1.9%
24-Jan-2020	1,190	1,213	23	23	1.9%	1.9%	1.9%
25-Jan-2020	1,313	1,280	-33	33	-2.5%	2.5%	-2.6%
26-Jan-2020	1,237	1,216	-20	20	-1.6%	1.6%	-1.7%
27-Jan-2020	1,137	1,139	2	2	0.2%	0.2%	0.2%
28-Jan-2020	1,182	1,136	-46	46	-3.9%	3.9%	-4.0%
29-Jan-2020	1,190	1,210	20	20	1.7%	1.7%	1.7%
30-Jan-2020	1,201	1,214	13	13	1.1%	1.1%	1.1%
31-Oct-2016	1,288	1,288	0	0	0.0%	0.0%	0.0%
Minimum	1,137	1,035	-158	0	-13.2%	0.0%	-15.3%
Average	1,291	1,268	-23	34	-1.8%	2.7%	-2.0%
Maximum	1,484	1,472	34	158	2.7%	13.2%	2.6%

²³ Lines that have been bolded indicate further examination of the hourly forecast was provided in this report.

Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report
Appendix A

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
1-Feb-2020	1,274	1,283	8	8	0.6%	0.6%	0.6%
2-Feb-2020	1,343	1,226	-116	116	-8.7%	8.7%	-9.5%
3-Feb-2020	1,274	1,304	29	29	2.3%	2.3%	2.2%
4-Feb-2020	1,241	1,245	4	4	0.3%	0.3%	0.3%
5-Feb-2020	1,261	1,263	1	1	0.1%	0.1%	0.1%
6-Feb-2020	1,358	1,365	6	6	0.5%	0.5%	0.5%
7-Feb-2020	1,248	1,240	-9	9	-0.7%	0.7%	-0.7%
8-Feb-2020	1,248	1,292	43	43	3.5%	3.5%	3.4%
9-Feb-2020	1,476	1,494	18	18	1.2%	1.2%	1.2%
10-Feb-2020	1,426	1,412	-14	14	-1.0%	1.0%	-1.0%
11-Feb-2020	1,497	1,515	18	18	1.2%	1.2%	1.2%
12-Feb-2020	1,347	1,358	10	10	0.8%	0.8%	0.8%
13-Feb-2020	1,105	1,133	28	28	2.5%	2.5%	2.4%
14-Feb-2020	1,219	1,234	15	15	1.2%	1.2%	1.2%
15-Feb-2020	1,120	1,119	-1	1	-0.1%	0.1%	-0.1%
16-Feb-2020	1,092	1,142	49	49	4.5%	4.5%	4.3%
17-Feb-2020	1,222	1,261	39	39	3.2%	3.2%	3.1%
18-Feb-2020	1,250	1,252	2	2	0.2%	0.2%	0.2%
19-Feb-2020	1,277	1,259	-18	18	-1.4%	1.4%	-1.5%
20-Feb-2020	1,366	1,363	-2	2	-0.2%	0.2%	-0.2%
21-Feb-2020	1,174	1,170	-4	4	-0.4%	0.4%	-0.4%
22-Feb-2020	1,250	1,247	-4	4	-0.3%	0.3%	-0.3%
23-Feb-2020	1,288	1,287	-1	1	-0.1%	0.1%	-0.1%
24-Feb-2020	1,476	1,494	18	18	1.2%	1.2%	1.2%
25-Feb-2020	1,437	1,474	37	37	2.6%	2.6%	2.5%
26-Feb-2020	1,317	1,258	-59	59	-4.5%	4.5%	-4.7%
27-Feb-2020	1,142	1,164	22	22	1.9%	1.9%	1.9%
28-Feb-2020	1,290	1,308	17	17	1.4%	1.4%	1.3%
29-Feb-2020	1,290	1,308	17	17	1.4%	1.4%	1.3%
Minimum	1,092	1,119	-116	1	-8.7%	0.1%	-9.5%
Average	1,287	1,292	5	21	0.5%	1.6%	0.4%
Maximum	1,497	1,515	49	116	4.5%	8.7%	4.3%
1-Mar-2020	1,203	1,177	-25	25	-2.1%	2.1%	-2.1%
2-Mar-2020	1,195	1,229	35	35	2.9%	2.9%	2.8%
3-Mar-2020	1,308	1,342	34	34	2.6%	2.6%	2.5%
4-Mar-2020	1,094	1,085	-9	9	-0.8%	0.8%	-0.9%
5-Mar-2020	1,166	1,133	-33	33	-2.8%	2.8%	-2.9%
6-Mar-2020	1,161	1,176	15	15	1.3%	1.3%	1.3%

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
7-Mar-2020	1,243	1,203	-40	40	-3.2%	3.2%	-3.3%
8-Mar-2020	1,181	1,188	8	8	0.7%	0.7%	0.6%
9-Mar-2020	1,311	1,402	91	91	7.0%	7.0%	6.5%
10-Mar-2020	1,496	1,465	-31	31	-2.1%	2.1%	-2.1%
11-Mar-2020	1,077	1,060	-18	18	-1.6%	1.6%	-1.7%
12-Mar-2020	1,195	1,258	62	62	5.2%	5.2%	4.9%
13-Mar-2020	1,270	1,281	11	11	0.8%	0.8%	0.8%
14-Mar-2020	1,152	1,191	40	40	3.5%	3.5%	3.3%
15-Mar-2020	1,129	1,135	6	6	0.5%	0.5%	0.5%
16-Mar-2020	1,122	1,157	34	34	3.1%	3.1%	3.0%
17-Mar-2020	1,141	1,102	-39	39	-3.4%	3.4%	-3.6%
18-Mar-2020	992	1,000	9	9	0.9%	0.9%	0.9%
19-Mar-2020	1,090	1,072	-17	17	-1.6%	1.6%	-1.6%
20-Mar-2020	1,133	1,136	3	3	0.3%	0.3%	0.3%
21-Mar-2020	1,282	1,241	-41	41	-3.2%	3.2%	-3.3%
22-Mar-2020	1,193	1,191	-3	3	-0.2%	0.2%	-0.2%
23-Mar-2020	1,272	1,253	-18	18	-1.4%	1.4%	-1.5%
24-Mar-2020	1,229	1,198	-31	31	-2.5%	2.5%	-2.6%
25-Mar-2020	1,126	1,164	38	38	3.4%	3.4%	3.3%
26-Mar-2020	1,274	1,276	2	2	0.2%	0.2%	0.2%
27-Mar-2020	1,373	1,355	-18	18	-1.3%	1.3%	-1.3%
28-Mar-2020	1,155	1,188	33	33	2.8%	2.8%	2.7%
29-Mar-2020	1,178	1,205	27	27	2.3%	2.3%	2.2%
30-Mar-2020	1,211	1,198	-12	12	-1.0%	1.0%	-1.0%
31-Mar-2020	1,043	1,058	15	15	1.5%	1.5%	1.4%
Minimum	992	1,000	-41	2	-3.4%	0.2%	-3.6%
Average	1,193	1,197	4	26	0.4%	2.1%	0.3%
Maximum	1,496	1,465	91	91	7.0%	7.0%	6.5%
1-Apr-2020	951	984	34	34	3.5%	3.5%	3.4%
2-Apr-2020	946	954	8	8	0.8%	0.8%	0.8%
3-Apr-2020	1,044	1,020	-24	24	-2.3%	2.3%	-2.3%
4-Apr-2020	1,030	1,000	-30	30	-2.9%	2.9%	-3.0%
5-Apr-2020	1,034	1,004	-31	31	-3.0%	3.0%	-3.0%
6-Apr-2020	1,022	1,087	66	66	6.4%	6.4%	6.0%
7-Apr-2020	1,015	1,037	22	22	2.1%	2.1%	2.1%
8-Apr-2020	1,039	1,091	52	52	5.0%	5.0%	4.8%
9-Apr-2020	1,035	1,059	24	24	2.4%	2.4%	2.3%
10-Apr-2020	1,110	1,116	5	5	0.5%	0.5%	0.5%

Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report
Appendix A

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
11-Apr-2020	899	919	20	20	2.2%	2.2%	2.1%
12-Apr-2020	905	865	-40	40	-4.5%	4.5%	-4.7%
13-Apr-2020	901	939	38	38	4.3%	4.3%	4.1%
14-Apr-2020	889	968	79	79	8.9%	8.9%	8.2%
15-Apr-2020	833	854	21	21	2.5%	2.5%	2.5%
16-Apr-2020	926	877	-49	49	-5.3%	5.3%	-5.6%
17-Apr-2020	956	998	43	43	4.5%	4.5%	4.3%
18-Apr-2020	892	919	27	27	3.1%	3.1%	3.0%
19-Apr-2020	1,161	1,058	-103	103	-8.8%	8.8%	-9.7%
20-Apr-2020	989	956	-33	33	-3.3%	3.3%	-3.4%
21-Apr-2020	986	989	3	3	0.3%	0.3%	0.3%
22-Apr-2020	898	952	53	53	5.9%	5.9%	5.6%
23-Apr-2020	909	894	-15	15	-1.7%	1.7%	-1.7%
24-Apr-2020	927	912	-16	16	-1.7%	1.7%	-1.7%
25-Apr-2020	924	924	0	0	0.0%	0.0%	0.0%
26-Apr-2020	826	857	31	31	3.8%	3.8%	3.6%
27-Apr-2020	917	902	-15	15	-1.7%	1.7%	-1.7%
28-Apr-2020	941	954	13	13	1.4%	1.4%	1.4%
29-Apr-2020	995	984	-11	11	-1.2%	1.2%	-1.2%
30-Apr-2020	945	929	-16	16	-1.7%	1.7%	-1.7%
Minimum	826	854	-103	0	-8.8%	0.0%	-9.7%
Average	961	967	5	31	0.7%	3.2%	0.5%
Maximum	1161	1116	79	103	8.9%	8.9%	8.2%
1-May-2020	781	800	19	19	2.4%	2.4%	2.4%
2-May-2020	727	757	30	30	4.1%	4.1%	3.9%
3-May-2020	846	782	-65	65	-7.6%	7.6%	-8.3%
4-May-2020	919	877	-41	41	-4.5%	4.5%	-4.7%
5-May-2020	1,049	981	-68	68	-6.5%	6.5%	-6.9%
6-May-2020	903	867	-36	36	-4.0%	4.0%	-4.1%
7-May-2020	866	891	24	24	2.8%	2.8%	2.7%
8-May-2020	865	854	-12	12	-1.4%	1.4%	-1.4%
9-May-2020	916	910	-6	6	-0.6%	0.6%	-0.6%
10-May-2020	884	878	-6	6	-0.6%	0.6%	-0.6%
11-May-2020	755	748	-7	7	-0.9%	0.9%	-0.9%
12-May-2020	738	733	-5	5	-0.6%	0.6%	-0.7%
13-May-2020	820	805	-15	15	-1.8%	1.8%	-1.9%
14-May-2020	727	801	74	74	10.2%	10.2%	9.2%
15-May-2020	714	730	16	16	2.2%	2.2%	2.1%

Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report
Appendix A

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
16-May-2020	695	687	-7	7	-1.0%	1.0%	-1.0%
17-May-2020	703	677	-26	26	-3.7%	3.7%	-3.9%
18-May-2020	701	669	-32	32	-4.6%	4.6%	-4.8%
19-May-2020	783	745	-38	38	-4.9%	4.9%	-5.2%
20-May-2020	881	875	-7	7	-0.7%	0.7%	-0.7%
21-May-2020	901	870	-30	30	-3.4%	3.4%	-3.5%
22-May-2020	906	838	-68	68	-7.5%	7.5%	-8.2%
23-May-2020	872	863	-9	9	-1.1%	1.1%	-1.1%
24-May-2020	885	910	26	26	2.9%	2.9%	2.8%
25-May-2020	916	888	-28	28	-3.0%	3.0%	-3.1%
26-May-2020	773	821	47	47	6.1%	6.1%	5.7%
27-May-2020	858	853	-5	5	-0.6%	0.6%	-0.6%
28-May-2020	803	826	23	23	2.8%	2.8%	2.7%
29-May-2020	906	891	-15	15	-1.6%	1.6%	-1.6%
30-May-2020	577	568	-8	8	-1.5%	1.5%	-1.5%
31-May-2020	596	573	-23	23	-3.9%	3.9%	-4.0%
Minimum	577	568	-68	5	-7.6%	0.6%	-8.3%
Average	815	805	-10	26	-1.1%	3.2%	-1.2%
Maximum	1049	981	74	74	10.2%	10.2%	9.2%
1-Jun-2020	650	639	-11	11	-1.7%	1.7%	-1.8%
2-Jun-2020	725	677	-48	48	-6.6%	6.6%	-7.1%
3-Jun-2020	688	659	-29	29	-4.2%	4.2%	-4.4%
4-Jun-2020	705	660	-45	45	-6.4%	6.4%	-6.8%
5-Jun-2020	608	616	7	7	1.2%	1.2%	1.2%
6-Jun-2020	570	590	20	20	3.5%	3.5%	3.4%
7-Jun-2020	675	666	-9	9	-1.3%	1.3%	-1.3%
8-Jun-2020	728	707	-21	21	-2.9%	2.9%	-3.0%
9-Jun-2020	740	743	4	4	0.5%	0.5%	0.5%
10-Jun-2020	746	746	0	0	0.0%	0.0%	0.0%
11-Jun-2020	628	616	-11	11	-1.8%	1.8%	-1.9%
12-Jun-2020	642	628	-14	14	-2.1%	2.1%	-2.2%
13-Jun-2020	598	606	8	8	1.4%	1.4%	1.4%
14-Jun-2020	602	584	-18	18	-3.0%	3.0%	-3.1%
15-Jun-2020	605	592	-13	13	-2.2%	2.2%	-2.2%
16-Jun-2020	597	576	-21	21	-3.5%	3.5%	-3.7%
17-Jun-2020	552	545	-7	7	-1.3%	1.3%	-1.3%
18-Jun-2020	569	533	-36	36	-6.3%	6.3%	-6.8%
19-Jun-2020	592	589	-3	3	-0.5%	0.5%	-0.5%

Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report
Appendix A

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
20-Jun-2020	585	584	-1	1	-0.2%	0.2%	-0.2%
21-Jun-2020	683	686	3	3	0.5%	0.5%	0.5%
22-Jun-2020	627	655	28	28	4.5%	4.5%	4.3%
23-Jun-2020	581	574	-7	7	-1.2%	1.2%	-1.2%
24-Jun-2020	634	622	-12	12	-1.9%	1.9%	-1.9%
25-Jun-2020	693	680	-13	13	-1.9%	1.9%	-1.9%
26-Jun-2020	605	614	9	9	1.5%	1.5%	1.5%
27-Jun-2020	591	592	1	1	0.2%	0.2%	0.2%
28-Jun-2020	592	591	-1	1	-0.2%	0.2%	-0.2%
29-Jun-2020	608	626	17	17	2.9%	2.9%	2.8%
30-Jun-2020	669	668	-1	1	-0.2%	0.2%	-0.2%
Minimum	552	533	-48	0	-6.6%	0.0%	-7.1%
Average	636	629	-7	14	-1.1%	2.2%	-1.2%
Maximum	746	746	28	48	4.5%	6.6%	4.3%
1-Jul-2020	570	566	-4	4	-0.7%	0.7%	-0.7%
2-Jul-2020	617	626	9	9	1.4%	1.4%	1.4%
3-Jul-2020	650	629	-20	20	-3.1%	3.1%	-3.2%
4-Jul-2020	592	598	6	6	1.0%	1.0%	1.0%
5-Jul-2020	608	587	-22	22	-3.5%	3.5%	-3.7%
6-Jul-2020	613	618	5	5	0.8%	0.8%	0.7%
7-Jul-2020	573	589	15	15	2.7%	2.7%	2.6%
8-Jul-2020	573	582	9	9	1.6%	1.6%	1.5%
9-Jul-2020	590	586	-4	4	-0.7%	0.7%	-0.7%
10-Jul-2020	578	576	-2	2	-0.3%	0.3%	-0.3%
11-Jul-2020	538	535	-3	3	-0.5%	0.5%	-0.5%
12-Jul-2020	549	534	-15	15	-2.6%	2.6%	-2.7%
13-Jul-2020	589	593	4	4	0.7%	0.7%	0.7%
14-Jul-2020	590	578	-12	12	-2.0%	2.0%	-2.0%
15-Jul-2020	704	609	-94	94	-13.4%	13.4%	-15.5%
16-Jul-2020	679	601	-78	78	-11.5%	11.5%	-12.9%
17-Jul-2020	650	615	-36	36	-5.5%	5.5%	-5.8%
18-Jul-2020	545	577	32	32	5.8%	5.8%	5.5%
19-Jul-2020	538	566	28	28	5.2%	5.2%	4.9%
20-Jul-2020	583	599	15	15	2.6%	2.6%	2.6%
21-Jul-2020	592	587	-5	5	-0.9%	0.9%	-0.9%
22-Jul-2020	573	572	0	0	-0.1%	0.1%	-0.1%
23-Jul-2020	572	569	-3	3	-0.5%	0.5%	-0.5%
24-Jul-2020	587	579	-9	9	-1.5%	1.5%	-1.5%

Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report
Appendix A

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
25-Jul-2020	540	534	-6	6	-1.0%	1.0%	-1.1%
26-Jul-2020	575	550	-25	25	-4.4%	4.4%	-4.6%
27-Jul-2020	588	586	-2	2	-0.3%	0.3%	-0.3%
28-Jul-2020	575	574	-1	1	-0.2%	0.2%	-0.2%
29-Jul-2020	576	573	-3	3	-0.5%	0.5%	-0.5%
30-Jul-2020	599	601	2	2	0.3%	0.3%	0.3%
31-Jul-2020	583	568	-15	15	-2.7%	2.7%	-2.7%
Minimum	538	534	-94	0	-13.4%	0.1%	-15.5%
Average	590	582	-7	16	-1.1%	2.5%	-1.3%
Maximum	704	629	32	94	5.8%	13.4%	5.5%
1-Aug-2020	545	561	16	16	2.9%	2.9%	2.8%
2-Aug-2020	559	551	-8	8	-1.4%	1.4%	-1.4%
3-Aug-2020	556	574	18	18	3.2%	3.2%	3.1%
4-Aug-2020	590	582	-9	9	-1.4%	1.4%	-1.5%
5-Aug-2020	551	548	-3	3	-0.6%	0.6%	-0.6%
6-Aug-2020	579	567	-12	12	-2.0%	2.0%	-2.0%
7-Aug-2020	573	567	-6	6	-1.0%	1.0%	-1.1%
8-Aug-2020	531	524	-7	7	-1.3%	1.3%	-1.3%
9-Aug-2020	548	536	-12	12	-2.3%	2.3%	-2.3%
10-Aug-2020	582	591	9	9	1.6%	1.6%	1.6%
11-Aug-2020	592	582	-10	10	-1.7%	1.7%	-1.7%
12-Aug-2020	589	581	-8	8	-1.4%	1.4%	-1.5%
13-Aug-2020	591	589	-2	2	-0.3%	0.3%	-0.3%
14-Aug-2020	579	572	-6	6	-1.1%	1.1%	-1.1%
15-Aug-2020	524	546	22	22	4.2%	4.2%	4.0%
16-Aug-2020	532	524	-8	8	-1.4%	1.4%	-1.4%
17-Aug-2020	566	578	12	12	2.1%	2.1%	2.1%
18-Aug-2020	585	567	-18	18	-3.0%	3.0%	-3.1%
19-Aug-2020	574	551	-22	22	-3.9%	3.9%	-4.0%
20-Aug-2020	569	558	-11	11	-1.9%	1.9%	-1.9%
21-Aug-2020	547	562	15	15	2.7%	2.7%	2.7%
22-Aug-2020	528	522	-5	5	-1.0%	1.0%	-1.1%
23-Aug-2020	526	518	-9	9	-1.6%	1.6%	-1.7%
24-Aug-2020	582	575	-7	7	-1.1%	1.1%	-1.1%
25-Aug-2020	558	560	2	2	0.3%	0.3%	0.3%
26-Aug-2020	616	603	-14	14	-2.2%	2.2%	-2.3%
27-Aug-2020	572	578	6	6	1.1%	1.1%	1.1%
28-Aug-2020	560	558	-2	2	-0.4%	0.4%	-0.4%

Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report
Appendix A

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
29-Aug-2020	524	535	11	11	2.0%	2.0%	2.0%
30-Aug-2020	603	598	-5	5	-0.9%	0.9%	-0.9%
31-Aug-2020	595	601	6	6	1.0%	1.0%	1.0%
Minimum	524	518	-22	2	-3.9%	0.3%	-4.0%
Average	565	563	-2	10	-0.4%	1.7%	-0.4%
Maximum	616	603	22	22	4.2%	4.2%	4.0%
1-Sep-2020	560	573	14	14	2.4%	2.4%	2.4%
2-Sep-2020	558	546	-12	12	-2.1%	2.1%	-2.2%
3-Sep-2020	581	550	-31	31	-5.3%	5.3%	-5.6%
4-Sep-2020	583	550	-33	33	-5.6%	5.6%	-5.9%
5-Sep-2020	553	539	-14	14	-2.6%	2.6%	-2.7%
6-Sep-2020	526	519	-7	7	-1.4%	1.4%	-1.4%
7-Sep-2020	539	545	6	6	1.1%	1.1%	1.1%
8-Sep-2020	573	551	-22	22	-3.9%	3.9%	-4.1%
9-Sep-2020	591	554	-37	37	-6.3%	6.3%	-6.7%
10-Sep-2020	639	616	-23	23	-3.6%	3.6%	-3.7%
11-Sep-2020	599	623	24	24	4.1%	4.1%	3.9%
12-Sep-2020	571	567	-4	4	-0.7%	0.7%	-0.7%
13-Sep-2020	588	565	-23	23	-3.9%	3.9%	-4.0%
14-Sep-2020	624	609	-14	14	-2.3%	2.3%	-2.4%
15-Sep-2020	621	599	-22	22	-3.6%	3.6%	-3.7%
16-Sep-2020	632	606	-26	26	-4.1%	4.1%	-4.3%
17-Sep-2020	590	576	-14	14	-2.4%	2.4%	-2.5%
18-Sep-2020	609	584	-25	25	-4.0%	4.0%	-4.2%
19-Sep-2020	609	606	-3	3	-0.5%	0.5%	-0.5%
20-Sep-2020	664	630	-34	34	-5.1%	5.1%	-5.4%
21-Sep-2020	706	692	-13	13	-1.9%	1.9%	-1.9%
22-Sep-2020	686	675	-11	11	-1.6%	1.6%	-1.6%
23-Sep-2020	617	617	-1	1	-0.1%	0.1%	-0.1%
24-Sep-2020	584	595	10	10	1.8%	1.8%	1.8%
25-Sep-2020	580	596	16	16	2.8%	2.8%	2.7%
26-Sep-2020	601	586	-15	15	-2.5%	2.5%	-2.6%
27-Sep-2020	586	559	-26	26	-4.5%	4.5%	-4.7%
28-Sep-2020	591	593	2	2	0.4%	0.4%	0.4%
29-Sep-2020	590	574	-15	15	-2.6%	2.6%	-2.7%
30-Sep-2020	586	571	-15	15	-2.5%	2.5%	-2.6%
Minimum	526	519	-34	1	-5.6%	0.1%	-5.9%
Average	597	586	-12	16	-1.9%	2.8%	-2.0%

Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report
Appendix A

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/ Forecast
Maximum	706	692	24	34	4.1%	5.6%	3.9%
1-Oct-2020	582	567	-15	15	-2.6%	2.6%	-2.7%
2-Oct-2020	558	550	-9	9	-1.5%	1.5%	-1.6%
3-Oct-2020	577	550	-27	27	-4.7%	4.7%	-5.0%
4-Oct-2020	634	617	-18	18	-2.8%	2.8%	-2.9%
5-Oct-2020	710	683	-28	28	-3.9%	3.9%	-4.1%
6-Oct-2020	747	745	-1	1	-0.2%	0.2%	-0.2%
7-Oct-2020	678	663	-15	15	-2.3%	2.3%	-2.3%
8-Oct-2020	654	657	3	3	0.4%	0.4%	0.4%
9-Oct-2020	742	746	4	4	0.5%	0.5%	0.5%
10-Oct-2020	711	718	6	6	0.9%	0.9%	0.9%
11-Oct-2020	678	665	-13	13	-1.9%	1.9%	-1.9%
12-Oct-2020	744	736	-7	7	-1.0%	1.0%	-1.0%
13-Oct-2020	833	814	-19	19	-2.2%	2.2%	-2.3%
14-Oct-2020	809	796	-13	13	-1.6%	1.6%	-1.7%
15-Oct-2020	653	666	13	13	1.9%	1.9%	1.9%
16-Oct-2020	661	653	-7	7	-1.1%	1.1%	-1.1%
17-Oct-2020	621	605	-16	16	-2.6%	2.6%	-2.7%
18-Oct-2020	635	613	-22	22	-3.4%	3.4%	-3.5%
19-Oct-2020	672	654	-18	18	-2.6%	2.6%	-2.7%
20-Oct-2020	693	644	-49	49	-7.1%	7.1%	-7.6%
21-Oct-2020	712	686	-26	26	-3.6%	3.6%	-3.8%
22-Oct-2020	696	700	5	5	0.6%	0.6%	0.6%
23-Oct-2020	780	782	1	1	0.2%	0.2%	0.2%
24-Oct-2020	774	754	-19	19	-2.5%	2.5%	-2.5%
25-Oct-2020	780	772	-9	9	-1.1%	1.1%	-1.2%
26-Oct-2020	912	892	-20	20	-2.2%	2.2%	-2.2%
27-Oct-2020	904	924	20	20	2.3%	2.3%	2.2%
28-Oct-2020	926	916	-10	10	-1.1%	1.1%	-1.1%
29-Oct-2020	984	1,009	24	24	2.5%	2.5%	2.4%
30-Oct-2020	957	981	25	25	2.6%	2.6%	2.5%
31-Oct-2020	983	1,000	18	18	1.8%	1.8%	1.8%
Minimum	558	550	-49	1	-7.1%	0.2%	-7.6%
Average	742	734	-8	15	-1.2%	2.1%	-1.3%
Maximum	984	1,009	25	49	2.6%	7.1%	2.5%
1-Nov-2020	924	920	-4	4	-0.5%	0.5%	-0.5%
2-Nov-2020	885	856	-30	30	-3.4%	3.4%	-3.5%

Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report
Appendix A

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
3-Nov-2020	922	916	-6	6	-0.7%	0.7%	-0.7%
4-Nov-2020	1,151	1,146	-5	5	-0.5%	0.5%	-0.5%
5-Nov-2020	1,073	1,107	33	33	3.1%	3.1%	3.0%
6-Nov-2020	872	9,14	42	42	4.9%	4.9%	4.6%
7-Nov-2020	856	839	-17	17	-1.9%	1.9%	-2.0%
8-Nov-2020	967	945	-22	22	-2.3%	2.3%	-2.4%
9-Nov-2020	1,046	1,026	-19	19	-1.9%	1.9%	-1.9%
10-Nov-2020	849	890	41	41	4.8%	4.8%	4.6%
11-Nov-2020	912	894	-18	18	-1.9%	1.9%	-2.0%
12-Nov-2020	784	795	11	11	1.4%	1.4%	1.4%
13-Nov-2020	878	845	-33	33	-3.7%	3.7%	-3.9%
14-Nov-2020	1,089	1,009	-80	80	-7.3%	7.3%	-7.9%
15-Nov-2020	1,000	1,060	60	60	6.0%	6.0%	5.7%
16-Nov-2020	1,062	1,034	-28	28	-2.7%	2.7%	-2.7%
17-Nov-2020	886	934	48	48	5.4%	5.4%	5.1%
18-Nov-2020	987	957	-30	30	-3.0%	3.0%	-3.1%
19-Nov-2020	1,152	1,084	-67	67	-5.8%	5.8%	-6.2%
20-Nov-2020	1,098	1,122	24	24	2.2%	2.2%	2.1%
21-Nov-2020	931	925	-5	5	-0.6%	0.6%	-0.6%
22-Nov-2020	1,126	1,101	-25	25	-2.2%	2.2%	-2.3%
23-Nov-2020	1,186	1,204	18	18	1.5%	1.5%	1.5%
24-Nov-2020	1,003	986	-18	18	-1.8%	1.8%	-1.8%
25-Nov-2020	1,183	1,191	8	8	0.7%	0.7%	0.7%
26-Nov-2020	1,104	1,082	-22	22	-2.0%	2.0%	-2.0%
27-Nov-2020	933	911	-22	22	-2.4%	2.4%	-2.5%
28-Nov-2020	831	825	-6	6	-0.8%	0.8%	-0.8%
29-Nov-2020	985	968	-17	17	-1.7%	1.7%	-1.8%
30-Nov-2020	1,043	1,033	-10	10	-1.0%	1.0%	-1.0%
Minimum	784	795	-80	4	-7.3%	0.5%	-7.9%
Average	991	984	-7	26	-0.6%	2.6%	-0.7%
Maximum	1,186	1,204	60	80	6.0%	7.4%	5.7%
1-Dec-2020	1,029	1,011	-18	18	-1.8%	1.8%	-1.8%
2-Dec-2020	873	914	41	41	4.7%	4.7%	4.5%
3-Dec-2020	823	877	54	54	6.6%	6.6%	6.2%
4-Dec-2020	912	858	-54	54	-5.9%	5.9%	-6.3%
5-Dec-2020	899	837	-63	63	-7.0%	7.0%	-7.5%
6-Dec-2020	943	965	22	22	2.3%	2.3%	2.2%
7-Dec-2020	919	969	50	50	5.5%	5.5%	5.2%

Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report
Appendix A

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
8-Dec-2020	1,029	977	-52	52	-5.0%	5.0%	-5.3%
9-Dec-2020	1,109	1,203	94	94	8.4%	8.4%	7.8%
10-Dec-2020	1,067	1,086	19	19	1.8%	1.8%	1.8%
11-Dec-2020	1,101	1,151	50	50	4.5%	4.5%	4.3%
12-Dec-2020	1,078	1,103	25	25	2.3%	2.3%	2.3%
13-Dec-2020	1,225	1,212	-13	13	-1.0%	1.0%	-1.0%
14-Dec-2020	1,213	1,233	19	19	1.6%	1.6%	1.6%
15-Dec-2020	1,203	1,213	10	10	0.8%	0.8%	0.8%
16-Dec-2020	1,331	1,318	-13	13	-1.0%	1.0%	-1.0%
17-Dec-2020	1,237	1,205	-32	32	-2.6%	2.6%	-2.7%
18-Dec-2020	1,199	1,164	-35	35	-2.9%	2.9%	-3.0%
19-Dec-2020	1,174	1,184	10	10	0.8%	0.8%	0.8%
20-Dec-2020	1,216	1,207	-9	9	-0.8%	0.8%	-0.8%
21-Dec-2020	1,193	1,198	5	5	0.5%	0.5%	0.4%
22-Dec-2020	1,037	1,124	87	87	8.4%	8.4%	7.7%
23-Dec-2020	1,119	1,142	23	23	2.0%	2.0%	2.0%
24-Dec-2020	1,116	1,227	111	111	10.0%	10.0%	9.1%
25-Dec-2020	1,038	996	-42	42	-4.1%	4.1%	-4.2%
26-Dec-2020	948	924	-24	24	-2.5%	2.5%	-2.6%
27-Dec-2020	997	1,027	29	29	3.0%	3.0%	2.9%
28-Dec-2020	1,106	1,093	-14	14	-1.3%	1.3%	-1.3%
29-Dec-2020	1,167	1,182	15	15	1.3%	1.3%	1.3%
30-Dec-2020	1,227	1,268	41	41	3.3%	3.3%	3.2%
31-Dec-2020	1,250	1,177	-73	73	-5.8%	5.8%	-6.2%
Minimum	823	837	-73	5	-7.0%	0.5%	-7.5%
Average	1,090	1,098	9	37	0.8%	3.5%	0.7%
Maximum	1,331	1,318	111	111	10.0%	10.0%	9.1%

Table 4: Monthly Peak Utility Load Error Summary - Average Error

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
Jan 2020	1,291	1,268	-23	34	-1.8%	2.7%	-2.0%
Feb 2020	1,287	1,292	5	21	0.5%	1.6%	0.4%
Mar 2020	1,193	1,197	4	26	0.4%	2.1%	0.3%
Apr 2020	961	967	5	31	0.7%	3.2%	0.5%
May 2020	815	805	-10	26	-1.1%	3.2%	-1.2%
Jun 2020	636	629	-7	14	-1.1%	2.2%	-1.2%
Jul 2020	590	582	-7	16	-1.1%	2.5%	-1.3%
Aug 2020	565	563	-2	10	-0.4%	1.7%	-0.4%
Sep 2020	597	586	-12	16	-1.9%	2.8%	-2.0%
Oct 2020	742	734	-8	15	-1.2%	2.1%	-1.3%
Nov 2020	991	984	-7	26	-0.6%	2.6%	-0.7%
Dec 2020	1,090	1,098	9	37	0.8%	3.5%	0.7%
Total Average	897	892	-4	23	-0.6%	2.5%	-0.7%

Table 5: Monthly Peak Utility Load Error Summary - Maximum Error²⁴

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
Jan 2020	1,484	1,472	34	158	2.7%	13.2%	2.6%
Feb 2020	1,497	1,515	49	116	4.5%	8.7%	4.3%
Mar 2020	1,496	1,465	91	91	7.0%	7.0%	6.5%
Apr 2020	1,161	1,116	79	103	8.9%	8.9%	8.2%
May 2020	1,049	981	74	74	10.2%	10.2%	9.2%
Jun 2020	746	746	28	48	4.5%	6.6%	4.3%
Jul 2020	704	629	32	94	5.8%	13.4%	5.5%
Aug 2020	616	603	22	22	4.2%	4.2%	4.0%
Sep 2020	706	692	24	34	4.1%	5.6%	3.9%
Oct 2020	984	1,009	25	49	2.6%	7.1%	2.5%
Nov 2020	1,186	1,204	60	80	6.0%	7.4%	5.7%
Dec 2020	1,331	1,318	111	111	10.0%	10.0%	9.1%
Annual	1,497	1,515	111	158	10.2%	13.4%	9.2%

²⁴ The maximum forecast, the maximum peak, and the maximum error do not necessarily occur on the same day.

Table 6: Error in Ten Highest Utility Loads

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Percent Error	Absolute Percent Error	Actual/Forecast
11-Feb-2020	1,497	1,515	18	18	1.2%	1.2%	1.2%
10-Mar-2020	1,496	1,465	-31	31	-2.1%	2.1%	-2.1%
15-Jan-2020	1,484	1,472	-12	12	-0.8%	0.8%	-0.8%
9-Feb-2020	1,476	1,494	18	18	1.2%	1.2%	1.2%
24-Feb-2020	1,476	1,494	18	18	1.2%	1.2%	1.2%
10-Jan-2020	1,461	1,439	-22	22	-1.5%	1.5%	-1.5%
22-Jan-2020	1,440	1,423	-18	18	-1.2%	1.2%	-1.2%
25-Feb-2020	1,437	1,474	37	37	2.6%	2.6%	2.5%
10-Feb-2020	1,426	1,412	-14	14	-1.0%	1.0%	-1.0%
19-Jan-2020	1,419	1,367	-53	53	-3.7%	3.7%	-3.8%
Average	1,461	1,456	-6	24	-0.4%	1.7%	-0.4%

Table 7: Summary of Forecast Issues

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Absolute Percent Error	Explanation
2-Jan-2020	1,193	1,035	-158	158	13.2%	External technology error
3-Jan-2020	1,204	1,066	-137	137	13.2%	External technology error
6-Jan-2020	1,280	1,314	34	34	2.7%	Error in industrial load
2-Feb-2020	1,343	1,226	-116	116	8.7%	Error in temperature and wind speed forecast; non-uniform customer behaviour
15-Feb-2020	1,120	1,119	-1	1	0.1%	Error in industrial load; non-uniform customer behaviour
26-Feb-2020	1,317	1,258	-59	59	4.5%	Error in industrial load; error in the Nostradamus program
9-Mar-2020	1,311	1,402	91	91	7.0%	Software forecast error
18-Mar-2020	992	1,000	9	9	0.9%	Error in industrial load
23-Mar-2020	1,272	1,253	-18	18	1.4%	External technology error
2-Apr-2020	946	954	8	8	0.8%	Error in industrial load
14-Apr-2020	889	968	79	79	8.9%	Error in industrial load; error in temperature forecast; non-uniform customer behaviour

Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro 2020 Annual Report
Appendix A

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Absolute Percent Error	Explanation
19-Apr-2020	1,161	1,058	-103	103	8.8%	Non-uniform customer behaviour
1-May-2020	781	800	19	19	2.4%	Error in industrial load
12-May-2020	738	733	-5	5	0.6%	Error in the Nostradamus program; export activity over the Maritime Link
24-May-2020	885	910	26	26	2.9%	Error in industrial load; non-uniform customer behaviour
5-Jun-2020	608	616	7	7	1.2%	Export activity over the Maritime Link; error in industrial load
12-Jun-2020	642	628	-14	14	2.1%	Error in industrial load; export activity over the Maritime Link
29-Jun-2020	608	626	17	17	2.9%	Error in industrial load; export activity over the Maritime Link
8-Jul-2020	573	582	9	9	1.6%	Error in industrial load
18-Jul-2020	545	577	32	32	5.8%	External technology error
19-Jul-2020	538	566	28	28	5.2%	External technology error
9-Aug-2020	548	536	-12	12	2.3%	Error in industrial load
10-Aug-2020	582	591	9	9	1.6%	Error in industrial load
27-Aug-2020	572	578	6	6	1.1%	Error in industrial load
8-Sep-2020	573	551	-22	22	3.9%	Export activity over the Maritime Link
9-Sep-2020	591	554	-37	37	6.3%	Error with SCADA data
11-Sep-2020	599	623	24	24	4.1%	Error in industrial load
1-Oct-2020	582	567	-15	15	2.6%	Error in industrial load
18-Oct-2020	635	613	-22	22	3.4%	Export activity over the Maritime Link
21-Oct-2020	712	686	-26	26	3.6%	Error in industrial load; Error due to SCADA System Upgrade
14-Nov-2020	1,089	1,009	-80	80	7.3%	Error in temperature forecast; non-uniform customer behaviour
17-Nov-2020	886	934	48	48	5.4%	Error in industrial load; error in wind speed forecast
19-Nov-2020	1,152	1,084	-67	67	5.8%	Export activity over the Maritime Link; error in temperature and cloud cover forecast

Date	Actual Utility Peak (MW)	Forecast Utility Peak (MW)	Error (MW)	Absolute Error (MW)	Absolute Percent Error	Explanation
10-Dec-2020	1,067	1,086	19	19	1.8%	Error in industrial load
19-Dec-2020	1,174	1,184	10	10	0.8%	Export activity over the Maritime Link
30-Dec-2020	1,227	1,268	41	41	3.3%	Error in industrial load; non-uniform customer behaviour